



Corrigendum to EN 61936-1:2010

English version

Add the following SNCs in Annex ZA:

<u>Clause</u>	<u>Special national condition</u>
----------------------	--

6.2.9.5	Iceland
----------------	----------------

Minimum depth of a buried cable is 0,7 m.

7.2.6	Iceland
--------------	----------------

Minimum height of the external fence is 2 500 mm.

7.7	Iceland
------------	----------------

Minimum height H' of live parts above accessible surfaces to the general public shall be: $H' = 5\,500$ mm for rated voltages U_m up to 52 kV.

February 2013