



Corrigendum to HD 60364-7-710:2012

English version

Add the following special national conditions to the Annex ZA:

Subclause	Special national conditions
710.415.2.2	<p>Slovakia</p> <p>Replace the first paragraph as follows:</p> <p>In medical locations of group 1 the resistance of the protective conductors, including the resistance of the connections, between the terminals for the protective conductor of socket-outlets and of fixed equipment or any extraneous-conductive-parts and the equipotential bonding bus bar, shall not exceed 0,2 Ω.</p>
710.512.2.1	<p>Slovakia</p> <p>Replace the paragraph above NOTE 4 as follows:</p> <p>Electrical devices (e.g. socket-outlets and switches) shall be installed at a distance of at least 0,2 m in all directions (centre to centre) from any medical gas-outlets, so as to minimize the risk of ignition of flammable gases.</p>
Table B.1, line 19	<p>Slovakia</p> <p>In Slovakia, haemodialysis rooms fall into group 2.</p>

March 2013