

Information technology - Data centre facilities and  
infrastructures - Part 1: General concepts

## EESTI STANDARDI EESSÕNA

## NATIONAL FOREWORD

See Eesti standard EVS-EN 50600-1:2019 sisaldab Euroopa standardi EN 50600-1:2019 ingliskeelset teksti.	This Estonian standard EVS-EN 50600-1:2019 consists of the English text of the European standard EN 50600-1:2019.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 07.06.2019.	Date of Availability of the European standard is 07.06.2019.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile [standardiosakond@evs.ee](mailto:standardiosakond@evs.ee).

ICS 35.020, 35.160

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:  
Koduleht [www.evs.ee](http://www.evs.ee); telefon 605 5050; e-post [info@evs.ee](mailto:info@evs.ee)

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Homepage [www.evs.ee](http://www.evs.ee); phone +372 605 5050; e-mail [info@evs.ee](mailto:info@evs.ee)

## English Version

**Information technology - Data centre facilities and infrastructures  
- Part 1: General concepts**

Technologie de l'information - Installation et infrastructures  
de centres de traitement de données - Partie 1: Concepts  
généraux

Informationstechnik - Einrichtungen und Infrastrukturen von  
Rechenzentren - Teil 1: Allgemeine Konzepte

This European Standard was approved by CENELEC on 2019-04-29. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels**

## Contents

<b>European foreword</b>	<b>3</b>
<b>Introduction</b>	<b>4</b>
<b>1 Scope</b>	<b>6</b>
<b>2 Normative references</b>	<b>6</b>
<b>3 Terms, definitions and abbreviations</b>	<b>7</b>
3.1 Terms and definitions	7
3.2 Abbreviations	11
<b>4 Conformance</b>	<b>11</b>
<b>5 Business risk analysis</b>	<b>12</b>
5.1 General	12
5.2 Business impact analysis	12
5.3 Risk analysis	13
<b>6 Data centre design overview</b>	<b>14</b>
6.1 General	14
6.2 Spaces and facilities	15
<b>7 Classification system for the design of data centre facilities and infrastructures</b>	<b>17</b>
7.1 General	17
7.2 Availability	17
7.2.1 General	17
7.2.2 Single-site data centres	17
7.2.3 Multi-site data centres	20
7.3 Physical security	20
7.3.1 General	20
7.3.2 Protection against unauthorised access	20
7.3.3 Protection against intrusion	20
7.3.4 Protection against environmental events	21
7.4 Energy efficiency enablement	21
7.4.1 General	21
7.4.2 Power distribution system	22
7.4.3 Environmental monitoring and control	22
7.4.4 Operational processes and KPIs	22
<b>8 Design and implementation process</b>	<b>22</b>
8.1 General	22
8.2 Design phases	23
8.2.1 Phase 1 - Strategy	23
8.2.2 Phase 2 - Objectives	24
8.2.3 Phase 3 - System specifications	24
8.2.4 Phase 4 - Design proposal	24
8.2.5 Phase 5 - Decision	25
8.2.6 Phase 6 - Functional design	25
8.2.7 Phase 7 - Approval	25
8.2.8 Phase 8 - Final design and project plan	25
8.2.9 Phase 9 - Contract	25
8.2.10 Phase 10 - Construction	25
8.2.11 Phase 11 - Operation	25
<b>9 Design Principles</b>	<b>26</b>
9.1 Design reference documentation	26
9.2 Design principles to support energy efficiency	26
9.3 Design principles for EMI	26
9.4 Design principles to support operational excellence	26
<b>Annex A (informative) Overall availability and infrastructure availability</b>	<b>27</b>
<b>Annex B (informative) Availability description</b>	<b>30</b>
<b>Bibliography</b>	<b>31</b>

## European foreword

This document (EN 50600-1:2019) has been prepared by CLC/TC 215 “Electrotechnical aspects of telecommunication equipment”.

The following dates are fixed:

- latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2020-04-29
- latest date by which the national standards conflicting with this document have to be withdrawn (dow) 2022-04-29

This document supersedes EN 50600-1:2012.

The following major modifications have been made compared to EN 50600-1:2012:

- a) reference to Key Performance Indicators of EN 50600-4-X included;
- b) Clause 7 (Availability) has been revised;
- c) the design processes (Clause 8) and design principles (Clause 9) have been moved from an annex to the main body of the document;
- d) existing Annex A has been removed;
- e) new Annexes A and B have been added.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association.

## Introduction

The unrestricted access to internet-based information demanded by the information society has led to an exponential growth of both internet traffic and the volume of stored/retrieved data. Data centres are housing and supporting the information technology and network telecommunications equipment for data processing, data storage and data transport. They are required both by network operators (delivering those services to customer premises) and by enterprises within those customer premises.

Data centres usually need to provide modular, scalable and flexible facilities and infrastructures to easily accommodate the rapidly changing requirements of the market. In addition, energy consumption of data centres has become critical both from an environmental point of view (reduction of environmental footprint) and with respect to economical considerations (cost of energy) for the data centre operator.

The implementation of data centres varies in terms of:

- a) purpose (enterprise, co-location, co-hosting or network operator facilities);
- b) security level;
- c) physical size;
- d) accommodation (mobile, temporary and permanent constructions).

The needs of data centres also vary in terms of availability of service, the provision of security and the objectives for energy efficiency. These needs and objectives influence the design of data centres in terms of building construction, power distribution, environmental control, telecommunications cabling and physical security as well as the operation of the data centre. Effective management and operational information is required to monitor achievement of the defined needs and objectives.

Recognizing the substantial resource consumption, particularly of energy, of larger data centres, it is also important to provide tools for the assessment of that consumption both in terms of overall value and of source mix and to provide Key Performance Indicators (KPIs) to evaluate trends and drive performance improvements.

At the time of publication of this European Standard, EN 50600 series is designed as a framework of standards and technical reports covering the design, the operation and management as well as the key performance indicators for energy efficient operation of the data centre.

The EN 50600-2 series defines the requirements for the data centre design.

The EN 50600-3 series defines the requirements for the operation and the management of the data centre.


The EN 50600-4 series defines the key performance indicators for the data centre.

The CLC/TR 50600-99-X Technical Reports cover recommended practices and guidance for specific topics around data centre operation and design.

This series of European Standards specifies requirements and recommendations to support the various parties involved in the design, planning, procurement, integration, installation, operation and maintenance of facilities and infrastructures within data centres. These parties include:

- 1) owners, operators, facility managers, ICT managers, project managers, main contractors;
- 2) consulting engineers, architects, building designers and builders, system and installation designers, auditors, test and commissioning agents;
- 3) facility and infrastructure integrators, suppliers of equipment;
- 4) installers, maintainers.

The inter-relationship of the standards and technical reports within the EN 50600 series is shown in Figure 1.



**Figure 1 – Schematic relationship between EN 50600 series of standards**

This European Standard specifies general requirements for data centres for all kinds of data centres irrespective of their size and physical construction. It introduces a classification system for availability, physical security and energy efficiency enablement.

EN 50600-2-X standards specify requirements and recommendations for particular facilities and infrastructures to support the relevant classification for “availability”, “physical security” and “energy efficiency enablement” selected from EN 50600-1.

EN 50600-3-X documents specify requirements and recommendations for data centre operations, processes and management.

EN 50600-4-X documents specify requirements and recommendations for key performance indicators (KPIs) used to assess and improve the resource usage efficiency and effectiveness, respectively, of a data centre.

This European Standard is intended for use by and collaboration between architects, building designers and builders, system and installation designers.

This series of European Standards does not address the selection of information technology and network telecommunications equipment, software and associated configuration issues.

## 1 Scope

This document:

- a) describes the general principles for data centres upon which the requirements of the EN 50600 series are based;
- b) defines the common aspects of data centres including terminology, parameters and reference models (functional elements and their accommodation) addressing both the size and complexity of their intended purpose;
- c) describes general aspects of the facilities and infrastructures required to support data centres;
- d) specifies a classification system, based upon the key criteria of “availability”, “security” and “energy-efficiency” over the planned lifetime of the data centre, for the provision of effective facilities and infrastructure;
- e) details the issues to be addressed in a business risk and operating cost analysis enabling application of the classification of the data centre;
- f) provides reference to operation and management of data centres;
- g) introduces the concepts of Key Performance Indicators (KPIs) for resource management of data centre facilities and infrastructures.

The following topics are outside of the scope of this series of European Standards:

- 1) the selection of information technology and network telecommunications equipment, software and associated configuration issues are outside the scope of this European Standard;
- 2) quantitative analysis of overall service availability resulting from multi-site data centres;
- 3) safety and electromagnetic compatibility (EMC) requirements (covered by other standards and regulations. However, information given in this European Standard can be of assistance in meeting these standards and regulations).

## 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 50600-2-1, *Information technology - Data centre facilities and infrastructures - Part 2-1: Building construction*

EN 50600-2-2, *Information technology - Data centre facilities and infrastructures - Part 2-2: Power supply and distribution*

EN 50600-2-3, *Information technology - Data centre facilities and infrastructures - Part 2-3: Environmental control*

EN 50600-2-4, *Information technology - Data centre facilities and infrastructures - Part 2-4: Telecommunications cabling infrastructure*

EN 50600-2-5, *Information technology - Data centre facilities and infrastructures - Part 2-5: Security systems*



EN 50600-3-1, *Information technology - Data centre facilities and infrastructures - Part 3-1: Management and operational information*

EN 50600-4-X (all parts), *Information technology – Data centre facilities and infrastructures – Part 4-X*

### 3 Terms, definitions and abbreviations

#### 3.1 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

##### 3.1.1

##### **availability**

ability of an item to be in a state to perform a required function under given conditions at a given instant of time or over a given time interval, assuming that the required external resources are provided

[SOURCE: IEC 60050-191:1990, 191-02-05]

##### 3.1.2

##### **building entrance facility**

facility that provides all necessary mechanical and electrical services and which complies with all relevant regulations for the entry of specific services or infrastructures into a building

[SOURCE: EN 50173-1:2018, 3.1.18 – modified: replaced “telecommunication cables” with “specific infrastructures or services” and deleted „and which can enable transmission from outdoor to indoor cable”]

##### 3.1.3

##### **building security**

facilities and systems necessary to provide the required levels of security at the entrance to and within the building containing the data centre

##### 3.1.4

##### **cabinet**

enclosed construction for housing closures and other information technology equipment

[SOURCE: EN 50174-1:2018, 3.1.7]

##### 3.1.5

##### **co-hosting data centre**

data centre in which multiple customers are provided with access to network(s), servers and storage equipment on which they operate their own services/applications

Note 1 to entry: Both the information technology equipment and the support infrastructure of the building are provided as a service by the data centre operator.

[SOURCE: EN 50174-2:2018, 3.1.2]