

Madalpingelised aparaadikoosted. Osa 1: Üldreeglid

**Low-voltage switchgear and controlgear assemblies -
Part 1: General rules**

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 61439-1:2012 sisaldab Euroopa standardi EN 61439-1:2011 ingliskeelset teksti.	This Estonian standard EVS-EN 61439-1:2012 consists of the English text of the European standard EN 61439-1:2011.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 28.10.2011.	Date of Availability of the European standard is 28.10.2011.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 29.130.20

Võtmesõnad: controlgear, low-voltage, switchgear,

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Aru 10, 10317 Tallinn, Eesti; www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:
Aru 10, 10317 Tallinn, Estonia; www.evs.ee; phone 605 5050; e-mail info@evs.ee

English version

**Low-voltage switchgear and controlgear assemblies -
Part 1: General rules
(IEC 61439-1:2011)**

Ensembles d'appareillage
à basse tension -
Partie 1: Règles générales
(CEI 61439-1:2011)

Niederspannungs-
Schaltgerätekombinationen -
Teil 1: Allgemeine Festlegungen
(IEC 61439-1:2011)

This European Standard was approved by CENELEC on 2011-09-23. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 17D/441/FDIS, future edition 2 of IEC 61439-1, prepared by SC 17D, "Low-voltage switchgear and controlgear assemblies", of IEC TC 17, "Switchgear and controlgear" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61439-1:2011.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2012-06-23
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2014-09-23

This document supersedes EN 61439-1:2009.

EN 61439-1:2011 includes the following significant technical changes with respect to EN 61439-1:2009:

- revision of service conditions in Clause 7;
- numerous changes regarding verification methods in Clause 10;
- modification of routine verification in respect of clearances and creepage distances (see 11.3);
- adaption of the tables in Annex C and Annex D to the revised requirements and verification methods;
- shifting of tables from Annex H to new Annex N;
- new Annex O with guidance on temperature rise verification;
- new Annex P with a verification method for short-circuit withstand strength (integration of the content of IEC/TR 61117);
- update of normative references;
- general editorial review.

NOTE It should be noted that when a dated reference to EN 60439-1 is made in another Part of the EN 60439 series of assembly standards not yet transferred into the new EN 61439 series, the superseded EN 60439-1 still applies (see also the Introduction below).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For the relationship with EU Directive see informative Annex ZZ, which is an integral part of this document.

Endorsement notice

The text of the International Standard IEC 61439-1:2011 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60038	NOTE	Harmonized as EN 60038.
IEC 60079 series	NOTE	Harmonized in EN 60079 series.
IEC 60112:2003	NOTE	Harmonized as EN 60112:2003 (not modified).
IEC 60204 series	NOTE	Harmonized in EN 60204 series.
IEC 60204-1	NOTE	Harmonized as EN 60204-1.
IEC 60228:2004	NOTE	Harmonized as EN 60228:2005 (not modified).
IEC 60947 series	NOTE	Harmonized in EN 60947 series.
IEC 61000-3-2:2005	NOTE	Harmonized as EN 61000-3-2:2006 (not modified).
IEC 61000-3-3	NOTE	Harmonized as EN 61000-3-3.
IEC 61000-3-11	NOTE	Harmonized as EN 61000-3-11.
IEC 61000-3-12	NOTE	Harmonized as EN 61000-3-12.
IEC 61000-6-1	NOTE	Harmonized as EN 61000-6-1.
IEC 61000-6-2	NOTE	Harmonized as EN 61000-6-2.
IEC 61000-6-3	NOTE	Harmonized as EN 61000-6-3.
IEC 61082 series	NOTE	Harmonized in EN 61082 series.
IEC 61140:2001	NOTE	Harmonized as EN 61140:2002 (not modified).
IEC 61241 series	NOTE	Harmonized in EN 61241 series.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60068-2-2	2007	Environmental testing - Part 2-2: Tests - Test B: Dry heat	EN 60068-2-2	2007
IEC 60068-2-11	1981	Environmental testing - Part 2: Tests - Test Ka: Salt mist	EN 60068-2-11	1999
IEC 60068-2-30	2005	Environmental testing - Part 2-30: Tests - Test Db: Damp heat, cyclic (12 h + 12 h cycle)	EN 60068-2-30	2005
IEC 60073	2002	Basic and safety principles for man-machine interface, marking and identification - Coding principles for indicators and actuators	EN 60073	2002
IEC 60085	2007	Electrical insulation - Thermal evaluation and designation	EN 60085	2008
IEC 60216	Series	Electrical insulating materials - Properties of thermal endurance	EN 60216	Series
IEC 60227-3 (mod)	1993	Polyvinyl chloride insulated cables of rated voltages up to and including 450/750 V - Part 3: Non-sheathed cables for fixed wiring	HD 21.3 S3 ¹⁾ + A1 + A2	1995 1999 2008
IEC 60245-3	1994	Rubber insulated cables - Rated voltages up to and including 450/750 V - Part 3: Heat resistant silicone insulated cables	-	-
IEC 60245-4 (mod)	1994	Cables of rated voltages up to and including 450/750 V and having cross-linked insulation - Part 4: Cords and flexible cables	HD 22.4 S3 ²⁾ + A1 + A2	1995 1999 2002
IEC 60364	Series	Low-voltage electrical installations	HD 60364	Series
IEC 60364-4-41 (mod)	2005	Low-voltage electrical installations - Part 4-41: Protection for safety - Protection against electric shock	HD 60364-4-41 + corr. July	2007 2007
IEC 60364-4-44 (mod)	2007	Low voltage electrical installations - Part 4-44: Protection for safety - Protection against voltage disturbances and electromagnetic disturbances	HD 60364-4-444 + corr. July	2010 2010
IEC 60364-5-52 (mod)	2009	Low-voltage electrical installations - Part 5-52: Selection and erection of electrical equipment - Wiring systems	HD 60364-5-52	2011
IEC 60364-5-53	2001	Electrical installations of buildings - Part 5-53: Selection and erection of electrical equipment - Isolation, switching and control	-	-

¹⁾ HD 21.3 S3 is superseded by EN 50525-2-31:2011.

²⁾ HD 22.4 S3 is superseded by HD 22.4 S4:2004.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60364-5-54	2011	Low-voltage electrical installations - Part 5-54: Selection and erection of electrical equipment - Earthing arrangements and protective conductors	HD 60364-5-54	2011
IEC 60439	Series	Low-voltage switchgear and controlgear assemblies	EN 60439	Series
IEC 60445	2010	Basic and safety principles for man-machine interface, marking and identification - Identification of equipment terminals, conductor terminations and conductors	EN 60445	2010
IEC 60447	2004	Basic and safety principles for man-machine interface, marking and identification - Actuating principles	EN 60447	2004
IEC 60529	1989	Degrees of protection provided by enclosures (IP Code)	EN 60529 + corr. May	1991 1993
IEC 60664-1	2007	Insulation coordination for equipment within low-voltage systems - Part 1: Principles, requirements and tests	EN 60664-1	2007
IEC 60695-2-10	2000	Fire hazard testing - Part 2-10: Glowing/hot-wire based test methods - Glow-wire apparatus and common test procedure	EN 60695-2-10	2001
IEC 60695-2-11	2000	Fire hazard testing - Part 2-11: Glowing/hot-wire based test methods - Glow-wire flammability test method for end-products	EN 60695-2-11	2001
IEC 60695-11-5	2004	Fire hazard testing - Part 11-5: Test flames - Needle-flame test method - Apparatus, confirmatory test arrangement and guidance	EN 60695-11-5	2005
IEC 60865-1	1993	Short-circuit currents - Calculation of effects - Part 1: Definitions and calculation methods	EN 60865-1	1993
IEC/TR3 60890	1987	A method of temperature-rise assessment by extrapolation for partially type-tested assemblies (PTTA) of low-voltage switchgear and controlgear	CLC/TR 60890 ³⁾	2002
IEC 60947-1	2007	Low-voltage switchgear and controlgear - Part 1: General rules	EN 60947-1	2007
IEC 61000-4-2	2008	Electromagnetic compatibility (EMC) - Part 4-2: Testing and measurement techniques - Electrostatic discharge immunity test	EN 61000-4-2	2009
IEC 61000-4-3	2006	Electromagnetic compatibility (EMC) - Part 4-3: Testing and measurement techniques - Radiated, radio-frequency, electromagnetic field immunity test	EN 61000-4-3	2006
IEC 61000-4-4	2004	Electromagnetic compatibility (EMC) - Part 4-4: Testing and measurement techniques - Electrical fast transient/burst immunity test	EN 61000-4-4	2004

³⁾ CLC/TR 60890 includes A1:1995 to IEC/TR3 60890 + corr. March 1988.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61000-4-5	2005	Electromagnetic compatibility (EMC) - Part 4-5: Testing and measurement techniques - Surge immunity test	EN 61000-4-5	2006
IEC 61000-4-6	2008	Electromagnetic compatibility (EMC) - Part 4-6: Testing and measurement techniques - Immunity to conducted disturbances, induced by radio-frequency fields	EN 61000-4-6	2009
IEC 61000-4-8	2009	Electromagnetic compatibility (EMC) - Part 4-8: Testing and measurement techniques - Power frequency magnetic field immunity test	EN 61000-4-8	2010
IEC 61000-4-11	2004	Electromagnetic compatibility (EMC) - Part 4-11: Testing and measurement techniques - Voltage dips, short interruptions and voltage variations immunity tests	EN 61000-4-11	2004
IEC 61000-4-13	2002	Electromagnetic compatibility (EMC) - Part 4-13: Testing and measurement techniques - Harmonics and interharmonics including mains signalling at a.c. power port, low frequency immunity tests	EN 61000-4-13	2002
IEC 61000-6-4	2006	Electromagnetic compatibility (EMC) - Part 6-4: Generic standards - Emission standard for industrial environments	EN 61000-6-4	2007
IEC 61082-1	-	Preparation of documents used in electrotechnology - Part 1: Rules	EN 61082-1	-
IEC 61180	Series	High-voltage test techniques for low-voltage equipment	EN 61180	Series
IEC/TS 61201	2007	Use of conventional touch voltage limits - Application guide	-	-
IEC 61439	Series	Low-voltage switchgear and controlgear assemblies	EN 61439	Series
IEC 62208	-	Empty enclosures for low-voltage switchgear and controlgear assemblies - General requirements	EN 62208	-
IEC 62262	2002	Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code)	EN 62262	2002
IEC 81346-1	-	Industrial systems, installations and equipment and industrial products - Structuring principles and reference designations - Part 1: Basic rules	EN 81346-1	-
IEC 81346-2	-	Industrial systems, installations and equipment and industrial products - Structuring principles and reference designations - Part 2: Classification of objects and codes for classes	EN 81346-2	-
CISPR 11 (mod)	2009	Industrial, scientific and medical equipment - Radio-frequency disturbance characteristics - Limits and methods of measurement	EN 55011	2009

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
CISPR 22	-	Information technology equipment - Radio disturbance characteristics - Limits and methods of measurement	EN 55022	-
ISO 178	2001	Plastics - Determination of flexural properties	EN ISO 178	2003
ISO 179	Series	Plastics - Determination of Charpy impact properties	EN ISO 179	Series
ISO 2409	2007	Paints and varnishes - Cross-cut test	EN ISO 2409	2007
ISO 4628-3	2003	Paints and varnishes - Evaluation of degradation of coatings - Designation of quantity and size of defects, and of intensity of uniform changes in appearance - Part 3: Assessment of degree of rusting	EN ISO 4628-3	2003
ISO 4892-2	2006	Plastics - Methods of exposure to laboratory light sources - Part 2: Xenon-arc lamps	EN ISO 4892-2	2006

Annex ZZ (informative)

Coverage of Essential Requirements of EC Directive 2004/108/EC

This European Standard has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association and within its scope the standard covers all relevant essential requirements as given in Article 1 of Annex I of the EC Directive 2004/108/EC.

This Part 1 of the EN 61439 series alone does not give presumption of conformity with the essential requirements of the EMC Directive without another relevant part of the series (e.g. EN 61439-2 for power switchgear and controlgear assemblies). These product parts call up the applicable EMC requirements of EN 61439-1 for assemblies within their specific scope.

WARNING: Other requirements and other EC Directives may be applicable to the products falling within the scope of this standard.

CONTENTS

FOREWORD.....	8
INTRODUCTION.....	11
1 Scope.....	12
2 Normative references	12
3 Terms and definitions	15
3.1 General terms	15
3.2 Constructional units of ASSEMBLIES	17
3.3 External design of ASSEMBLIES.....	18
3.4 Structural parts of ASSEMBLIES	18
3.5 Conditions of installation of ASSEMBLIES.....	20
3.6 Insulation characteristics	20
3.7 Protection against electric shock	23
3.8 Characteristics	25
3.9 Verification	27
3.10 Manufacturer/user	28
4 Symbols and abbreviations.....	28
5 Interface characteristics	29
5.1 General.....	29
5.2 Voltage ratings	29
5.2.1 Rated voltage (U_n) (of the ASSEMBLY)	29
5.2.2 Rated operational voltage (U_e) (of a circuit of an ASSEMBLY).....	29
5.2.3 Rated insulation voltage (U_i) (of a circuit of an ASSEMBLY)	29
5.2.4 Rated impulse withstand voltage (U_{imp}) (of the ASSEMBLY).....	29
5.3 Current ratings	30
5.3.1 Rated current of the ASSEMBLY (I_{nA}).....	30
5.3.2 Rated current of a circuit (I_{nC})	30
5.3.3 Rated peak withstand current (I_{pk}).....	30
5.3.4 Rated short-time withstand current (I_{cw}) (of a circuit of an ASSEMBLY)	30
5.3.5 Rated conditional short-circuit current of an ASSEMBLY (I_{cc}).....	30
5.4 Rated diversity factor (RDF)	31
5.5 Rated frequency (f_n).....	31
5.6 Other characteristics	31
6 Information	32
6.1 ASSEMBLY designation marking	32
6.2 Documentation	32
6.2.1 Information relating to the ASSEMBLY	32
6.2.2 Instructions for handling, installation, operation and maintenance	32
6.3 Device and/or component identification	33
7 Service conditions	33
7.1 Normal service conditions	33
7.1.1 Ambient air temperature	33
7.1.2 Humidity conditions	33
7.1.3 Pollution degree	33
7.1.4 Altitude.....	34
7.2 Special service conditions	34
7.3 Conditions during transport, storage and installation	35

8	Constructional requirements	35
8.1	Strength of materials and parts	35
8.1.1	General	35
8.1.2	Protection against corrosion	35
8.1.3	Properties of insulating materials	35
8.1.4	Resistance to ultra-violet radiation	36
8.1.5	Mechanical strength	36
8.1.6	Lifting provision	36
8.2	Degree of protection provided by an ASSEMBLY enclosure	36
8.2.1	Protection against mechanical impact	36
8.2.2	Protection against contact with live parts, ingress of solid foreign bodies and water	36
8.2.3	ASSEMBLY with removable parts	37
8.3	Clearances and creepage distances	37
8.3.1	General	37
8.3.2	Clearances	38
8.3.3	Creepage distances	38
8.4	Protection against electric shock	39
8.4.1	General	39
8.4.2	Basic protection	39
8.4.3	Fault protection	40
8.4.4	Protection by total insulation	42
8.4.5	Limitation of steady-state touch current and charge	43
8.4.6	Operating and servicing conditions	43
8.5	Incorporation of switching devices and components	45
8.5.1	Fixed parts	45
8.5.2	Removable parts	45
8.5.3	Selection of switching devices and components	46
8.5.4	Installation of switching devices and components	46
8.5.5	Accessibility	46
8.5.6	Barriers	47
8.5.7	Direction of operation and indication of switching positions	47
8.5.8	Indicator lights and push-buttons	47
8.6	Internal electrical circuits and connections	47
8.6.1	Main circuits	47
8.6.2	Auxiliary circuits	48
8.6.3	Bare and insulated conductors	48
8.6.4	Selection and installation of non-protected live conductors to reduce the possibility of short-circuits	49
8.6.5	Identification of the conductors of main and auxiliary circuits	49
8.6.6	Identification of the protective conductor (PE, PEN) and of the neutral conductor (N) of the main circuits	49
8.7	Cooling	49
8.8	Terminals for external conductors	49
9	Performance requirements	51
9.1	Dielectric properties	51
9.1.1	General	51
9.1.2	Power-frequency withstand voltage	51
9.1.3	Impulse withstand voltage	51

9.1.4	Protection of surge protective devices	51
9.2	Temperature rise limits	52
9.3	Short-circuit protection and short-circuit withstand strength	52
9.3.1	General	52
9.3.2	Information concerning short-circuit withstand strength	52
9.3.3	Relationship between peak current and short-time current	53
9.3.4	Co-ordination of protective devices	53
9.4	Electromagnetic compatibility (EMC)	53
10	Design verification	54
10.1	General	54
10.2	Strength of materials and parts	55
10.2.1	General	55
10.2.2	Resistance to corrosion	55
10.2.3	Properties of insulating materials	56
10.2.4	Resistance to ultra-violet (UV) radiation	58
10.2.5	Lifting	58
10.2.6	Mechanical impact	59
10.2.7	Marking	59
10.3	Degree of protection of ASSEMBLIES	59
10.4	Clearances and creepage distances	59
10.5	Protection against electric shock and integrity of protective circuits	60
10.5.1	Effectiveness of the protective circuit	60
10.5.2	Effective earth continuity between the exposed conductive parts of the ASSEMBLY and the protective circuit	60
10.5.3	Short-circuit withstand strength of the protective circuit	60
10.6	Incorporation of switching devices and components	61
10.6.1	General	61
10.6.2	Electromagnetic compatibility	61
10.7	Internal electrical circuits and connections	61
10.8	Terminals for external conductors	61
10.9	Dielectric properties	61
10.9.1	General	61
10.9.2	Power-frequency withstand voltage	61
10.9.3	Impulse withstand voltage	62
10.9.4	Testing of enclosures made of insulating material	64
10.9.5	External operating handles of insulating material	64
10.10	Verification of temperature rise	64
10.10.1	General	64
10.10.2	Verification by testing	64
10.10.3	Derivation of ratings for similar variants	70
10.10.4	Verification assessment	71
10.11	Short-circuit withstand strength	74
10.11.1	General	74
10.11.2	Circuits of ASSEMBLIES which are exempted from the verification of the short-circuit withstand strength	74
10.11.3	Verification by comparison with a reference design – Utilising a check list	75
10.11.4	Verification by comparison with a reference design – Utilising calculation	75
10.11.5	Verification by test	75

10.12 Electromagnetic compatibility (EMC)	80
10.13 Mechanical operation	80
11 Routine verification	80
11.1 General	80
11.2 Degree of protection of enclosures	81
11.3 Clearances and creepage distances	81
11.4 Protection against electric shock and integrity of protective circuits	81
11.5 Incorporation of built-in components	81
11.6 Internal electrical circuits and connections	81
11.7 Terminals for external conductors	81
11.8 Mechanical operation	82
11.9 Dielectric properties	82
11.10 Wiring, operational performance and function	82
Annex A (normative) Minimum and maximum cross-section of copper conductors suitable for connection to terminals for external conductors (see 8.8)	90
Annex B (normative) Method of calculating the cross-sectional area of protective conductors with regard to thermal stresses due to currents of short duration	91
Annex C (informative) User information template	92
Annex D (informative) Design verification	96
Annex E (informative) Rated diversity factor	97
Annex F (normative) Measurement of clearances and creepage distances	106
Annex G (normative) Correlation between the nominal voltage of the supply system and the rated impulse withstand voltage of the equipment	111
Annex H (informative) Operating current and power loss of copper conductors	113
Annex I (Void)	115
Annex J (normative) Electromagnetic compatibility (EMC)	116
Annex K (normative) Protection by electrical separation	123
Annex L (informative) Clearances and creepage distances for North American region	126
Annex M (informative) North American temperature rise limits	127
Annex N (normative) Operating current and power loss of bare copper bars	128
Annex O (informative) Guidance on temperature rise verification	130
Annex P (normative) Verification of the short-circuit withstand strength of busbar structures by comparison with a tested reference design by calculation	135
Bibliography	139
Figure E.1 – Typical ASSEMBLY	98
Figure E.2 – Example 1: Table E.1 – Functional unit loading for an ASSEMBLY with a rated diversity factor of 0,8	100
Figure E.3 – Example 2: Table E.1 – Functional unit loading for an ASSEMBLY with a rated diversity factor of 0,8	101
Figure E.4 – Example 3: Table E.1 – Functional unit loading for an ASSEMBLY with a rated diversity factor of 0,8	102
Figure E.5 – Example 4: Table E.1 – Functional unit loading for an ASSEMBLY with a rated diversity factor of 0,8	103
Figure E.6 – Example of average heating effect calculation	104
Figure E.7 – Example graph for the relation between the equivalent RDF and the parameters at intermittent duty at $t_1 = 0,5$ s, $I_1 = 7 \cdot I_2$ at different cycle times	105

Figure E.8 – Example graph for the relation between the equivalent RDF and the parameters at intermittent duty at $I_1 = I_2$ (no starting overcurrent).....	105
Figure F.1 – Measurement of ribs	110
Figure J.1 – Examples of ports	116
Figure O.1 – Temperature rise verification methods	134
Figure P.1 – Tested busbar structure (TS)	135
Figure P.2 – Non tested busbar structure (NTS).....	136
Figure P.3 – Angular busbar configuration with supports at the corners	138
Table 1 – Minimum clearances in air ^a (8.3.2).....	82
Table 2 – Minimum creepage distances (8.3.3)	83
Table 3 – Cross-sectional area of a copper protective conductor (8.4.3.2.2)	83
Table 4 – Conductor selection and installation requirements (8.6.4).....	84
Table 5 – Minimum terminal capacity for copper protective conductors (PE, PEN) (8.8)	84
Table 6 – Temperature-rise limits (9.2)	85
Table 7 – Values for the factor n^a (9.3.3)	86
Table 8 – Power-frequency withstand voltage for main circuits (10.9.2)	86
Table 9 – Power-frequency withstand voltage for auxiliary and control circuits (10.9.2).....	86
Table 10 – Impulse withstand test voltages (10.9.3).....	87
Table 11 – Copper test conductors for rated currents up to 400 A inclusive (10.10.2.3.2).....	87
Table 12 – Copper test conductors for rated currents from 400 A to 4 000 A (10.10.2.3.2).....	88
Table 13 – Short-circuit verification by comparison with a reference design: check list (10.5.3.3, 10.11.3 and 10.11.4).....	88
Table 14 – Relationship between prospective fault current and diameter of copper wire	89
Table A.1 – Cross-section of copper conductors suitable for connection to terminals for external conductors	90
Table B.1 – Values of k for insulated protective conductors not incorporated in cables, or bare protective conductors in contact with cable covering.....	91
Table C.1 – Template	92
Table D.1 – List of design verifications to be performed	96
Table E.1 – Examples of loading for an ASSEMBLY with a rated diversity factor of 0,8	99
Table E.2 – Example of loading of a group of circuits (Section B – Figure E.1) with a rated diversity factor of 0,9	104
Table E.3 – Example of loading of a group of circuits (Sub-distribution board – Figure E.1) with a rated diversity factor of 0,9.....	104
Table F.1 – Minimum width of grooves.....	106
Table G.1 – Correspondence between the nominal voltage of the supply system and the equipment rated impulse withstand voltage.....	112
Table H.1 – Operating current and power loss of single-core copper cables with a permissible conductor temperature of 70 °C (ambient temperature inside the ASSEMBLY: 55 °C).....	113
Table H.2 – Reduction factor k_1 for cables with a permissible conductor temperature of 70 °C (extract from IEC 60364-5-52:2009, Table B.52.14).....	114
Table J.1 – Tests for EMC immunity for environment A (see J.10.12.1).....	120
Table J.2 – Tests for EMC immunity for environment B (see J.10.12.1).....	121

Table J.3 – Acceptance criteria when electromagnetic disturbances are present.....	122
Table K.1 – Maximum disconnecting times for TN systems	125
Table L.1 – Minimum clearances in air	126
Table L.2 – Minimum creepage distances	126
Table M.1 – North American temperature rise limits	127
Table N.1 – Operating current and power loss of bare copper bars with rectangular cross-section, run horizontally and arranged with their largest face vertical, frequency 50 Hz to 60 Hz (ambient temperature inside the ASSEMBLY: 55 °C, temperature of the conductor 70 °C).....	128
Table N.2 – Factor k_4 for different temperatures of the air inside the ASSEMBLY and/or for the conductors	129

This document is a preview generated by EVS

INTRODUCTION

The purpose of this standard is to harmonize as far as practicable all rules and requirements of a general nature applicable to low-voltage switchgear and controlgear assemblies (ASSEMBLIES) in order to obtain uniformity of requirements and verification for ASSEMBLIES and to avoid the need for verification to other standards. All those requirements for the various ASSEMBLIES standards which can be considered as general have therefore been gathered in this basic standard together with specific subjects of wide interest and application, e.g. temperature rise, dielectric properties, etc.

For each type of low-voltage switchgear and controlgear assembly only two main standards are necessary to determine all requirements and the corresponding methods of verification:

- this basic standard referred to as “Part 1” in the specific standards covering the various types of low-voltage switchgear and controlgear assemblies;
- the specific ASSEMBLY standard hereinafter also referred to as the relevant ASSEMBLY standard.

For a general rule to apply to a specific ASSEMBLY standard, it should be explicitly referred to by quoting the relevant clause or sub-clause number of this standard followed by “Part 1” e.g. “9.1.3 of Part 1”.

A specific ASSEMBLY standard may not require and hence need not call up a general rule where it is not applicable, or it may add requirements if the general rule is deemed inadequate in the particular case but it may not deviate from it unless there is substantial technical justification detailed in the specific ASSEMBLY standard.

Where in this standard a cross-reference is made to another clause, the reference is to be taken to apply to that clause as amended by the specific ASSEMBLY standard, where applicable.

Requirements in this standard that are subject to agreement between the ASSEMBLY manufacturer and the user are summarised in Annex C (informative). This schedule also facilitates the supply of information on basic conditions and additional user specifications to enable proper design, application and utilization of the ASSEMBLY.

For the new re-structured IEC 61439 series, the following parts are envisaged:

- a) IEC 61439-1: General rules
- b) IEC 61439-2: Power switchgear and controlgear ASSEMBLIES (PSC-ASSEMBLIES)
- c) IEC 61439-3: Distribution boards (to supersede IEC 60439-3)
- d) IEC 61439-4: ASSEMBLIES for construction sites (to supersede IEC 60439-4)
- e) IEC 61439-5: ASSEMBLIES for power distribution (to supersede IEC 60439-5)
- f) IEC 61439-6: Busbar trunking systems (to supersede IEC 60439-2)
- g) IEC/TR 61439-0: Guidance to specifying ASSEMBLIES.

This list is not exhaustive; additional Parts may be developed as the need arises.

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR ASSEMBLIES –

Part 1: General rules

1 Scope

NOTE 1 Throughout this standard, the term ASSEMBLY (see 3.1.1) is used for a low-voltage switchgear and controlgear assembly.

This part of the IEC 61439 series lays down the definitions and states the service conditions, construction requirements, technical characteristics and verification requirements for low-voltage switchgear and controlgear assemblies.

This standard cannot be used alone to specify an ASSEMBLY or used for a purpose of determining conformity. ASSEMBLIES shall comply with the relevant part of the IEC 61439 series; Parts 2 onwards.

This standard applies to low-voltage switchgear and controlgear assemblies (ASSEMBLIES) only when required by the relevant ASSEMBLY standard as follows:

- ASSEMBLIES for which the rated voltage does not exceed 1 000 V in case of a.c. or 1 500 V in case of d.c.;
- stationary or movable ASSEMBLIES with or without enclosure;
- ASSEMBLIES intended for use in connection with the generation, transmission, distribution and conversion of electric energy, and for the control of electric energy consuming equipment;
- ASSEMBLIES designed for use under special service conditions, for example in ships and in rail vehicles provided that the other relevant specific requirements are complied with;

NOTE 2 Supplementary requirements for ASSEMBLIES in ships are covered by IEC 60092-302.

- ASSEMBLIES designed for electrical equipment of machines provided that the other relevant specific requirements are complied with.

NOTE 3 Supplementary requirements for ASSEMBLIES forming part of a machine are covered by the IEC 60204 series.

This standard applies to all ASSEMBLIES whether they are designed, manufactured and verified on a one-off basis or fully standardised and manufactured in quantity.

The manufacture and/or assembly may be carried out other than by the original manufacturer (see 3.10.1).

This standard does not apply to individual devices and self-contained components, such as motor starters, fuse switches, electronic equipment, etc. which will comply with the relevant product standards.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-2-2:2007, *Environmental testing – Part 2-2: Tests – Test B: Dry heat*

IEC 60068-2-11:1981, *Basic environmental testing procedures – Part 2-11: Tests – Test Ka: Salt mist*

IEC 60068-2-30:2005, *Environmental testing – Part 2-30: Tests – Test Db: Damp heat, cyclic (12 + 12 h cycle)*

IEC 60073:2002, *Basic and safety principles for man-machine interface, marking and identification – Coding principles for indicators and actuators*

IEC 60085:2007, *Electrical insulation – Thermal evaluation and designation*

IEC 60216 (all parts), *Electrical insulating materials – Properties of thermal endurance*

IEC 60227-3:1993, *Polyvinyl chloride insulated cables of rated voltages up to and including 450/750 V – Part 3: Non-sheathed cables for fixed wiring*

IEC 60245-3:1994, *Rubber insulated cables – Rated voltages up to and including 450/750 V – Part 3: Heat resistant silicone insulated cables*

IEC 60245-4:1994, *Rubber insulated cables – Rated voltages up to and including 450/750 V – Part 4: Cords and flexible cables*

IEC 60364 (all parts), *Low-voltage electrical installations*

IEC 60364-4-41:2005, *Low-voltage electrical installations – Part 4-41: Protection for safety – Protection against electric shock*

IEC 60364-4-44:2007, *Low-voltage electrical installations – Part 4-44: Protection for safety – Protection against voltage disturbances and electromagnetic disturbances*

IEC 60364-5-52:2009, *Low-voltage electrical installations – Part 5-52: Selection and erection of electrical equipment – Wiring systems*

IEC 60364-5-53:2001, *Electrical installations of buildings – Part 5-53: Selection and erection of electrical equipment – Isolation, switching and control*

IEC 60364-5-54:2011, *Low-voltage electrical installations – Part 5-54: Selection and erection of electrical equipment – Earthing arrangements and protective conductors*

IEC 60439 (all parts), *Low-voltage switchgear and controlgear assemblies*

IEC 60445:2010, *Basic and safety principles for man-machine interface, marking and identification – Identification of equipment terminals, conductor terminations and conductors*

IEC 60447:2004, *Basic and safety principles for man-machine interface, marking and identification – Actuating principles*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*¹

IEC 60664-1:2007, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

¹ There is a consolidated edition 1.1 (2001) that includes IEC 60529 (1989) and its amendment 1 (1999).

IEC 60695-2-10:2000, *Fire Hazard testing – Part 2-10: Glowing/hot-wire based test methods – Glow-wire apparatus and common test procedure*

IEC 60695-2-11:2000, *Fire hazard testing – Part 2-11: Glowing/hot-wire based test methods – Glow-wire flammability test method for end-products*

IEC 60695-11-5:2004, *Fire hazard testing – Part 11-5: Test flames – Needle-flame test method – Apparatus, confirmatory test arrangement and guidance*

IEC 60865-1:1993, *Short-circuit currents – Calculation of effects – Part 1: Definitions and calculation methods*

IEC 60890:1987, *A method of temperature-rise assessment by extrapolation for partially type-tested assemblies (PTTA) of low-voltage switchgear and controlgear*

IEC 60947-1:2007, *Low-voltage switchgear and controlgear – Part 1: General rules*

IEC 61000-4-2:2008, *Electromagnetic compatibility (EMC) – Part 4-2: Testing and measurement techniques – Electrostatic discharge immunity test*

IEC 61000-4-3:2006, *Electromagnetic compatibility (EMC) – Part 4-3: Testing and measurement techniques – Radiated, radio frequency, electromagnetic field immunity test²*

IEC 61000-4-4:2004, *Electromagnetic compatibility (EMC) – Part 4-4: Testing and measurement techniques – Electrical fast transient/burst immunity test*

IEC 61000-4-5:2005, *Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test*

IEC 61000-4-6:2008, *Electromagnetic compatibility (EMC) – Part 4-6: Testing and measurement techniques – Immunity to conducted disturbances, induced by radio-frequency fields*

IEC 61000-4-8:2009, *Electromagnetic compatibility (EMC) – Part 4-8: Testing and measurement techniques – Power frequency magnetic field immunity test*

IEC 61000-4-11:2004, *Electromagnetic compatibility (EMC) – Part 4-11: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations immunity tests*

IEC 61000-4-13:2002, *Electromagnetic compatibility (EMC) – Part 4-13: Testing and measurement techniques – Harmonics and interharmonics including mains signalling at a.c. power port, low-frequency immunity tests³*

IEC 61000-6-4:2006, *Electromagnetic compatibility (EMC) – Part 6-4: Generic standards – Emission standard for industrial environments⁴*

IEC 61082-1, *Preparation of documents used in electrotechnology – Part 1: Rules*

IEC 61180 (all parts), *High-voltage test techniques for low-voltage equipment*

² There is a consolidated edition 3.2 (2010) that includes IEC 61000-4-3 (2006) and amendment 1 (2007) and amendment 2 (2010).

³ There is a consolidated edition 1.1 (2009) that includes IEC 61000-4-13 (2002) and its amendment 1 (2009).

⁴ There is a consolidated edition 2.1 (2011) that includes IEC 61000-6-4 (2006) and its amendment 1 (2010).