

**Ehitustoodete ja -elementide tuleohutusalane
klassifikatsioon. Osa 2: Klassifikatsioon
tulepüsivuskatsete alusel, välja arvatud
ventilatsioonisüsteemid KONSOLIDEERITUD TEKST**

Fire classification of construction products and building
elements - Part 2: Classification using data from fire
resistance tests, excluding ventilation services
CONSOLIDATED TEXT

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

Käesolev Eesti standard EVS-EN 13501-2:2007+A1:2009 sisaldab Euroopa standardi EN 13501-2:2007+A1:2009 ingliskeelset teksti.

Standard on kinnitatud Eesti Standardikeskuse 30.10.2009 käskkirjaga ja jõustub sellekohase teate avaldamisel EVS Teatajas.

Euroopa standardimisorganisatsioonide poolt rahvuslikele liikmetele Euroopa standardi teksti kättesaadavaks tegemise kuupäev on 02.09.2009.

Standard on kättesaadav Eesti standardiorganisatsioonist.

This Estonian standard EVS-EN 13501-2:2007+A1:2009 consists of the English text of the European standard EN 13501-2:2007+A1:2009.

This standard is ratified with the order of Estonian Centre for Standardisation dated 30.10.2009 and is endorsed with the notification published in the official bulletin of the Estonian national standardisation organisation.

Date of Availability of the European standard text 02.09.2009.

The standard is available from Estonian standardisation organisation.

ICS 13.220.50

Standardite reprodutseerimis- ja levitamiseõigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonilisse süsteemi või edastamine ükskõik millises vormis või millisel teel on keelatud ilma Eesti Standardikeskuse poolt antud kirjaliku loata.

Kui Teil on küsimusi standardite autorikaitse kohta, palun võtke ühendust Eesti Standardikeskusega:
Aru 10 Tallinn 10317 Eesti; www.evs.ee; Telefon: 605 5050; E-post: info@evs.ee

Right to reproduce and distribute Estonian Standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without permission in writing from Estonian Centre for Standardisation.

If you have any questions about standards copyright, please contact Estonian Centre for Standardisation:
Aru str 10 Tallinn 10317 Estonia; www.evs.ee; Phone: +372 605 5050; E-mail: info@evs.ee

English Version

**Fire classification of construction products and building elements
- Part 2: Classification using data from fire resistance tests,
excluding ventilation services**

Classement au feu des produits et éléments de
construction - Partie 2: Classement à partir des données
d'essais de résistance au feu à l'exclusion des produits
utilisés dans les systèmes de ventilation

Klassifizierung von Bauprodukten und Bauarten zu ihrem
Brandverhalten - Teil 2: Klassifizierung mit den
Ergebnissen aus den Feuerwiderstandsprüfungen, mit
Ausnahme von Lüftungsanlagen

This European Standard was approved by CEN on 30 November 2006 and includes Amendment 1 approved by CEN on 17 July 2009.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

Foreword	4
Introduction	5
1 Scope	6
2 Normative references	7
3 Terms and definitions	9
4 Fire scenarios	13
4.1 General	13
4.2 The standard temperature/time curve (post flash-over fire)	13
4.3 The slow heating curve (smouldering fire)	14
4.4 The 'semi-natural' fire	14
4.5 The external fire exposure curve	14
4.6 Constant temperature attack	15
5 Resistance to fire performance characteristics	15
5.1 General	15
5.2 Performance characteristics	15
5.2.1 R - Loadbearing capacity	15
5.2.2 E - Integrity	16
5.2.3 I - Thermal insulation	16
5.2.4 W - Radiation	18
5.2.5 M - Mechanical action	18
5.2.6 C - Self-closing	19
5.2.7 S - Smoke leakage	19
5.2.8 G - 'Soot fire' resistance	19
5.2.9 K - Fire protection ability	19
6 Declaration of fire resistance performance	20
6.1 Classification periods	20
6.2 Designatory letters	20
6.3 Declaration of performance	20
6.4 Combinations of classes	21
6.5 Particular classifications	21
6.5.1 Fire doors and shutters	21
6.5.2 Conveyor systems and their closures	22
6.6 Additional performance parameters	22
6.6.1 Optional performance parameters	22
6.6.2 Expansion of performance parameters	22
6.6.3 Particular performance parameters	23
6.7 Presentation of classification	23
6.8 Declaration of fire resistance classes in product specifications	23
7 Classification procedure for fire resistance	23
7.1 General	23
7.1.1 Procedure	23
7.1.2 General rules for deducing the number of standard temperature/time fire resistance tests	25
7.1.3 \square_{A1} Field of application \square_{A1}	26
7.2 Classification of loadbearing elements without a fire separating function	27
7.2.1 General	27
7.2.2 Classification of loadbearing walls without separating function	27
7.2.3 Classification of loadbearing floors and roofs without fire separating function	28

7.2.4	Classification of beams	29
7.2.5	Classification of columns	30
7.2.6	Classification of balconies, walkways and stairs	31
7.3	Classification of loadbearing elements with fire separating function	32
7.3.1	General	32
7.3.2	Classification of loadbearing walls with fire separating function	32
7.3.3	Classification of loadbearing floors and roofs with fire separating function	34
7.3.4	Classification of raised floors	35
7.4	Products and systems for protecting elements or parts of works	36
7.4.1	General	36
7.4.2	Tests to be carried out	37
7.4.3	Test methods	38
7.4.4	Performance criteria	38
7.4.5	Classes	38
7.4.6	Classification of protected structural members	38
7.5	Classification of non-loadbearing elements	41
7.5.1	General	41
7.5.2	Partitions	42
7.5.3	Classification of curtain walling	43
7.5.4	Classification of ceilings with independent fire resistance	45
7.5.5	Classification of fire doors and shutters including their closing devices	47
7.5.6	Classification of smoke control doors	48
7.5.7	Classification of closure and conveyor system assemblies	50
7.5.8	Classification of penetration seals	51
7.5.9	Classification of linear joint seals	53
7.5.10	Classification of service ducts and shafts	55
7.5.11	Classification of chimneys	57
7.6	Classification of wall and ceiling coverings for fire protection ability	57
7.6.1	General	57
7.6.2	Test method	58
7.6.3	Tests to be carried out	58
7.6.4	Performance criteria for fire protection ability	58
7.6.5	Classes	59
Annex A	(normative) Classification report	60
A.1	General	60
A.2	Content and format	60
A.3	Classification report format	62
Annex B	(informative) Presentation of characterisation data and their field of application for products and systems for protecting elements or parts of work	66
B.1	General	66
B.2	Characterisation data for protective vertical membranes	66
B.3	Characterisation data for applied protection to concrete members	67
B.4	Characterisation data for applied protection to steelwork	68
B.5	Characterisation data for applied protection to concrete/profiled sheet steel composite members	70
B.6	Characterisation data for applied protection to concrete filled hollow steel columns	71
B.7	Characterisation data for applied protection to timber members	72
	Bibliography	80

Foreword

This document (EN 13501-2:2007+A1:2009) has been prepared by Technical Committee CEN/TC 127 "Fire safety in buildings", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by March 2010, and conflicting national standards shall be withdrawn at the latest by March 2010.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document includes Amendment 1, approved by CEN on 2009-07-17.

This document supersedes A1 EN 13501-2:2007 A1.

The start and finish of text introduced or altered by amendment is indicated in the text by tags A1 A1.

The first edition of this European Standard was prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, supporting essential requirements of the Construction Products Directive.

A1 Amendment 1 provides for the use of extended application reports in the classification procedure. A1

CEN, CENELEC and EOTA committees preparing technical specifications which contain performance requirements against resistance to fire tests should make reference to the resistance to fire classification given in this European Standard and not refer directly to any specific fire test method.

Changes have been made in this revision to bring it in line with the relevant current EC Decisions on fire resistance classification, and experience in use in the first edition.

EN 13501 *Fire classification of construction products and building elements* consists of the following Parts:

Part 1: Classification using data from reaction to fire tests

Part 2: Classification using data from fire resistance tests, excluding ventilation services

Part 3: Classification using data from fire resistance tests on products and elements used in building service installations: fire resisting ducts and fire dampers

Part 4: Classification using data from fire resistance tests on components of smoke control systems

Part 5: Classification using data from external fire exposure to roof tests

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

Introduction

The aim of this European Standard is to define a harmonised procedure for the classification for resistance to fire of construction products and building elements. This classification is based on the test procedures listed in ^{A1} Clause 2 and the relevant field of application procedures ^{A1}.

This European Standard is prepared in support of the second essential requirement in the EC Construction Products Directive (89/106/EEC) which is detailed in the Interpretative Document number 2 (ID2): Safety in case of fire (OJ C62 Vol 37). It reflects the Commission Decision of 3 May 2000 on the implementation of the Council Directive 89/106/EEC as regards the classification of the resistance to fire performance of construction products, construction works and parts thereof.

The Interpretative Document and the Commission Decision of 2 May 2000 specify performance and classes regarding fire resistance. These classes are identified by designation letters, each of which refers to an important characteristic of fire resistance behaviour.

This European Standard provides for a common understanding for these requirements. It interprets the functional requirements for the different groups of building elements and explains the method for deriving their classification on the basis of ^{A1} test results and/or extended application results for individual elements ^{A1}.

^{A1} NOTE Test reports constitute the basis for extended application reports as explained in prEN 15725. ^{A1}

1 Scope

This European Standard specifies the procedure for classification of construction products and building elements using data from fire resistance and smoke leakage tests which are within the direct field of application of the relevant test method. **A1** Classification on the basis of extended application of test results is also included in the scope of this European Standard. **A1**

This European Standard deals with:

a) loadbearing elements without a fire separating function:

walls;
floors;
roofs;
beams;
columns;
balconies;
walkways;
stairs.

b) loadbearing elements with a fire separating function, with or without glazing, services and fixtures:

walls;
floors;
roofs;
raised floors.

c) products and systems for protecting elements or parts of the works

ceilings with no independent fire resistance;
fire protective coatings, claddings and screens;

d) non-loadbearing elements or parts of works, with or without glazing, services and fixtures:

partitions;
facades (curtain walls) and external walls;
ceilings with independent fire resistance;
fire doors and shutters and their closing devices;
smoke control doors;
conveyor systems and their closures;
penetration seals;
linear joint seals;
service ducts and shafts;
chimneys.

e) wall and ceiling coverings with fire protection ability.

f) lift landing doors which are tested according to EN 81-58 are excluded from this European Standard. Lift landing doors which are tested according to EN 1634-1 are classified in accordance with 7.5.5.

Relevant test methods which have been prepared for these elements are listed in Clauses 2 and 7.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1363-2, *Fire resistance tests — Part 2: Alternative and additional procedures*

EN 1364-1, *Fire resistance tests for non-loadbearing elements — Part 1: Walls*

EN 1364-2, *Fire resistance tests for non-loadbearing elements — Part 2: Ceilings*

EN 1364-3, *Fire resistance tests for non-loadbearing elements — Part 3: Curtain walling - Full configuration (complete assembly)*

EN 1364-4, *Fire resistance tests for non-loadbearing elements — Part 4: Curtain walling — Part configuration*

EN 1365-1, *Fire resistance tests for loadbearing elements — Part 1: Walls*

EN 1365-2, *Fire resistance tests for loadbearing elements — Part 2: Floors and roofs*

EN 1365-3, *Fire resistance tests for loadbearing elements — Part 3: Beams*

EN 1365-4, *Fire resistance tests for loadbearing elements — Part 4: Columns*

EN 1365-5, *Fire resistance tests for loadbearing elements — Part 5: Balconies and walkways*

EN 1365-6, *Fire resistance tests for loadbearing elements — Part 6: Stairs*

EN 1366-3, *Fire resistance tests for service installations — Part 3: Penetration seals*

EN 1366-4, *Fire resistance tests for service installations — Part 4: Linear joint seals*

EN 1366-5, *Fire resistance tests for service installations — Part 5: Service ducts and shafts*

EN 1366-6, *Fire resistance tests for service installations — Part 6: Raised access and hollow core floors*

EN 1366-7, *Fire resistance tests for service installations — Part 7: Conveyor systems and their closures*

EN 1634-1, *Fire resistance tests for door and shutter assemblies — Part 1: Fire doors and shutters*

EN 1634-3, *Fire resistance tests for door and shutter assemblies — Part 3: Smoke control doors and shutters*

EN 13216-1, *Chimneys — Test methods for system chimneys — Part 1: General test methods*

CEN/TS 13381-1, *Test methods for determining the contribution to the fire resistance of structural members — Part 1: Horizontal protective membranes*

ENV 13381-2, *Test methods for determining the contribution to the fire resistance of structural members — Part 2: Vertical protective membranes*

ENV 13381-3, *Test methods for determining the contribution to the fire resistance of structural members — Part 3: Applied protection to concrete members*

ENV 13381-4, *Test methods for determining the contribution to the fire resistance of structural members — Part 4: Applied protection to steel members*

ENV 13381-5, *Test methods for determining the contribution to the fire resistance of structural members — Part 5: Applied protection to concrete/profiled sheet steel composite members*

ENV 13381-6, *Test methods for determining the contribution to the fire resistance of structural members — Part 6: Applied protection to concrete filled hollow steel columns*

ENV 13381-7, *Test methods for determining the contribution to the fire resistance of structural members — Part 7: Applied protection to timber members*

EN 14135, *Coverings — Determination of fire protection ability*

EN 14600, *Doorsets and openable windows with fire resisting and/or smoke control characteristics — Requirements and classification*

EN 15080-8, *Extended application of results from fire resistance tests — Part 8: Beams*

EN 15254-2, *Extended application of results from fire resistance tests — Non-loadbearing walls — Part 2: Masonry and gypsum blocks*

prEN 15254-5, *Extended application of results from fire resistance tests — Non-loadbearing walls — Part 5: Metal sandwich panel construction*

prEN 15254-6¹⁾, *Extended application of results from fire resistance tests — Non-loadbearing walls — Part 6: Curtain walling*

prEN 15254-7, *Extended application of results from fire resistance tests — Non-loadbearing walls — Part 7: Non-loadbearing sandwich panels — Ceilings*

prEN 15269-1, *Extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies, including their elements of building hardware — Part 1: General requirements*



prEN 15269-2, *Extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies, including their elements of building hardware — Part 2: Fire resistance of hinged and pivoted steel doorsets*

prEN 15269-3, *Extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies, including their elements of building hardware — Part 3: Fire resistance of hinged and pivoted timber doorsets and openable timber framed windows*

prEN 15269-4¹⁾, *Extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies, including their elements of building hardware — Part 4: Fire resistance of hinged and pivoted glass doorsets*

prEN 15269-5¹⁾, *Extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies, including their elements of building hardware — Part 5: Fire resistance of hinged and pivoted, metal framed, glazed doorsets and openable windows*

prEN 15269-6¹⁾, *Extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies, including their elements of building hardware — Part 6: Fire resistance of sliding timber doorsets*

¹⁾  To be published. 

prEN 15269-7, *Extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies, including their elements of building hardware — Part 7: Fire resistance of sliding steel doorsets*

prEN 15269-8¹⁾, *Extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies, including their elements of building hardware — Part 8: Fire resistance of horizontally folding timber doorsets*

prEN 15269-9¹⁾, *Extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies, including their elements of building hardware — Part 9: Fire resistance of horizontally folding steel doorsets*

prEN 15269-10¹⁾, *Extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies, including their elements of building hardware — Part 10: Fire resistance of steel rolling shutters*

prEN 15269-11¹⁾, *Extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies, including their elements of building hardware — Part 11: Fire resistance of fabric curtains*


prEN 15269-20, *Extended application of test results for fire resistance and/or smoke control for door, shutter and openable window assemblies, including their elements of building hardware — Part 20: Smoke control for hinged and pivoted steel, timber and metal framed glazed doorsets*

prEN 15725, *Extended application reports on the fire performance of construction products and building elements*

prEN 15882-1, *Extended application of results from fire resistance tests for service installations — Part 1: Fire resisting ducts*

prEN 15882-2, *Extended application of results from fire resistance tests for service installations — Part 2: Dampers*

EN 15882-3, *Extended application of results from fire resistance tests for service installations — Part 3: Penetration seals*

prEN 15882-4¹⁾, *Extended application of results from fire resistance tests for service installations — Part 4: Linear joint seals* 

EN ISO 13943:2000, *Fire safety — Vocabulary (ISO 13943:2000)*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN ISO 13943:2000 and the following apply.

3.1

element of building construction

defined part of a construction component, e.g. wall, partition, floor, roof, beam or column (EN 1363-1:1999). An element, for the purpose of this European Standard, covers both individual products and elements made up of one or more products

3.2

ceiling

non-loadbearing element of a building construction designed to provide horizontal fire separation

(EN 1364-2:1999)