

**Madalpingelised elektripaigaldised. Osa 1:
Põhialused, üldiseloomustus, määratlused**

Low-voltage electrical installations -- Part 1:
Fundamental principles, assessment of general
characteristics, definitions

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

Käesolev Eesti standard EVS-HD 60364-1:2008 sisaldab Euroopa standardi HD 60364-1:2008 ingliskeelset teksti.

Standard on kinnitatud Eesti Standardikeskuse 20.10.2008 käskkirjaga ja jõustub sellekohase teate avaldamisel EVS Teatajas.

Euroopa standardimisorganisatsioonide poolt rahvuslikele liikmetele Euroopa standardi teksti kättesaadavaks tegemise kuupäev on 14.08.2008.

Standard on kättesaadav Eesti standardiorganisatsioonist.

This Estonian standard EVS-HD 60364-1:2008 consists of the English text of the European standard HD 60364-1:2008.

This standard is ratified with the order of Estonian Centre for Standardisation dated 20.10.2008 and is endorsed with the notification published in the official bulletin of the Estonian national standardisation organisation.

Date of Availability of the European standard text 14.08.2008.

The standard is available from Estonian standardisation organisation.

ICS 91.140.50

Võtmesõnad: ehitis, elektripaigaldis, määratlus

Standardite reprodutseerimis- ja levitamiseõigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonilisse süsteemi või edastamine ükskõik millises vormis või millisel teel on keelatud ilma Eesti Standardikeskuse poolt antud kirjaliku loata.

Kui Teil on küsimusi standardite autorikaitse kohta, palun võtke ühendust Eesti Standardikeskusega:
Aru 10 Tallinn 10317 Eesti; www.evs.ee; Telefon: 605 5050; E-post: info@evs.ee

English version

**Low-voltage electrical installations -
Part 1: Fundamental principles,
assessment of general characteristics, definitions
(IEC 60364-1:2005, modified)**

Installations électriques à basse tension -
Partie 1: Principes fondamentaux,
détermination des caractéristiques
générales, définitions
(CEI 60364-1:2005, modifiée)

Errichten von Niederspannungsanlagen -
Teil 1: Allgemeine Grundsätze,
Bestimmungen allgemeiner Merkmale,
Begriffe
(IEC 60364-1:2005, modifiziert)

This Harmonization Document was approved by CENELEC on 2008-05-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for implementation of this Harmonization Document at national level.

Up-to-date lists and bibliographical references concerning such national implementations may be obtained on application to the Central Secretariat or to any CENELEC member.

This Harmonization Document exists in three official versions (English, French, German).

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

The text of the International Standard IEC 60364-1:2005, prepared by IEC TC 64, Electrical installations and protection against electric shock, together with the common modifications prepared by the Technical Committee CENELEC TC 64, Electrical installations and protection against electric shock, was submitted to the formal vote and was approved by CENELEC as HD 60364-1 on 2008-05-01.

This Harmonization Document supersedes HD 384.1 S2:2001 + HD 384.3 S2:1995.

The following dates were fixed:

- latest date by which the existence of the HD
has to be announced at national level (doa) 2008-11-01
- latest date by which the HD has to be implemented
at national level by publication of a harmonized
national standard or by endorsement (dop) 2009-05-01
- latest date by which the national standards conflicting
with the HD have to be withdrawn (dow) 2011-05-01

In this Harmonization Document the common modifications to the International Standard are indicated by a vertical line in the left margin of the text.

Annex ZA has been added by CENELEC.

Contents

11	Scope	5
12	Normative references	7
13	Fundamental principles	8
131	Protection for safety	8
131.1	General	8
131.2	Protection against electric shock	8
131.3	Protection against thermal effects	9
131.4	Protection against overcurrent	9
131.5	Protection against fault currents	9
131.6	Protection against voltage disturbances and measures against electromagnetic influences	9
131.7	Protection against power supply interruption	9
132	Design	10
132.1	General	10
132.2	Characteristics of available supply or supplies	10
132.3	Nature of demand	11
132.4	Electric supply systems for safety services or standby electric supply systems	11
132.5	Environmental conditions	11
132.6	Cross-sectional area of conductors	11
132.7	Type of wiring and methods of installation	11
132.8	Protective equipment	12
132.9	Emergency control	12
132.10	Disconnecting devices	12
132.11	Prevention of mutual detrimental influence	12
132.12	Accessibility of electrical equipment	12
132.13	Documentation for the electrical installation	12
133	Selection of electrical equipment	12
133.1	General	12
133.2	Characteristics	13
133.3	Conditions of installation	13
133.4	Prevention of harmful effects	13
134	Erection and verification of electrical installations	14
134.1	Erection	14
134.2	Initial verification	14
134.3	Periodic verification	14
20	Terms and definitions	14
30	Assessment of general characteristics	15
31	Purposes, supplies and structure	15
311	Maximum demand and diversity	15
312	Conductor arrangement and system earthing	15
312.1	Current-carrying conductors depending on kind of current	15
312.2	Types of system earthing	17

313	Supplies	30
313.1	General	30
313.2	Supplies for safety services and standby systems	30
314	Division of installation	30
32	Classification of external influences	31
33	Compatibility	31
33.1	Compatibility of characteristics	31
33.2	Electromagnetic compatibility	31
34	Maintainability	31
35	Safety services	32
35.1	General	32
35.2	Classification	32
36	Continuity of service	32
	Annex A (informative) Examples of system earthing	33
A.1	TN Systems (AC)	33
A.2	TT-Systems (AC)	37
A.3	IT-Systems (AC)	38
A.4	TN-Systems (DC)	41
A.5	TT-Systems (DC)	43
A.6	IT-Systems (DC)	44
	Annex B (informative) Definitions – Application guide and explanations to selected terms of IEC 60050–826 (IEV 826 – Electrical installations)	45
	Annex ZA (informative) A-deviations	48
	Bibliography	49

11 Scope ¹⁾

HD 60364-1 gives the rules for the design, erection, and verification of low-voltage electrical installations. The rules are intended to provide for the safety of persons, livestock and property against dangers and damage which may arise in the reasonable use of electrical installations and to provide for the proper functioning of those installations.

11.1 HD 60364-1 applies to the design, erection and verification of electrical installations such as those of

- a) residential premises;
- b) commercial premises;
- c) public premises;
- d) industrial premises;
- e) agricultural and horticultural premises;
- f) prefabricated buildings;
- g) caravans, caravan sites and similar sites;
- h) construction sites, exhibitions, fairs and other installations for temporary purposes;
- i) marinas;
- j) external lighting and similar installations (see, however, 11.3 e));
- k) medical locations;
- l) mobile or transportable units;
- m) photovoltaic systems;
- n) low-voltage generating sets.

NOTE "Premises" covers the land and all facilities including buildings belonging to it.

11.2 HD 60364-1 covers

- a) circuits supplied at nominal voltages up to and including 1 000 V a.c. or 1 500 V d.c.;
For a.c., the preferred frequencies which are taken into account in this standard are 50 Hz, 60 Hz and 400 Hz. The use of other frequencies for special purposes is not excluded.
- b) circuits, other than the internal wiring of apparatus, operating at voltages exceeding 1 000 V and derived from an installation having a voltage not exceeding 1 000 V a.c., for example, discharge lighting, electrostatic precipitators;
- c) wiring systems and cables not specifically covered by the standards for appliances;
- d) all consumer installations external to buildings;
- e) fixed wiring for information and communication technology, signalling, control and the like (excluding internal wiring of apparatus);
- f) the extension or alteration of the installation and also parts of the existing installation affected by the extension or alteration.

NOTE The rules of HD 60364-1 are intended to apply to electrical installations generally but, in certain cases, they may need to be supplemented by the requirements or recommendations of other CENELEC standards (for example, for installations in explosive gas atmospheres).

¹⁾ The numbering system is explained in Annex A of IEC 60364-1:2005.

11.3 HD 60364-1 does not apply to

- a) electric traction equipment, including rolling stock and signaling equipment;
 - b) electrical equipment of motor vehicles, except those covered in Part 7;
 - c) electrical installations on board ships and mobile and fixed offshore platforms;
 - d) electrical installations in aircraft;
 - e) public street-lighting installations which are part of the public power grid;
 - f) installations in mines and quarries;
 - g) radio interference suppression equipment, except where it affects the safety of the installation;
 - h) electric fences;
 - i) external lightning protection systems for buildings (LPS);
- NOTE Atmospheric phenomena are covered in HD 60364-1 but only insofar as effects on the electrical installations are concerned (for example, with respect to selection of surge protective devices).
- j) certain aspects of lift installations;
 - k) electrical equipment of machines.

11.4 HD 60364-1 is not intended to apply to

- systems for distribution of energy to the public, or
- power generation and transmission for such systems.

NOTE 1 Countries wishing to do so may, however, use this document in whole or in part for that purpose.

NOTE 2 According to HD 637 which provides common rules for the design and the erection of electrical power installations in systems with nominal voltages above 1 kV a.c. and nominal frequency up to and including 60 Hz, low-voltage a.c. and d.c. protection and monitoring systems should be in accordance with HD 60364 series.

11.5 Electrical equipment is dealt with only so far as its selection and application in the installation are concerned.

This applies also to assemblies of electrical equipment complying with the relevant standards.

12 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

<u>EN/HD</u>	<u>Year</u>	<u>Title</u>	<u>IEC</u>	<u>Year</u>
HD 472 S1	1989	Nominal voltages for low voltage public electricity supply systems ²⁾	IEC 60038 (mod)	1983
-	-	International Electrotechnical Vocabulary (IEV) Chapter 691: Tariffs for electricity	IEC 60050-691	
-	-	International Electrotechnical Vocabulary (IEV) Part 826: Electrical installations	IEC 60050-826	
HD 384 / HD 60364	Series	Electrical installations of buildings	IEC 60364 (mod)	Series
EN 60445		Basic and safety principles for man-machine interface, marking and identification - Identification of equipment terminals and conductor terminations	IEC 60445 (mod)	
EN 60446		Basic and safety principles for man-machine interface, marking and identification - Identification of conductors by colours or numerals	IEC 60446	
-	-	Graphical symbols for diagrams	IEC 60617	Database
EN 60721	Series	Classification of environmental conditions	IEC 60721	Series

²⁾ The title of IEC 60038 is: "IEC standard voltages".