

**Mõõtereled ja kaitseseadised. Osa 27: Toote
ohutusnõuded**

**Measuring relays and protection equipment -- Part 27:
Product safety requirements**

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 60255-27:2014 sisaldab Euroopa standardi EN 60255-27:2014 inglisekeelset teksti.	This Estonian standard EVS-EN 60255-27:2014 consists of the English text of the European standard EN 60255-27:2014.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 28.03.2014.	Date of Availability of the European standard is 28.03.2014.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 29.120.70

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Aru 10, 10317 Tallinn, Eesti; www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:
Aru 10, 10317 Tallinn, Estonia; www.evs.ee; phone 605 5050; e-mail info@evs.ee

**Measuring relays and protection equipment -
Part 27: Product safety requirements
(IEC 60255-27:2013)**

Relais de mesure et dispositifs de
protection -
Partie 27: Exigences de sécurité
(CEI 60255-27:2013)

Messrelais und Schutzeinrichtungen -
Teil 27: Anforderungen an die
Produktsicherheit
(IEC 60255-27:2013)

This European Standard was approved by CENELEC on 2013-11-19. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 95/316/FDIS, future edition 2 of IEC 60255-27, prepared by IEC/TC 95 "Measuring relays and protection equipment" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 60255-27:2014.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2014-09-28
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2016-11-19

This document supersedes EN 60255-5:2001 and EN 60255-27:2005.

EN 60255-27:2014 includes the following significant technical changes with respect to EN 60255-27:2005:

- a) The removal of tables and diagrams which are from other standards and referring instead directly to the source standard.
- b) All aspects of EN 60255-5 have been covered and this standard can be withdrawn.
- c) Ambiguity within the standard has been removed.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This standard covers the Principle Elements of the Safety Objectives for Electrical Equipment Designed for Use within Certain Voltage Limits (LVD - 2006/95/EC).

Endorsement notice

The text of the International Standard IEC 60255-27:2013 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60068-3-4:2001	NOTE Harmonized in EN 60068-3-4:2001 (not modified)
IEC 60112:2003	NOTE Harmonized in EN 60112:2003 (not modified)
IEC 60127-1	NOTE Harmonized in EN 60127-1
IEC 60255-5:2000	NOTE Harmonized in EN 60255-5:2000 (not modified)
IEC 60384-14:2013	NOTE Harmonized in EN 60384-14:2013 (not modified)
IEC 60695-2-12	NOTE Harmonized in EN 60695-2-12
IEC 60695-2-13:2010	NOTE Harmonized in EN 60695-2-13:2010 (not modified)
IEC 61558 (series)	NOTE Harmonized in EN 61558 (series)
IEC 61810-1:2008	NOTE Harmonized in EN 61810-1:2008 (not modified)

Annex ZA
(normative)
**Normative references to international publications
with their corresponding European publications**

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60050 (series)		International Electrotechnical Vocabulary - Part 103: Mathematics - Functions	-	
IEC 60085		Electrical insulation - Thermal evaluation and designation	EN 60085	
IEC 60255-1		Measuring relays and protection equipment - Part 1: Common requirements	EN 60255-1	
IEC 60255-21-1		Electrical relays - Part 21: Vibration, shock, bump and seismic tests on measuring relays and protection equipment - Section 1: Vibration tests (sinusoidal)	EN 60255-21-1	
IEC 60255-21-2		Electrical relays - Part 21: Vibration, shock, bump and seismic tests on measuring relays and protection equipment - Section 2: Shock and bump tests	EN 60255-21-2	
IEC 60255-21-3		Electrical relays - Part 21: Vibration, shock, bump and seismic tests on measuring relays and protection equipment - Section 3: Seismic tests	EN 60255-21-3	
IEC 60255-26	2013	Measuring relays and protection equipment - Part 26: Electromagnetic compatibility requirements	EN 60255-26 + AC:2013	2013
IEC 60352-1		Solderless connections - Part 1: Wrapped connections - General requirements, test methods and practical guidance	EN 60352-1	
IEC 60352-2		Solderless connections - Part 2: Crimped connections - General requirements, test methods and practical guidance	EN 60352-2	
IEC 60417	Data-base	Graphical symbols for use on equipment		
IEC 60529 +A1	1989 1999	Degrees of protection provided by enclosures (IP Code)	EN 60529 + corr. May +A1	1991 1993 2000
IEC 60664-1	2007	Insulation coordination for equipment within low-voltage systems - Part 1: Principles, requirements and tests	EN 60664-1	2007
IEC 60664-3	2003	Insulation coordination for equipment within low-voltage systems - Part 3: Use of coating, potting or moulding for protection against pollution	EN 60664-3	2003

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC/TS 60695-2-20		Fire hazard testing - Part 2-20: Glowing/hot wire based test methods - Hot-wire coil ignitability - Apparatus, test method and guidance	-	-
IEC 60695-11-10		Fire hazard testing - Part 11-10: Test flames - 50 W horizontal and vertical flame test methods	EN 60695-11-10	
IEC 60825-1		Safety of laser products - Part 1: Equipment classification and requirements	EN 60825-1	
IEC 60990	1999	Methods of measurement of touch current and protective conductor current	EN 60990	1999
IEC 61010-1	2010	Safety requirements for electrical equipment for measurement, control and laboratory use - Part 1: General requirements	EN 61010-1	2010
IEC 61032		Protection of persons and equipment by enclosures - Probes for verification	EN 61032	
IEC 61140		Protection against electric shock - Common aspects for installation and equipment	EN 61140	
IEC 61180-1	1992	High-voltage test techniques for low-voltage equipment - Part 1: Definitions, test and procedure requirements	EN 61180-1	1994
IEC 61180-2		High-voltage test techniques for low-voltage equipment - Part 2: Test equipment	EN 61180-2	
IEC 62151		Safety of equipment electrically connected to a telecommunication network	-	-
ISO 7000		Graphical symbols for use on equipment - Registered symbols	-	-

CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
2 Normative references	10
3 Terms and definitions	11
4 General safety requirements.....	19
4.1 General.....	19
4.2 Earthing requirements	20
5 Protection against electric shock	20
5.1 General.....	20
5.1.1 Introductory remark	20
5.1.2 Protection from contact with hazardous live parts	20
5.1.3 Discharge of capacitors	21
5.1.4 Protective impedance	22
5.1.5 Accessible parts	22
5.1.6 Bonding to the protective conductor.....	25
5.1.7 Protective conductor connection	26
5.1.8 High leakage current	26
5.1.9 Solid insulation.....	26
5.1.10 Clearances and creepage distances	27
5.1.11 Functional earthing.....	29
5.2 Single-fault conditions	29
5.2.1 Testing in single-fault condition	29
5.2.2 Application of single-fault condition	30
5.2.3 Duration of tests	31
5.2.4 Compliance	32
6 Mechanical aspects	33
6.1 Protection against mechanical hazards.....	33
6.1.1 Stability	33
6.1.2 Moving parts.....	33
6.1.3 Edges and corners	33
6.2 Mechanical requirements.....	33
6.3 Mechanical security of terminations.....	33
7 Flammability and resistance to fire	33
7.1 General.....	33
7.2 Rationale.....	34
7.3 General hazards from overheating and fire	36
7.3.1 Equipment temperature limits	36
7.3.2 Hazardous gases and chemicals.....	36
7.4 Minimization of fire risk.....	37
7.4.1 General	37
7.4.2 Eliminating or reducing the sources of ignition within the equipment.....	37
7.5 Cabling and fusing.....	37
7.6 Flammability of materials and components	38
7.6.1 General	38
7.6.2 Materials for components and other parts inside fire enclosures	38

7.6.3	Materials for fire enclosures	39
7.6.4	Materials for components and other parts outside fire enclosures	39
7.7	Fire ignition sources	40
7.8	Conditions for a fire enclosure	40
7.8.1	General	40
7.8.2	Parts requiring a fire enclosure	40
7.8.3	Parts not requiring a fire enclosure	40
7.9	Requirements for primary circuits and circuits exceeding ELV limits	41
7.10	Fire enclosures and flame barriers	41
7.11	Assessment of the fire risk due to a single-fault condition	43
7.11.1	Guidelines for maximum acceptable temperatures when subjecting a circuit or component to a single-fault condition	43
7.11.2	Temperature of windings under a normal condition or a single-fault condition	43
7.11.3	Compliance of equipment with requirements for protection against the spread of fire	43
7.12	Limited-energy circuit	44
8	General and fundamental design requirements for safety	45
8.1	Climatic conditions for safety	45
8.2	Electrical connections	45
8.3	Components	45
8.3.1	General	45
8.3.2	High-integrity part or component	45
8.4	Connection to telecommunication networks	46
8.5	Connection to other equipment	46
8.6	Laser sources	46
8.7	Explosion	46
8.7.1	General	46
8.7.2	Components at risk of explosion	46
9	Marking, documentation and packaging	47
9.1	Marking	47
9.1.1	General	47
9.1.2	Identification	48
9.1.3	Auxiliary supplies, VT, CT, I/O (Input/Output)	48
9.1.4	Fuses	49
9.1.5	Measuring circuit terminals	50
9.1.6	Terminals and operating devices	50
9.1.7	Equipment protected by double or reinforced insulation	51
9.1.8	Batteries	51
9.1.9	Test voltage marking	53
9.1.10	Warning markings	53
9.1.11	Marking durability	54
9.2	Documentation	54
9.2.1	General	54
9.2.2	Equipment ratings	54
9.2.3	Equipment installation	55
9.2.4	Equipment commissioning and maintenance	55
9.2.5	Equipment operation	56
9.3	Packaging	56

10	Type tests and routine tests.....	56
10.1	General	56
10.2	Safety type tests	58
10.3	Routine testing or sample testing	58
10.4	Conditions for testing	58
10.5	Verification procedure	58
10.6	Tests	59
10.6.1	Climatic environmental tests	59
10.6.2	Mechanical tests.....	59
10.6.3	Clearances and creepage distances	60
10.6.4	Safety-related electrical tests	60
10.6.5	Electrical environment and flammability	66
10.6.6	Reverse polarity and slow ramp test	67
Annex A	(normative) Isolation class requirements and example diagrams	69
Annex B	(normative) Rated impulse voltages	77
Annex C	(normative) Guidance for the determination of clearance, creepage distance and withstand voltages	78
Annex D	(informative) Components.....	88
Annex E	(normative) External wiring terminations	92
Annex F	(informative) Examples of battery protection	94
Bibliography	95
Figure 1	– Flow chart showing requirements for protection against the spread of fire	35
Figure 2	– Baffle	42
Figure 3	– Location and extent of a flame barrier	42
Figure 4	– Voltage ramp test.....	68
Figure A.1	– Equipment with SELV input/output (I/O)	73
Figure A.2	– Equipment with PELV input/output (I/O)	74
Figure A.3	– Equipment with PEB input/output (I/O)	75
Figure A.4	– Equipment with ELV input/output (I/O)	76
Figure C.1	– Guidance for determination of clearances, creepage distances and withstand voltages	81
Figure F.1	– Non-rechargeable battery protection	94
Figure F.2	– Rechargeable battery protection	94
Table 1	– Current levels under normal conditions.....	24
Table 2	– Charge or energy of capacitance levels under normal conditions.....	24
Table 3	– Altitude multiplication factor	28
Table 4	– Current levels in single-fault condition	32
Table 5	– Maximum temperature under normal conditions and at an ambient temperature of 40 °C	36
Table 6	– Acceptable perforation in the bottom of an equipment case	42
Table 7	– Insulation material of windings	43
Table 8	– Limits of maximum available current.....	44
Table 9	– Overcurrent protective device.....	44

Table 10 – Symbols	52
Table 11 – Symbols for marking of test voltage(s)	53
Table 12 – Overview of tests	57
Table 13 – Guidance for routine and sample dielectric voltage testing for safety – Informative	63
Table 14 – AC test voltages	64
Table A.1 – Circuit isolation class for product circuits/groups	69
Table A.2 – Insulation requirement between any two circuits	71
Table B.1 – Rated impulse voltages (waveform: 1,2/50 μ s)	77
Table C.1 – Functional insulation, pollution degree 1, overvoltage category I	82
Table C.2 – Functional insulation, pollution degree 2, overvoltage category I	83
Table C.3 – Functional, basic or supplementary insulation, pollution degree 1, overvoltage category II	83
Table C.4 – Functional, basic or supplementary insulation, pollution degree 2, overvoltage category II	84
Table C.5 – Functional, basic or supplementary insulation, pollution degree 1, overvoltage category III	84
Table C.6 – Functional, basic or supplementary insulation, pollution degree 2, overvoltage category III	85
Table C.7 – Double or reinforced insulation, pollution degree 1, overvoltage category II	85
Table C.8 – Double or reinforced insulation, pollution degree 2, overvoltage category II	86
Table C.9 – Double or reinforced insulation, pollution degree 1, overvoltage category III	86
Table C.10 – Double or reinforced insulation, pollution degree 2, overvoltage category III	87
Table C.11 – Test voltage multiplication factor for proving the clearance in air	87
Table C.12 – Reduction of the pollution degree of internal environment through the use of additional protection within the equipment	87
Table E.1 – Range of conductor sizes to be accepted by terminals	93
Table E.2 – Sizes of terminal studs or screws directly securing supply conductors	93

INTRODUCTION

In order to demonstrate that the equipment is safe, it was previously necessary to refer to general safety standards such as IEC 61010-1 in addition to IEC 60664-1.

These general safety standards specify requirements for general product types or product families in order to reduce the risk of fire, electric shock or injury to the user. The product types do not include measuring relays and protection equipment. These standards also take into account single-fault conditions.

Reference to all these various standards created confusion due to conflicting requirements, for example, different clearances, creepage distances and test voltages etc., for the same rated voltages.

The aim of this standard is:

- to remove confusion due to conflicting requirements between existing standards;
- to achieve a uniform approach throughout the international industry for measuring relays and protection equipment.

This product safety standard for measuring relays and protection equipment takes the general product safety standards and IEC 60664-1 as the base, defining those issues specific to measuring relays and protection equipment.

MEASURING RELAYS AND PROTECTION EQUIPMENT –

Part 27: Product safety requirements

1 Scope

This part of the IEC 60255 series describes the product safety requirements for measuring relays and protection equipment having a rated a.c. voltage up to 1 000 V with a rated frequency up to 65 Hz, or a rated d.c. voltage up to 1 500 V. Above these limits, IEC 60664-1 is applicable for the determination of clearance, creepage distance and withstand test voltage.

This standard details essential safety requirements to minimize the risk of fire and hazards caused by electric shock or injury to the user.

This standard does not cover the safety requirements of installations. It does cover all the ways in which the equipment may be mounted and used in cubicles, racks and panels, and also retesting. This standard also applies to auxiliary devices such as shunts, series resistors, transformers, etc., that are used in conjunction with measuring relays and protection equipment and are tested together.

Ancillary equipment used in conjunction with measuring relays and protection equipment may need to comply with additional safety requirements.

This standard is intended to describe only product safety requirements; therefore, functional performance of the equipment is not covered.

Functional safety requirements, including EMC functional safety, are not covered by this standard. Functional safety risk analysis is not within the scope of this product safety standard.

This standard does not specify the implementation of individual equipment, circuits and components.

The object of this standard is to have a comprehensive standard that covers all aspects of product safety and the related type and routine tests, for measuring relays and protection equipment.

This standard applies to equipment designed to be safe at least under the following environmental conditions:

- indoor use;
- altitude up to 2 000 m, in accordance with IEC 60255-1;
- external operating temperature range, in accordance with IEC 60255-1;
- maximum external relative humidity 95 %, non-condensing, in accordance with IEC 60255-1;
- supply fluctuations in accordance with IEC 60255-1;
- applicable supply overvoltage category;
- external pollution degree 1 and external pollution degree 2.

The equipment will normally be installed in a restricted access area within a power station, substation or industrial/retail environment. The environmental conditions specified for the equipment in IEC 60255-1 apply. This standard considers the normal environmental