

**Fire resistance tests for non-loadbearing elements - Part
4: Curtain walling - Part configuration**

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 1364-4:2014 sisaldab Euroopa standardi EN 1364-4:2014 inglisekeelset teksti.	This Estonian standard EVS-EN 1364-4:2014 consists of the English text of the European standard EN 1364-4:2014.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 05.02.2014.	Date of Availability of the European standard is 05.02.2014.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 13.220.50, 91.060.10

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Aru 10, 10317 Tallinn, Eesti; www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:
Aru 10, 10317 Tallinn, Estonia; www.evs.ee; phone 605 5050; e-mail info@evs.ee

English Version

**Fire resistance tests for non-loadbearing elements - Part 4:
Curtain walling - Part configuration**

Essais de résistance au feu des éléments non-porteurs -
Partie 4: Façades rideaux - Configuration partielle

Feuerwiderstandsprüfungen für nichttragende Bauteile -
Teil 4: Vorhangfassaden - Teilausführung

This European Standard was approved by CEN on 9 November 2013.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

Foreword.....	4
Introduction	5
1 Scope	6
2 Normative references	6
3 Terms and definitions	7
4 Test equipment	8
4.1 General testing principles.....	8
4.2 Furnace configuration.....	9
4.3 Supporting floor.....	9
5 Test conditions	9
6 Test specimen	10
6.1 Size.....	10
6.2 Number of specimens	10
6.3 Design	10
6.3.1 General.....	10
6.3.2 Standard configuration	11
6.3.3 Restraint of the specimen	11
6.3.4 Surfaces.....	12
6.3.5 Perimeter seal	12
6.4 Construction.....	13
6.5 Verification	13
7 Installation of the test specimen	13
7.1 General.....	13
7.2 Supporting floor.....	13
7.2.1 Standard supporting floor	13
7.2.2 Non-standard supporting floor.....	13
7.3 Furnace closure	14
7.4 Fixing of the framing system	14
8 Conditioning.....	14
9 Application of instrumentation.....	14
9.1 Thermocouples	14
9.1.1 Furnace thermocouples (plate thermometers)	14
9.1.2 Unexposed face thermocouples	14

9.2	Pressure	17
9.3	Radiation	17
10	Test procedure.....	17
11	Performance criteria.....	17
12	Test report.....	18
13	Field of direct application of test results	19
13.1	Rules for curtain walling type A.....	19
13.1.1	General rules.....	19
13.1.2	Rules for the complete construction.....	19
13.1.3	Framing system.....	21
13.1.4	Spandrel panels.....	24
13.2	Rules for curtain walling type B.....	28
13.3	Perimeter seal	28
13.3.1	General	28
13.3.2	Material	28
13.3.3	Width/depth.....	29
13.3.4	Fixing of the perimeter seal.....	29
13.3.5	Covering	29
13.4	Supporting floor	29
Annex A	(informative) Guidance on testing curtain walling – part configuration.....	44
A.1	Standard configuration	44
A.1.1	General	44
A.1.2	Supporting floor	44
A.1.3	Parts of a curtain walling	44
A.1.4	Specimen selection	45
A.2	Test principles and requirements.....	45
A.3	Fire from the inside	47
A.3.1	General	47
A.3.2	Curtain walling type A.....	47
A.3.3	Curtain walling type B.....	47
A.3.4	Perimeter seal	48
A.3.5	Fixing of the framing system.....	48
A.4	Fire from the outside.....	48
Annex B	(normative) Standard configurations	51
Annex C	(normative) Radiation calculation	56
Annex D	(normative) Field of direct application of test results for unitised construction	59
D.1	Rules for curtain walling type A.....	59
D.1.1	General	59
D.1.2	Exposure conditions	59
D.1.3	Rules for the complete construction.....	59
D.1.4	Spandrel panels.....	59
D.2	Rules for curtain walling type B.....	59
	Bibliography.....	60

Foreword

This document (EN 1364-4:2014) has been prepared by Technical Committee CEN/TC 127 “Fire safety in buildings”, the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by August 2014, and conflicting national standards shall be withdrawn at the latest by August 2014.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 1364 -4:2007.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of 89/106/EEC.

According to the CEN/CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Introduction

WARNING

The attention of all persons concerned with managing and carrying out this fire resistance test is drawn to the fact that fire testing can be hazardous and that there is a possibility that toxic and/or harmful smoke and gases can be developed during the test. Mechanical and operational hazards can also arise during the construction of the test elements or structures, their testing and disposal of test residues.

An assessment of all potential hazards and risks to health should be made and safety precautions should be identified and provided. Written safety instructions should be issued. Appropriate training should be given to relevant personnel. Laboratory personnel should ensure that they follow written safety instructions at all times.

1 Scope

This European Standard specifies a method for determining the fire resistance of parts of curtain walling and of the perimeter seal. It examines the fire resistance to internal and external fire exposure of:

- the spandrel panel, i.e. downstand, upstand or a combination thereof, or
- the perimeter seal, or
- the fixing of the framing system (anchoring) used to attach the curtain walling to the floor element, or
- combinations thereof.

Results from tests according to this standard form the basis for classification of curtain walling type A (see 3.3 for definition).

For curtain walling type B (see 3.4 for definition) results may be used to determine fire resistance of parts of a curtain walling to increase the field of application when previously tested to EN 1364-3. For intended classification EW and for corner/faceted specimens EN 1364-3 should be used.

This European Standard does not cover double skin façades, over-cladding systems and ventilated façade systems on external walls. It does not deal with the reaction to fire behaviour of curtain walling.

This standard is intended to be read in conjunction with EN 1363-1 and EN 1363-2 as well as EN 1364-3 for curtain walling type B.

NOTE Annex A gives informative guidance on the principles of testing parts of curtain walling and the test method.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1363-1, *Fire resistance tests - Part 1: General Requirements*

EN 1363-2, *Fire resistance tests - Part 2: Alternative and additional procedures*

EN 1364-3, *Fire resistance tests for non-loadbearing elements - Part 3: Curtain walling - Full configuration (complete assembly)*

EN 13119, *Curtain walling - Terminology*

EN 13501-1, *Fire classification of construction products and building elements — Part 1: Classification using data from reaction to fire tests*

EN 13501-2, *Fire classification of construction products and building elements — Part 2: Classification using data from fire resistance tests, excluding ventilation services*

EN 13830, *Curtain walling - Product standard*

EN ISO 13943, *Fire safety - Vocabulary (ISO 13943)*