

Cleanrooms and associated controlled environments -
Part 2: Specifications for monitoring and periodic
testing to prove continued compliance with ISO 14644-1
(ISO 14644-2:2015)

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN ISO 14644-2:2015 sisaldab Euroopa standardi EN ISO 14644-2:2015 ingliskeelset teksti.	This Estonian standard EVS-EN ISO 14644-2:2015 consists of the English text of the European standard EN ISO 14644-2:2015.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 23.12.2015.	Date of Availability of the European standard is 23.12.2015.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 13.040.35

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:

Aru 10, 10317 Tallinn, Eesti; koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Aru 10, 10317 Tallinn, Estonia; homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

English Version

Cleanrooms and associated controlled environments - Part
2: Monitoring to provide evidence of cleanroom
performance related to air cleanliness by particle
concentration (ISO 14644-2:2015)

Salles propres et environnements maîtrisés apparentés
- Partie 2: Surveillance du maintien des performances
de la salle propre pour la propreté particulière de l'air
(ISO 14644-2:2015)

Reinräume und zugehörige Reinraumbereiche - Teil 2:
Überwachung zum Nachweis der Reinraumleistung
bezüglich Luftreinheit anhand der
Partikelkonzentration (ISO 14644-2:2015)

This European Standard was approved by CEN on 27 November 2015.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

European foreword

This document (EN ISO 14644-2:2015) has been prepared by Technical Committee ISO/TC 209 "Cleanrooms and associated controlled environments" in collaboration with Technical Committee CEN/TC 243 "Cleanroom technology" the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by June 2016, and conflicting national standards shall be withdrawn at the latest by June 2016.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN ISO 14644-2:2000.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Endorsement notice

The text of ISO 14644-2:2015 has been approved by CEN as EN ISO 14644-2:2015 without any modification.

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Creating, implementing and maintaining a monitoring plan	2
4.1 Principle.....	2
4.2 Risk assessment.....	2
4.3 Monitoring plan.....	3
4.4 Calibration.....	3
4.5 Review and approval.....	4
4.6 Response to a deviation during monitoring.....	4
5 Periodic classification of air cleanliness by particle concentration	4
Annex A (informative) Matters to consider when developing a monitoring plan	5
Annex B (informative) Considerations for setting alert and action levels	9
Bibliography	14

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT) see the following URL: [Foreword - Supplementary information](#)

The committee responsible for this document is ISO/TC 209, *Cleanrooms and associated controlled environments*.

This second edition cancels and replaces the first edition (ISO 14644-2:2000), which has been technically revised throughout.

ISO 14644 consists of the following parts, under the general title *Cleanrooms and associated controlled environments*:

- *Part 1: Classification of air cleanliness by particle concentration*
- *Part 2: Monitoring to provide evidence of cleanroom performance related to air cleanliness by particle concentration*
- *Part 3: Test methods*
- *Part 4: Design, construction and start-up*
- *Part 5: Operations*
- *Part 7: Separative devices (clean air hoods, gloveboxes, isolators and mini-environments)*
- *Part 8: Classification of air cleanliness by chemical concentration (ACC)*
- *Part 9: Classification of surface cleanliness by particle concentration*
- *Part 10: Classification of surface cleanliness by chemical concentration*

Attention is also drawn to ISO 14698, *Cleanrooms and associated controlled environments — Bio-contamination control*:

- *Part 1: General principles and methods*
- *Part 2: Evaluation and interpretation of bio-contamination data*

Introduction

This revision of ISO 14644-2 emphasizes the need to consider a monitoring strategy in addition to the initial or periodic execution of the classification of a cleanroom or clean zone in accordance with ISO 14644-1:2015, 5.1. The monitoring activity provides a continuing flow of data over time, thereby providing a more detailed view of the performance of the installation.

Potential benefits gained from monitoring are

- faster response to adverse events and conditions,
- ability to develop trends from data over time,
- integration of data from multiple instruments,
- enhanced knowledge of installation and process, which allows for more effective risk assessment, and
- improved control of operational costs and product losses.

ISO 14644-2 specifies the requirements of a monitoring plan, based on risk assessment of the intended use. The data obtained provide evidence of cleanroom or clean zone performance related to air cleanliness by particle concentration.

In some circumstances, relevant regulatory agencies may impose supplementary policies, requirements or restrictions. In such situations, appropriate adaptations of the monitoring procedures may be required. After a monitoring plan is initially established and implemented, it may be necessary to revise the plan when significant changes are made to the installation or process requirements. It is also prudent to conduct periodic reviews of a monitoring plan based on data obtained and experience in use.

Cleanrooms and associated controlled environments —

Part 2:

Monitoring to provide evidence of cleanroom performance related to air cleanliness by particle concentration

1 Scope

This part of ISO 14644 specifies minimum requirements for a monitoring plan for cleanroom or clean zone performance related to air cleanliness by particle concentration, based upon parameters that measure or affect airborne particle concentration.

This part of ISO 14644 does not address condition monitoring of aspects such as vibration or general maintenance of the engineering systems. It does not provide for monitoring of particle populations that are outside the specified lower threshold particle-size range, 0,1 μm to 5 μm . Concentrations of ultrafine particles (particles smaller than 0,1 μm) will be addressed in a separate standard.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 14644-1:2015, *Cleanrooms and associated controlled environments — Part 1: Classification of air cleanliness by particle concentration*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 14644-1 and the following apply:

3.1

test

procedure undertaken in accordance with a defined method to determine the performance of an installation or an element thereof

3.2

monitoring

observations made by measurement in accordance with a defined method and plan to provide evidence of the performance of an installation

Note 1 to entry: Monitoring may be continuous, sequential or periodic; and if periodic, the frequency shall be specified.

Note 2 to entry: This information may be used to detect trends in operational state and to provide process support.

3.3

action level

level of a parameter set by the user which, when exceeded, requires immediate intervention, including investigation of cause, and corrective action