

**UKSE-, LUUGIKOMPLEKTIDE JA AVATAVATE AKENDE  
NING NENDE SULUSTE TULEPÜSIVUSE JA  
SUITSUPIDAVUSE KATSED. OSA 3: UKSE- JA  
LUUGIKOMPLEKTIDE SUITSUPIDAVUSE KATSED**

**Fire resistance and smoke control tests for door and shutter assemblies, openable windows and elements of building hardware - Part 3: Smoke control test for door and shutter assemblies**

**EESTI STANDARDI EESSÕNA****NATIONAL FOREWORD**

See Eesti standard EVS-EN 1634-3:2004 sisaldab Euroopa standardi EN 1634-3:2004 ingliskeelset teksti.	This Estonian standard EVS-EN 1634-3:2004 consists of the English text of the European standard EN 1634-3:2004.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 20.10.2004.	Date of Availability of the European standard is 20.10.2004.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile [standardiosakond@evs.ee](mailto:standardiosakond@evs.ee).

ICS 13.220.50

**Standardite reproduutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele**

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonisse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:  
Aru 10, 10317 Tallinn, Eesti; koduleht [www.evs.ee](http://www.evs.ee); telefon 605 5050; e-post [info@evs.ee](mailto:info@evs.ee)

**The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation**

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Aru 10, 10317 Tallinn, Estonia; homepage [www.evs.ee](http://www.evs.ee); phone +372 605 5050; e-mail [info@evs.ee](mailto:info@evs.ee)

EUROPEAN STANDARD  
NORME EUROPÉENNE  
EUROPÄISCHE NORM

EN 1634-3

October 2004

ICS 13.220.50

Supersedes EN 1634-3:2001

English version

Fire resistance tests for door and shutter assemblies - Part 3:  
Smoke control doors and shutters

Essais de résistance au feu des portes et fermetures -  
Partie 3: Portes et volets pare-fumées

Feuerwiderstandsprüfungen für Tür- und  
Abschlusseinrichtungen - Teil 3: Rauchschutzabschlüsse

This European Standard was approved by CEN on 15 July 2004.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Central Secretariat has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

## Contents

	Page
<b>Foreword .....</b>	<b>3</b>
<b>1 Scope.....</b>	<b>4</b>
<b>2 Normative references .....</b>	<b>4</b>
<b>3 Definitions, symbols and designations .....</b>	<b>4</b>
<b>3.1 Terms and definitions.....</b>	<b>4</b>
<b>3.2 Symbols and designation .....</b>	<b>5</b>
<b>4 Test equipment.....</b>	<b>6</b>
<b>4.1 Test apparatus.....</b>	<b>6</b>
<b>4.2 Instrumentation .....</b>	<b>6</b>
<b>5 Test conditions.....</b>	<b>7</b>
<b>6 Test specimen .....</b>	<b>7</b>
<b>6.1 Size .....</b>	<b>7</b>
<b>6.2 Number.....</b>	<b>7</b>
<b>6.3 Design and construction .....</b>	<b>7</b>
<b>6.4 Verification.....</b>	<b>8</b>
<b>7 Installation of test specimen.....</b>	<b>8</b>
<b>8 Conditioning .....</b>	<b>8</b>
<b>8.1 Moisture content .....</b>	<b>8</b>
<b>8.2 Mechanical conditioning .....</b>	<b>8</b>
<b>9 Application of instrumentation.....</b>	<b>9</b>
<b>9.1 Thermocouples .....</b>	<b>9</b>
<b>9.2 Pressure.....</b>	<b>9</b>
<b>9.3 Air flow .....</b>	<b>9</b>
<b>10 Test procedure .....</b>	<b>9</b>
<b>10.1 Pre-test procedures .....</b>	<b>9</b>
<b>10.2 Air leakage test.....</b>	<b>10</b>
<b>10.3 Observations .....</b>	<b>12</b>
<b>11 Expression of results.....</b>	<b>12</b>
<b>11.1 Ambient temperature only test to satisfy S<sub>a</sub> classification .....</b>	<b>12</b>
<b>11.2 Ambient together with medium temperature tests to satisfy S<sub>m</sub> .....</b>	<b>13</b>
<b>12 Test report .....</b>	<b>14</b>
<b>13 Field of direct application of test results.....</b>	<b>14</b>
<b>13.1 General .....</b>	<b>14</b>
<b>13.2 Construction of assembly .....</b>	<b>15</b>
<b>13.3 Size and aspect ratio .....</b>	<b>16</b>
<b>13.4 Glazing .....</b>	<b>16</b>
<b>13.5 Hardware and fittings .....</b>	<b>16</b>
<b>13.6 Seals .....</b>	<b>16</b>
<b>Annex A (informative) Test principle .....</b>	<b>17</b>
<b>Annex B (informative) Test apparatus .....</b>	<b>18</b>

## Foreword

This document (EN 1634-3:2004) has been prepared by Technical Committee CEN/TC 127 "Fire Safety in Buildings", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by April 2005, and conflicting national standards shall be withdrawn at the latest by April 2005.

This document has been prepared under mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of the Construction Products Directive.

This document supersedes EN 1634-3:2001.

EN 1634 '*Fire resistance tests for door and shutter assemblies*' consists of the following:

Part 1: *Fire doors and shutters*,

Part 2: *Fire door hardware - Building hardware for fire resisting doorsets and openable windows (in course of preparation)*,

Part 3: *Smoke control doors and shutters*.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

### Caution

The attention of all persons concerned with managing and carrying out this test is drawn to the following. Mechanical and operation hazards may arise during the construction of the test elements or structures, their testing and disposal of test residues. An assessment of all potential hazards and risks to health should be made and safety precautions should be identified and provided. Written safety instructions should be issued. Appropriate training should be given to relevant personnel.

Laboratory personnel should ensure that they follow written safety instructions at all times.

## 1 Scope

This Part of EN 1634 specifies a method for determining the leakage of cold and warm smoke from one side of a door assembly to the other under the specified test conditions. The test can be applied to door and shutter assemblies of different types intended for purposes of controlling the passage of smoke in case of fire. This test can also be applied to lift landing doors and conveyor system doors and shutters. The principle of the test is explained briefly in annex A.

## 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1363-1:1999, *Fire resistance tests — Part 1: General requirements*

EN 1634-1:2000, *Fire resistance tests for door and shutter assemblies — Part 1: Fire doors and shutters*

EN 13501-2:2003, *Fire classification of construction products and building elements — Part 2: Classification using data from fire resistance tests, excluding ventilation services*

prEN 14600, *Fire resisting and/or smoke control doorsets and operable windows - Requirements and classification*

EN ISO 13943:2000, *Fire safety — Vocabulary (ISO 13943:2000)*

## 3 Definitions, symbols and designations

### 3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 1363-1:1999, EN 1634-1:2000 and EN ISO 13943:2000, together with the following, apply:

#### 3.1.1

##### **smoke control door**

door assembly which has the function of restricting the passage of smoke, when in a closed position, to prescribed limits

#### 3.1.2

##### **ambient temperature**

for the purpose of this standard ambient temperature is an air temperature of  $(20 \pm 10) ^\circ\text{C}$

#### 3.1.3

##### **medium temperature**

for the purpose of this standard medium temperature is an air temperature of  $(200 \pm 20) ^\circ\text{C}$

#### 3.1.4

##### **smoke leakage Sa**

ambient temperature smoke leakage classification as defined in 7.5.6.3.1 of EN 13501-2:2003