

**Elektriõhuliinid vahelduvpingega üle 45 kV. Osa 1:
Üldnõuded - ühised eeskirjad**

Overhead electrical lines exceeding AC 45 kV - Part 1:
General requirements - Common specifications

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

Käesolev Eesti standard EVS-EN 50341-1:2006 sisaldab Euroopa standardi EN 50341-1:2001 ingliskeelset teksti.

Standard on kinnitatud Eesti Standardikeskuse 15.10.2002 käskkirjaga ja jõustub sellekohase teate avaldamisel EVS Teatajas.

Euroopa standardimisorganisatsioonide poolt rahvuslikele liikmetele Euroopa standardi teksti kättesaadavaks tegemise kuupäev on 31.10.2001.

Standard on kättesaadav Eesti standardiorganisatsioonist.

This Estonian standard EVS-EN 50341-1:2006 consists of the English text of the European standard EN 50341-1:2001.

This standard is ratified with the order of Estonian Centre for Standardisation dated 15.10.2002 and is endorsed with the notification published in the official bulletin of the Estonian national standardisation organisation.

Date of Availability of the European standard text 31.10.2001.

The standard is available from Estonian standardisation organisation.

ICS 29.240.20

Võttesõnad: 45 kV, elektriõhuliin, projekteerimine, õhuliin, üldnõuded

Standardite reprodutseerimis- ja levitamiseõigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonilisse süsteemi või edastamine ükskõik millises vormis või millisel teel on keelatud ilma Eesti Standardikeskuse poolt antud kirjaliku loata.

Kui Teil on küsimusi standardite autorikaitse kohta, palun võtke ühendust Eesti Standardikeskusega:
Aru 10 Tallinn 10317 Eesti; www.evs.ee; Telefon: 605 5050; E-post: info@evs.ee

EUROPEAN STANDARD

EN 50341-1

NORME EUROPÉENNE

EUROPÄISCHE NORM

October 2001

ICS 29.240.20

English version

**Overhead electrical lines exceeding AC 45 kV
Part 1: General requirements -
Common specifications**

Lignes électriques aériennes dépassant
AC 45 kV
Partie 1: Règles générales -
Spécifications communes

Freileitungen über AC 45 kV
Teil 1: Allgemeine Anforderungen -
Gemeinsame Festlegungen

This European Standard was approved by CENELEC on 2001-01-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Malta, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

This European Standard was prepared by the Technical Committee CENELEC TC 11, Overhead electrical lines exceeding AC 1 kV (DC 1,5 kV).

The text of the draft was submitted to the Unique Acceptance Procedure and was approved by CENELEC as EN 50341-1 on 2001-01-01.

The following dates were fixed:

- latest date by which the EN has to be implemented
at national level by publication of an identical
national standard or by endorsement (dop) 2002-05-01
- latest date by which the national standards conflicting
with the EN have to be withdrawn (dow) 2004-01-01

Annexes designated "normative" are part of the body of the standard.

Annexes designated "informative" are given for information only.

In this standard, annexes E, G, J & K are normative and annexes A, B, C, D, F, H, L, M, N, P, Q & R are informative.

As far as the overhead lines towers are concerned, the designer may refer to prEN 1993-7-1, currently referred to as ENV 1993-3-1, as prepared by TC 250 of CEN, if considered appropriate.

Contents

	Introduction.....	12
1	Scope.....	14
2	Definitions, symbols and references.....	14
2.1	Definitions.....	14
2.2	List of symbols	26
2.3	References.....	32
3	Basis of design.....	36
3.1	General.....	36
3.2	Requirements.....	38
3.2.1	<i>Basic requirements.....</i>	<i>38</i>
3.2.2	<i>Reliability of overhead lines</i>	<i>38</i>
3.2.3	<i>Security requirements.....</i>	<i>39</i>
3.2.4	<i>Safety requirements during construction and maintenance</i>	<i>39</i>
3.2.5	<i>Coordination of strength</i>	<i>39</i>
3.2.6	<i>Additional considerations.....</i>	<i>40</i>
3.2.7	<i>Design working life</i>	<i>40</i>
3.2.8	<i>Durability.....</i>	<i>40</i>
3.2.9	<i>Quality assurance.....</i>	<i>40</i>
3.3	Limit states	40
3.3.1	<i>General.....</i>	<i>40</i>
3.3.2	<i>Ultimate limit states.....</i>	<i>40</i>
3.3.3	<i>Serviceability limit states.....</i>	<i>41</i>
3.3.4	<i>Limit state design</i>	<i>41</i>
3.4	Actions.....	42
3.4.1	<i>Principal classifications.....</i>	<i>42</i>
3.4.2	<i>Characteristic values of actions</i>	<i>43</i>
3.4.3	<i>Combination values of variable actions</i>	<i>43</i>
3.5	Material properties	43
3.6	Modelling for structural analysis and resistance	44
3.6.1	<i>General.....</i>	<i>44</i>
3.6.2	<i>Interactions between support foundations and soil.....</i>	<i>44</i>
3.7	Design values and verification method	44
3.7.1	<i>General.....</i>	<i>44</i>
3.7.2	<i>Design values.....</i>	<i>45</i>
3.7.3	<i>Basic design equation.....</i>	<i>45</i>
3.7.4	<i>Combination of actions</i>	<i>46</i>
4	Actions on lines.....	47
4.1	Introduction.....	47
4.2	Actions, General approach	47
4.2.1	<i>Permanent loads</i>	<i>47</i>
4.2.2	<i>Wind loads</i>	<i>47</i>
4.2.3	<i>Ice loads.....</i>	<i>56</i>
4.2.4	<i>Combined wind and ice loads</i>	<i>58</i>
4.2.5	<i>Temperature effects</i>	<i>60</i>
4.2.6	<i>Construction and maintenance loads</i>	<i>60</i>
4.2.7	<i>Security loads.....</i>	<i>61</i>
4.2.8	<i>Forces due to short circuit currents.....</i>	<i>62</i>
4.2.9	<i>Other special forces</i>	<i>62</i>
4.2.10	<i>Load cases.....</i>	<i>62</i>
4.2.11	<i>Partial factors for actions</i>	<i>66</i>

4.3	Actions, Empirical approach	67
4.3.1	<i>Permanent loads</i>	67
4.3.2	<i>Wind loads</i>	67
4.3.3	<i>Ice loads</i>	68
4.3.4	<i>Combined wind and ice loads</i>	68
4.3.5	<i>Temperature effects</i>	68
4.3.6	<i>Construction and maintenance loads</i>	68
4.3.7	<i>Security loads</i>	68
4.3.8	<i>Forces due to short circuit currents</i>	69
4.3.9	<i>Other special forces</i>	69
4.3.10	<i>Load cases</i>	69
4.3.11	<i>Partial factors for actions</i>	70
5.	Electrical requirements	71
5.1	Voltage classification	71
5.2	Currents	72
5.2.1	<i>Normal current</i>	72
5.2.2	<i>Short-circuit current</i>	72
5.3	Insulation co-ordination	73
5.3.1	<i>General</i>	73
5.3.2	<i>Origin and classification of voltage stresses on overhead lines and evaluation of the representative overvoltages</i>	73
5.3.3	<i>Determination of the co-ordination withstand voltage</i>	74
5.3.4	<i>Determination of the required withstand voltage</i>	76
5.3.5	<i>Electrical clearance distances to avoid flashover</i>	76
5.4	Internal and external clearances	81
5.4.1	<i>Introduction</i>	81
5.4.2	<i>General considerations and load cases</i>	81
5.4.3	<i>Clearances within the span and at the tower</i>	84
5.4.4	<i>Clearances to ground in areas remote from buildings, roads, railways and navigable waterways</i>	85
5.4.5	<i>Clearances to buildings, traffic routes, other lines and recreational areas</i>	86
5.5	Corona effect	92
5.5.1	<i>Radio noise</i>	92
5.5.2	<i>Audible noise</i>	93
5.5.3	<i>Corona loss</i>	93
5.6	Electric and magnetic fields	94
5.6.1	<i>Electric and magnetic fields under a line</i>	94
5.6.2	<i>Electric and magnetic field induction</i>	94
5.6.3	<i>Interference with telecommunication circuits</i>	95
6.	Earthing systems	95
6.1	Purpose	95
6.2	Dimensioning of earthing systems at power frequency	95
6.2.1	<i>General</i>	95
6.2.2	<i>Dimensioning with respect to corrosion and mechanical strength</i>	96
6.2.3	<i>Dimensioning with respect to thermal strength</i>	97
6.2.4	<i>Dimensioning with regard to human safety</i>	97
6.3	Construction of earthing systems	101
6.3.1	<i>Installation of earth electrodes</i>	101
6.3.2	<i>Transferred potentials</i>	101
6.4	Earthing measures against lightning effects	102
6.5	Measurements for and on earthing systems	102
6.6	Site inspection and documentation of earthing systems	102

7	Supports	102
7.1	Initial design considerations.....	102
7.2	Materials.....	102
7.2.1	Steel materials, bolts, nuts and washers, welding consumables.....	102
7.2.2	Cold formed steel	103
7.2.3	Requirements for steel grades subject to galvanising.....	103
7.2.4	Holding-down bolts.....	103
7.2.5	Concrete and reinforcing steel.....	103
7.2.6	Timber.....	103
7.2.7	Guy materials.....	103
7.2.8	Other materials.....	103
7.3	Lattice steel towers.....	103
7.3.1	General.....	103
7.3.2	Basis of design.....	104
7.3.3	Materials	104
7.3.4	Serviceability limit states.....	104
7.3.5	Ultimate limit states	104
7.3.6	Connections	106
7.3.7	Fabrication and erection	107
7.3.8	Design assisted by testing	107
7.4	Steel poles	107
7.4.1	General.....	107
7.4.2	Basis of design.....	108
7.4.3	Materials	108
7.4.4	Serviceability limit states.....	108
7.4.5	Ultimate limit states	108
7.4.6	Connections	109
7.4.7	Fabrication and erection	111
7.4.8	Design assisted by testing	111
7.5	Timber poles	111
7.5.1	General.....	111
7.5.2	Basis of design.....	111
7.5.3	Materials	111
7.5.4	Serviceability limit states	111
7.5.5	Ultimate limit states	112
7.5.6	Resistance of connections.....	112
7.5.7	Design assisted by testing	112
7.6	Concrete poles	113
7.6.1	General.....	113
7.6.2	Basis of design.....	113
7.6.3	Materials	113
7.6.4	Serviceability limit states	114
7.6.5	Ultimate limit states	114
7.6.6	Design assisted by testing	114
7.7	Guyed structures.....	115
7.7.1	General.....	115
7.7.2	Basis of design.....	115
7.7.3	Materials	115
7.7.4	Serviceability limit states.....	115
7.7.5	Ultimate limit states	115
7.7.6	Design details for guys	116
7.8	Other structures	117

7.9	Corrosion protection and finishes	117
7.9.1	<i>General</i>	117
7.9.2	<i>Galvanising</i>	118
7.9.3	<i>Metal spraying</i>	118
7.9.4	<i>Paint over galvanising in plant (Duplex system)</i>	118
7.9.5	<i>Decorative finishes</i>	119
7.9.6	<i>Use of weather-resistant steels</i>	119
7.9.7	<i>Protection of timber poles</i>	119
7.10	Maintenance facilities	119
7.10.1	<i>Climbing</i>	119
7.10.2	<i>Maintainability</i>	119
7.10.3	<i>Safety requirements</i>	119
7.11	Loading tests	120
7.12	Assembly and erection	120
8	Foundations	120
8.1	Introduction	120
8.2	General requirements	120
8.3	Soil investigation	121
8.4	Loads acting on the foundations	121
8.5	Geotechnical design	122
8.5.1	<i>General</i>	122
8.5.2	<i>Geotechnical design by calculation</i>	122
8.5.3	<i>Geotechnical design by prescriptive measures</i>	123
8.6	Loading tests	123
8.7	Structural design	123
8.8	Construction and installation	124
9	Conductors and overhead earthwires (ground wires) with or without telecommunication circuits	124
9.1	Introduction	124
9.2	Aluminium based conductors	125
9.2.1	<i>Characteristics and dimensions</i>	125
9.2.2	<i>Electrical requirements</i>	125
9.2.3	<i>Conductor service temperatures and grease characteristics</i>	126
9.2.4	<i>Mechanical requirements</i>	126
9.2.5	<i>Corrosion protection</i>	126
9.2.6	<i>Test requirements</i>	127
9.3	Steel based conductors	127
9.3.1	<i>Characteristics and dimensions</i>	127
9.3.2	<i>Electrical requirements</i>	127
9.3.3	<i>Conductor service temperatures and grease characteristics</i>	127
9.3.4	<i>Mechanical requirements</i>	127
9.3.5	<i>Corrosion protection</i>	128
9.3.6	<i>Test requirements</i>	128
9.4	Copper based conductors	128
9.5	Conductors (OPCON's) and ground wires (OPGW's) containing optical fibre telecommunication circuits	128
9.5.1	<i>Characteristics and dimensions</i>	128
9.5.2	<i>Electrical requirements</i>	128
9.5.3	<i>Conductor service temperature</i>	129
9.5.4	<i>Mechanical requirements</i>	129
9.5.5	<i>Corrosion protection</i>	129
9.5.6	<i>Test requirements</i>	129

9.6	General requirements.....	129
9.6.1	<i>Avoidance of damage</i>	129
9.6.2	<i>Partial factor for conductors</i>	129
9.7	Test reports and certificates	130
9.8	Selection, delivery and installation of conductors	130
10	Insulators	130
10.1	General.....	130
10.2	Standard electrical requirements.....	130
10.3	RIV requirements and corona extinction voltage.....	131
10.4	Pollution performance requirements.....	131
10.5	Power arc requirements	132
10.6	Audible noise requirements	132
10.7	Mechanical requirements	132
10.8	Durability requirements	132
10.8.1	<i>General requirements for durability of insulators</i>	132
10.8.2	<i>Protection against vandalism</i>	132
10.8.3	<i>Protection of ferrous materials</i>	133
10.8.4	<i>Additional corrosion protection</i>	133
10.9	Material selection and specification	133
10.10	Characteristics and dimensions of insulators	133
10.11	Type test requirements.....	134
10.11.1	<i>Standard type tests</i>	134
10.11.2	<i>Optional type tests</i>	134
10.12	Sample test requirements.....	134
10.13	Routine test requirements	135
10.14	Summary of test requirements	135
10.15	Test reports and certificates	135
10.16	Selection, delivery and installation of insulators.....	135
11	Line equipment – Overhead line fittings.....	135
11.1	General.....	135
11.2	Electrical requirements.....	136
11.2.1	<i>Requirements applicable to all fittings</i>	136
11.2.2	<i>Requirements applicable to current carrying fittings</i>	136
11.3	RIV requirements and corona extinction voltage.....	136
11.4	Magnetic characteristics	136
11.5	Short circuit current and power arc requirements.....	136
11.6	Mechanical requirements	137
11.7	Durability requirements	137
11.8	Material selection and specification	137
11.9	Characteristics and dimensions of fittings.....	137
11.10	Type test requirements.....	138
11.10.1	<i>Standard type tests</i>	138
11.10.2	<i>Optional type tests</i>	138
11.11	Sample test requirements.....	138
11.12	Routine test requirements	138
11.13	Test reports and certificates	138
11.14	Selection, delivery and installation of fittings	138
12	Quality assurance, checks and taking-over.....	139
12.1	Quality assurance.....	139
12.2	Checks and taking-over.....	139

Annex A (informative) Strength coordination	141
A.1 Recommended design criteria	141
A.2 Proposed strength coordination	141
Annex B (informative) Extreme wind speeds and ice loads	143
B.1 Definition of symbols used in this annex	143
B.2 Evaluation of extreme wind speed data	143
B.3 Definition of extreme ice load	144
B.4 Statistical ice parameters	145
B.4.1 Basic ice load	145
B.4.2 Maximum yearly ice load I_m	145
B.4.3 Maximum ice load over several years I_{max}	145
B.4.4 Mean value I_{mm} of maximum yearly ice loads	145
B.4.5 Coefficient of variation v_i for maximum yearly ice loads	145
B.5 Extreme ice load evaluation based on various data sources	145
B.5.1 Data sources for statistical evaluation	145
B.5.2 Yearly maxima ice loads during periods of at least 10 years are available	146
B.5.3 Maximum ice load I_{max} is known only for a limited number of years	146
B.5.4 Evaluation of annual maximum ice load by means of analyses of meteorological data	146
B.6 Combination of wind speeds and ice loads	147
B.6.1 Extreme ice load I_L combined with a moderate wind speed V_{IH}	147
B.6.2 High wind speed V_{IL} combined with a moderate ice load I_H	147
Annex C (informative) Special forces	148
C.1 Definition of symbols used in this annex	148
C.2 Forces due to short circuit currents	148
C.3 Avalanches, creeping snow	149
C.4 Earthquakes	149
Annex D (informative) Statistical data for the Gumbel distribution of extremes	150
D.1 Definition of symbols used in this annex	150
D.2 The Gumbel distribution	150
D.3 Example of using C_1 and C_2	154
D.4 Calculation of C_1 and C_2	154
Annex E (normative) Electrical requirements	158
E.1 Definition of symbols used in this annex	158
E.2 Insulation co-ordination	159
E.2.1 Development of theoretical formulae for calculating electrical distances	159
E.2.2 Required withstand voltage of the air U_w	159
E.2.3 Overvoltages to be taken into account	162
E.2.4 Calculation formulae	164
E.2.5 Altitude factor	164
Annex F (informative) Electrical requirements	166
F.1 Definition of symbols used in this annex	166
F.2 Insulation co-ordination. Examples of calculation of D_{el} , D_{pp} and D_{50Hz} for different system voltages	166
F.2.1 Range I: 90 kV system equipped with insulator strings composed of 6 units	166
F.2.2 Range I: 90 kV system equipped with insulator strings composed of 9 units	168
F.2.3 Range II: 400 kV system	169

Annex G (normative) Earthing systems.....	172
G.1 Definition of symbols used in this annex	172
G.2 Minimum dimensions of earth electrode materials ensuring mechanical strength and corrosion resistance.....	173
G.3 Current rating calculation.....	174
G.4 Touch voltage and body current	177
G.4.1 <i>Equivalence between touch voltage and body current</i>	177
G.4.2 <i>Calculation taking into account additional resistances</i>	179
G.5 Measuring touch voltages.....	180
G.6 Reduction factor related to earthwires of overhead lines.....	180
G.6.1 <i>General</i>	180
G.6.2 <i>Values of reduction factors of overhead lines</i>	181
Annex H (informative) Earthing systems	182
H.1 Definition of symbols used in this annex	182
H.2 Basis for the verification	182
H.2.1 <i>Soil resistivity</i>	182
H.2.2 <i>Resistance to earth</i>	183
H.3 Installation of earth electrodes and earthing conductors.....	186
H.3.1 <i>Installation of earth electrodes</i>	186
H.3.2 <i>Installation of earthing conductors</i>	186
H.4 Measurements for and on earthing systems.....	187
H.4.1 <i>Measurement of soil resistivities</i>	187
H.4.2 <i>Measurement of resistances to earth and impedances to earth</i>	187
H.4.3 <i>Determination of the earth potential rise</i>	189
Annex J (normative) Lattice steel towers	190
J.1 Definition of symbols used in this annex	190
J.2 Classification of cross sections	191
J.2.1 <i>Basis</i>	191
J.2.2 <i>Classification</i>	191
J.2.3 <i>Effective cross-section properties for compression members</i>	191
J.3 Section properties.....	192
J.3.1 <i>Gross cross section</i>	192
J.3.2 <i>Net area</i>	192
J.4 Check of cross section resistance.....	193
J.4.1 <i>Tension</i>	193
J.4.2 <i>Compression</i>	194
J.4.3 <i>Bending moment</i>	194
J.4.4 <i>Bending and axial forces</i>	194
J.5 Check of the buckling resistance of members.....	195
J.5.1 <i>Compression members</i>	195
J.5.2 <i>Lateral torsional buckling of beams</i>	196
J.5.3 <i>Bending and axial tension</i>	196
J.5.4 <i>Bending and axial compression</i>	196
J.6 Buckling length of members	196
J.6.1 <i>General</i>	196
J.6.2 <i>Leg members and chords</i>	196
J.6.3 <i>Bracing patterns</i>	197
J.6.4 <i>Compound members</i>	202
J.7 Additional recommendations on bracing patterns.....	204
J.7.1 <i>Horizontal edge members with horizontal plan bracing</i>	204
J.7.2 <i>Horizontal edge members without horizontal plan bracing</i>	205
J.7.3 <i>Cranked K bracing</i>	206
J.7.4 <i>Portal frame</i>	206

J.8	Calculation of effective slenderness $\bar{\lambda}_{\text{eff}}$	206
J.9	Selection of buckling cases for angles	207
J.9.1	<i>Single angle</i>	207
J.9.2	<i>Compound members / Laced members</i>	208
J.10	Secondary (redundant) members	208
J.11	Bolted connections	209
Annex K	(normative) Steel poles	211
K.1	Definition of symbols used in this annex	211
K.2	Classification of cross sections	212
K.3	Effective cross-sections properties of class 4 cross-sections	213
K.4	Resistance of circular cross sections, without opening, under preponderant bending moment	213
K.5	Resistance of polygonal cross sections, without opening, under preponderant bending moment	214
K.5.1	<i>Class 3 cross-sections</i>	214
K.5.2	<i>Class 4 cross-sections</i>	215
K.6	Design of holding-down bolts	215
Annex L	(informative) Design requirements for supports and foundations	219
L.1	Structural requirement	219
L.2	Configuration requirements : types of supports and uses	219
L.3	Phase conductor and earthwire attachment	221
L.4	Foundation steelwork	221
L.5	Erection/maintenance facilities	221
L.6	Mass-length restrictions	221
Annex M	(informative) Typical values of the geotechnical parameters of soils and rocks	222
M.1	General	222
M.2	Definitions	222
M.3	Units	222
Annex N	(informative) Conductors and overhead earthwires	226
N.1	Specification of conductors and earthwires	226
N.1.1	<i>Factors influencing the specification of conductors and earthwires</i>	226
N.1.2	<i>Operational factors</i>	226
N.1.3	<i>Maintenance requirements</i>	226
N.1.4	<i>Environmental parameters</i>	226
N.2	Selection of conductors and earthwires	227
N.3	Packing and delivery of conductors and earthwires	227
N.4	Precautions during installation of conductors and earthwires	227
Annex P	(informative) Tests on overhead line insulators and insulator sets in porcelain and glass insulating materials	228
Annex Q	(informative) Insulators	231
Q.1	Specification of insulators	231
Q.1.1	<i>Factors influencing the specification of insulators</i>	231
Q.1.2	<i>Operational factors</i>	231
Q.1.3	<i>Maintenance requirements</i>	231
Q.1.4	<i>Environmental parameters</i>	231
Q.2	Selection of insulators	232
Q.3	Packing and delivery of insulators	232
Q.4	Precautions during installation of insulators	232

Annex R (informative) Line equipment – Overhead line fittings	233
R.1 Specification and selection of fittings.....	233
<i>R.1.1 Factors influencing specification and selection.....</i>	<i>233</i>
<i>R.1.2 Operational factors.....</i>	<i>233</i>
<i>R.1.3 Maintenance requirements</i>	<i>233</i>
<i>R.1.4 Environmental parameters.....</i>	<i>233</i>
R.2 Packing and delivery of fittings.....	234
R.3 Precautions during installation of fittings.....	234

This document is a preview generated by EVS

Introduction

Detailed structure of the standard

The standard comprises three parts:

Part 1: General requirements - Common specifications

This part, also referred to as the Main Body, includes clauses common to all countries. These clauses have been prepared by Working Groups and approved by CLC/TC 11.

The Main Body is available in English, French and German.

Part 2: Index of National Normative Aspects

This index gives the list of all the National Normative Aspects (NNAs) - see signification and contents of NNAs hereafter under "Part 3: National Normative Aspects".

The index is available in English, French and German.

Part 3: National Normative Aspects

The National Normative Aspects (NNAs) reflect national practices. They generally include A-deviations, special national conditions and national complements.

A-deviations:

A-deviations are required by existing national laws or regulations, which cannot be altered at the time of preparation of the standard.

Reference is made to CENELEC Internal Regulations Part 2, definition 3.1.9.

Special national conditions (snc):

Special national conditions are national characteristics or practices that cannot be changed even over a long period, e.g. those due to climatic conditions, earth resistivity, etc.

Reference is made to CENELEC Internal Regulations, Part 2, definition 3.1.7/ 3.1.9.

National complements (NCPTs):

National complements reflect national practices, which are neither A-deviations, nor special national conditions. It has been agreed within CLC/TC 11 that NCPTs should be gradually adapted to the Main Body, aiming at the usual EN standard structure including only a Main Body, A-deviations and special national conditions.

Rules for the numbering of NNAs:

The NNAs are numbered as follows :

AT	Austria	EN 50341-3-1
BE	Belgium	EN 50341-3-2
CH	Switzerland	EN 50341-3-3
DE	Germany	EN 50341-3-4
DK	Denmark	EN 50341-3-5
ES	Spain	EN 50341-3-6
FI	Finland	EN 50341-3-7
FR	France	EN 50341-3-8
GB	Great Britain	EN 50341-3-9
GR	Greece	EN 50341-3-10
IE	Ireland	EN 50341-3-11
IS	Iceland	EN 50341-3-12
IT	Italy	EN 50341-3-13
LU	Luxembourg	EN 50341-3-14 (non existant)
NL	Netherlands	EN 50341-3-15
NO	Norway	EN 50341-3-16
PT	Portugal	EN 50341-3-17
SE	Sweden	EN 50341-3-18
CZ	Czech Republic	EN 50341-3-19
x	xxxx	EN 50341-3-xx, etc.

Language:

The NNAs are published in English and in the national language(s) of the respective country.

1 Scope

This standard applies to overhead electric lines with rated voltages exceeding 45 kV AC and with rated frequencies below 100 Hz.

This standard specifies the general requirements that shall be met for the design and construction of new overhead lines to ensure that the line is suitable for its purpose with regard to safety of persons, maintenance, operation and environmental considerations.

NOTE 1 The extent of the application of this standard by each country in respect of existing overhead lines is subject to the requirements of the National Normative Aspects (NNA) applicable to that country.

NOTE 2 Design and construction of overhead lines with insulated conductors, where internal and external clearances can be smaller than specified in the standard are not included. All other requirements of the standard may be applied to overhead lines with insulated conductors. When necessary, requirements for clearances can be given in the NNAs.

NOTE 3 This part of the standard is applicable for optical Ground Wires (OPGWs) and optical Conductors (OPCONs). However the standard is not applicable to telecommunication systems which are used on overhead transmission lines either attached to the transmission line conductor/earth wire system (for example wraparound,...) or as separate cables supported by the transmission supports for example All Dielectric Self Supporting (ADSS) or for telecommunication equipment mounted on individual transmission line structures. When necessary, requirements can be given in the NNAs.

This standard does not apply to :

- overhead electric lines inside closed electrical areas as defined in HD 637;
- catenary systems of electrified railways.

2 Definitions, symbols and references

2.1 Definitions

For the purposes of this European Standard, the terms and definitions given in the International Vocabulary (IEC 60050) Chapters 441, 466, 471, 601 and 604 and the following apply.

In order to achieve a better understanding of the definition of certain terms used in this standard, some words in the definitions are written in *italics*. The definitions of these words are also given in this subclause.

2.1.1

action

- a) force (load) applied to the (*mechanical*) system (direct action).

NOTE An action can be *permanent*, *variable* or *accidental*.

- b) an imposed or constrained deformation or an imposed acceleration caused for example, by temperature changes, moisture variation, uneven settlement or earthquakes (indirect action)

2.1.2

accidental action

action, usually of short duration, which is unlikely to occur with a significant magnitude during the *design working life*

NOTE An accidental action can be expected in many cases to cause severe consequences unless special measures are taken.