

English Version

**Power transformers - Part 22-7: Power transformer and reactor
fittings - Accessories and fittings
(IEC 60076-22-7:2020/COR1:2023)**

Transformateurs de puissance - Partie 22-7:
Transformateurs de puissance et bobines d'inductance -
Accessoires et équipements
(IEC 60076-22-7:2020/COR1:2023)

Leistungstransformatoren - Teil 22-7: Zubehörteile von
Leistungstransformatoren und Drosselspulen - Zubehörteile
und Armaturen
(IEC 60076-22-7:2020/COR1:2023)

This corrigendum becomes effective on 14 July 2023 for incorporation in the English language version of the EN.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Endorsement notice

The text of the corrigendum IEC 60076-22-7:2020/COR1:2023 was approved by CENELEC as EN IEC 60076-22-7:2020/AC:2023-07 without any modification.

INTERNATIONAL ELECTROTECHNICAL COMMISSION
COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

IEC 60076-22-7
Edition 1.0 2020-05

IEC 60076-22-7
Édition 1.0 2020-05

Power transformers –

Transformateurs de puissance –

**Part 22-7: Power transformer and reactor fittings
– Accessories and fittings**

**Partie 22-7: Transformateur de puissance et
bobines d'inductance – Accessoires et
équipements**

C O R R I G E N D U M 1

Corrections to the French version appear after the English text.

Les corrections à la version française sont données après le texte anglais.

In Annex C, replace the line:

" V [dm³] = volume of insulating liquid in the transformer"

with the following:

" V [m³] = volume of insulating liquid in the transformer"

Additionally in Annex C, replace the line:

"Silica gel content = $(7,4 \times 10^{-4} \times 84\,000 \times 20 \times 6,88 \times 365) / 150 = 20,8$ kg"

with the following:

"Silica gel content = $(7,4 \times 10^{-4} \times 84 \times 20 \times 6,88 \times 365) / 150 = 20,8$ kg"