

**IEC 62271-102, Amendment 1
(2011)**

High-voltage switchgear and controlgear –

**Part 102: Alternating current disconnectors and
earthing switches**

**CEI 62271-102, Amendement 1
(2011)**

Appareillage à haute tension –

**Partie 102: Sectionneurs et sectionneurs de terre
à courant alternatif**

CORRIGENDUM 1

3.4.105.3

Instead of the existing text, read:

3.4.105.3

earthing switch class E2

*Replace the existing term, definition and
note by the following new term, definition
and note:*

earthing switch class E2 (for earthing
switches up to and including 52 kV)

earthing switch suitable for applications in
distribution and transmission systems
fulfilling the general requirements of this
standard, with the capability to withstand
five short-circuit making operations

NOTE The increased number of making operations
in Class E2 is restricted to voltages up to and
including 52 kV only depending on the operating
conditions and the protection systems typical to
such networks.

3.4.105.3

Au lieu du texte existant, lire:

3.4.105.3

sectionneur de terre de classe E2

*Remplacer le terme, la définition et la note
existants par les nouveaux terme,
définition et note suivants:*

sectionneur de terre de classe E2 (pour
les sectionneurs de terre de tension
inférieure ou égale à 52 kV)

sectionneur de terre qui convient pour une
utilisation dans des systèmes de transport
et de distribution correspondant aux
exigences générales de cette norme, avec
le pouvoir de tenir cinq manoeuvres de
fermeture sur court-circuit

NOTE L'augmentation du nombre de manoeuvres de
fermeture pour la Classe E2 se limite aux tensions
inférieures ou égales à 52 kV qui dépendent
uniquement des conditions de fonctionnement et
des systèmes de protections typiques de tels
réseaux.