

EUROPEAN STANDARD

NORME EUROPÉENNE

EUROPÄISCHE NORM

EN 54-25:2008/AC

March 2012

Mars 2012

März 2012

ICS 13.220.20

English version
Version Française
Deutsche Fassung

Fire detection and fire alarm systems - Part 25: Components using radio links

Systèmes de détection et d'alarme incendie
- Partie 25: Composants utilisant des
liaisons radioélectriques

Brandmeldeanlagen - Teil 25: Bestandteile,
die Hochfrequenz-Verbindungen nutzen

This corrigendum becomes effective on 7 March 2012 for incorporation in the official English version of the EN.

Ce corrigendum prendra effet le 7 mars 2012 pour incorporation dans la version anglaise officielle de la EN.

Die Berichtigung tritt am 7. März 2012 zur Einarbeitung in die offizielle Englische Fassung der EN in Kraft.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

© 2012 CEN All rights of exploitation in any form and by any means reserved worldwide for CEN national Members.
Tous droits d'exploitation sous quelque forme et de quelque manière que ce soit réservés dans le monde entier aux membres nationaux du CEN.
Alle Rechte der Verwertung, gleich in welcher Form und in welchem Verfahren, sind weltweit den nationalen Mitgliedern von CEN vorbehalten.

Ref. No.: EN 54-25:2008/AC:2012 E

Modification from EN 54-25:2008/AC:2010

1 Modification to 5.2.2

Replace the text with the following:

"The component shall be designed such that any non-destructive dismantling is detected and indicated as a fault."

Modification from EN 54-25:2008/AC:2012

2 Modification to 8.3.12.2

Replace second paragraph, after table 10 with the following:

"During the last 0,5h of the conditioning period at the high temperature phase in the last cycle, the transmissions threshold of the specimen shall be determined in accordance with annex A. The threshold value A_{during} shall be recorded".