

Corrigendum to EN 61936-1:2010

English version

---

**Add** the following SNCs in Annex ZA:

<b><u>Clause</u></b>	<b><u>Special national condition</u></b>
----------------------	------------------------------------------

<b>6.2.9.5</b>	<b>Iceland</b>
----------------	----------------

Minimum depth of a buried cable is 0,7 m.

<b>7.2.6</b>	<b>Iceland</b>
--------------	----------------

Minimum height of the external fence is 2 500 mm.

<b>7.7</b>	<b>Iceland</b>
------------	----------------

Minimum height  $H'$  of live parts above accessible surfaces to the general public shall be:  $H' = 5\,500$  mm for rated voltages  $U_m$  up to 52 V.

---

March 2012