



Corrigendum to EN 62271-201:2006

English version

Foreword

Replace the last paragraph by:

Annexes ZA and ZB have been added by CENELEC.

Add Annex ZB (see overleaf):

Annex ZB (informative)

A-deviations

A-deviation: National deviation due to regulations, the alteration of which is for the time being outside the competence of the CENELEC national member.

This European Standard does not fall under any Directive of the EC.

In the relevant CENELEC countries these A-deviations are valid instead of the provisions of the European Standard until they have been removed.

<u>Clause</u>	<u>Deviation</u>
---------------	------------------

General	Sweden (ELSÄK-FS 2004:1)
----------------	---------------------------------

Only switchgear of class PB 2 of this standard is allowed.

1.1	Italy (Italian pressure vessel code for electrical switchgear DM 1 December 1980 and DM 10 September 1981, published in Gazzetta Ufficiale n° 285 dated 16.10.1981).
------------	---

For insulation-enclosed switchgear and controlgear containing gas-filled compartments, the design pressure is limited to a maximum of 0,5 bar (gauge) and the volume is limited to a maximum of 2 m³. Gas filled compartments having a design pressure exceeding 0,5 bar (gauge) or a volume exceeding 2 m³ shall be designed according to Italian pressure vessel code for electrical switchgear
