

Corrigendum to HD 620 S1:1996/A3:2007

English version

Throughout the amendment, for the partial discharge test, **replace** the unit "%" by "pC".

This replacement is to be executed on

<u>Section</u>	<u>Page</u>
5-B-1	12 (2 times), 19 (4 times), 20 (2 times);
5-B-2	11 (2 times), 18 (4 times), 19 (2 times);
5-B-3	12 (2 times), 18 (4 times), 19 (2 times);
5-C	10 (2 times), 16 (3 times), 17;
5-E-1	7, 9;
5-F	10 (2 times), 13;
5-G-2	12, 14;
5-J	11 (2 times), 12 (2 times), 16 (2 times);
5-L	9, 10, 11 (3 times);
5-N	7, 9
5-O-7	8, 10;
5-O-8	8, 11;
6-C	11 (2 times), 15 (3 times), 16;
6-F	10 (2 times), 12;
6-J	13 (2 times), 14 (2 times), 18 (2 times);
6-N	8, 10;
6-O-4	9, 11;
7-E-1	7, 9;
7-N	7, 9;
7-O-5	9, 11;
8-N	8, 10;
9-E	7, 9.
