



INTERNATIONAL STANDARD ISO 5801:2007

TECHNICAL CORRIGENDUM 1

Published 2008-07-01

INTERNATIONAL ORGANIZATION FOR STANDARDIZATION • МЕЖДУНАРОДНАЯ ОРГАНИЗАЦИЯ ПО СТАНДАРТИЗАЦИИ • ORGANISATION INTERNATIONALE DE NORMALISATION

Industrial fans — Performance testing using standardized airways

TECHNICAL CORRIGENDUM 1

Ventilateurs industriels — Essais aérauliques sur circuits normalisés

RECTIFICATIF TECHNIQUE 1

Technical Corrigendum 1 to ISO 5801:2007 was prepared by Technical Committee ISO/TC 117, *Fans*.

Page 76, Figure 19, Note 2

Delete

$$m = 0,009\ 63 - 0,047\ 83d + 0,012\ 86d^2$$

Insert

$$m = - 0,009\ 63 + 0,047\ 83d - 0,012\ 86d^2$$