

TECHNICAL SPECIFICATION  
SPÉCIFICATION TECHNIQUE  
TECHNISCHE SPEZIFIKATION

CLC/TS 50654-2

March 2018

ICS 29.240.01

English Version

HVDC Grid Systems and connected Converter Stations -  
Guideline and Parameter Lists for Functional Specifications -  
Part 2: Parameter Lists

Réseaux CCHT et stations de conversion connectées -  
Lignes directrices et listes de paramètres pour les  
spécifications fonctionnelles - Partie 2: Listes de  
paramètres

Hochspannungsgleichstrom-Netzsysteme - Leitfaden und  
Parameter-Listen für funktionale Spezifikationen - Teil 2:  
Parameter-Listen

This Technical Specification was approved by CENELEC on 2018-01-22.

CENELEC members are required to announce the existence of this TS in the same way as for an EN and to make the TS available promptly at national level in an appropriate form. It is permissible to keep conflicting national standards in force.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

## Contents

	Page
European foreword .....	5
Introduction .....	6
1    Scope .....	7
1.1    General .....	7
1.2    About the present release .....	7
2    Normative references .....	7
3    Terms, definitions and abbreviations .....	8
3.1    Terms and definitions .....	8
3.2    Abbreviations .....	10
4    Coordination of HVDC Grid System and AC Systems .....	11
4.1    Purpose of the HVDC Grid System and Power Network Diagram .....	11
4.2    Hybrid AC/DC Power Flow Optimization .....	12
4.3    Basic Operation Functions – Converter Normal Operation State .....	14
4.3.1    General .....	14
4.3.2    AC System Frequency by a Frequency / Power Droop .....	15
4.3.3    DC Voltage / DC Power Droop .....	15
4.4    Basic Operation Functions – Converter Abnormal Operation State .....	15
4.4.1    General .....	15
4.4.2    Network Conditions and Power Flow Requirements .....	16
4.4.3    Abnormal AC Voltage Conditions .....	16
4.5    Ancillary Services .....	18
4.5.1    General .....	18
4.5.2    Frequency Control Related Services .....	18
4.5.3    AC Voltage Control Related Services .....	20
4.5.4    Power Oscillation Damping Services .....	20
4.5.5    System Restoration Services .....	20
5    HVDC Grid System Characteristics .....	21
5.1    HVDC Circuit Topologies .....	21
5.1.1    Basic Characteristics and Nomenclature .....	21
5.1.2    Attributes of HVDC Grid Systems or HVDC Grid Sub-Systems .....	21
5.1.3    Attributes of a Converter Station .....	21
5.2    Grid Operating States .....	22
5.2.1    Normal State .....	22
5.2.2    Alert State .....	22
5.2.3    Emergency State .....	22
5.2.4    Blackout State .....	23
5.2.5    Restoration .....	23
5.3    DC Voltages .....	23
5.3.1    General .....	23
5.3.2    Nominal DC System Voltage .....	24
5.3.3    Steady-State DC Voltage .....	24
5.3.4    Temporary DC Voltage .....	24
5.4    Insulation Coordination .....	25

5.5	Short-Circuit Characteristics .....	25
5.5.1	General Remarks .....	25
5.5.2	Calculation of Short-Circuit Currents in HVDC Grid Systems.....	25
5.5.3	Short Circuit Current Design Requirements.....	27
5.6	Steady-State Voltage and Current Distortions .....	27
6	HVDC Grid System Control.....	27
6.1	Closed-Loop Control Functions.....	27
6.1.1	General.....	27
6.1.2	Core Control Functions .....	27
6.1.3	Coordinating Control Functions .....	28
6.2	Controller Hierarchy .....	28
6.2.1	General.....	28
6.2.2	Internal Converter Control.....	28
6.2.3	DC Node Voltage Control.....	28
6.2.4	Coordinated System Control.....	28
6.2.5	AC/DC Grid Control!.....	30
6.3	Propagation of Information.....	31
6.4	Open-Loop Controls .....	34
6.4.1	Operating Sequences for Grid Installations .....	34
6.4.2	Operating Sequences for the Return Path.....	35
6.4.3	Recovery .....	35
7	HVDC Grid System Protection .....	36
7.1	General.....	36
7.2	DC Fault Separation.....	36
7.3	Protection System Related Installations and Equipment .....	36
7.3.1	AC/DC Converter Station .....	36
7.3.2	HVDC Grid System Topology and Equipment.....	36
7.4	HVDC Grid System Protection Zones .....	36
7.4.1	General.....	36
7.4.2	Permanent Stop P .....	38
7.4.3	Permanent Stop PQ .....	38
7.4.4	Temporary Stop P .....	39
7.4.5	Temporary Stop PQ .....	39
7.4.6	Continued Operation .....	39
7.4.7	Example of a Protection Zone Matrix .....	39
7.5	DC Protection .....	39
7.5.1	General.....	39
7.5.2	DC Converter Protections .....	40
7.5.3	HVDC Grid System Protections .....	40
7.5.4	HVDC Hub Respective HVDC Node Protections .....	40
7.5.5	DC Grid Protection Communication .....	40
8	AC/DC Converter Stations .....	40
8.1	General.....	40
8.2	AC/DC Converter Station Types .....	40
9	HVDC Grid System Installations .....	40
10	Models and Validation .....	40
10.1	Introduction.....	40
10.2	HVDC Grid System Studies .....	40
10.2.1	Type of Studies .....	40

10.2.2	Tools and Methods.....	41
10.3	Model General Specifications .....	41
10.3.1	Model Capability.....	41
10.3.2	Model Format and Data Type .....	41
10.3.3	Model Aggregation .....	41
10.4	Model Specific Recommendations.....	42
10.4.1	Load Flow Models .....	42
10.4.2	Short-Circuit Models.....	42
10.4.3	Protection System Models .....	42
10.4.4	Insulation Coordination Related Models .....	42
10.4.5	Electromechanical Transient Models .....	43
10.4.6	Electromagnetic Transient Models.....	44
10.4.7	Power Quality Models .....	49
10.5	Model Validation.....	50
10.6	Compliance Simulation .....	51
10.7	Outputs/Results .....	51
10.7.1	Model Data.....	51
10.7.2	Model Documentation .....	51
10.7.3	Model Example .....	51
10.7.4	Model Compliance Documentation .....	51
10.7.5	Model Validation Documentation – Model Final Version .....	51
10.7.6	Model Guarantee .....	51
11	HVDC Grid System Integration Tests .....	51
	Bibliography .....	52

## European foreword

This document (CLC/TS 50654-2:2018) has been prepared by CLC/TC8X/WG 06 "System Aspects of HVDC Grid".

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

## Introduction

HVDC Grid Systems are a new field of technology. There are very few systems with a small number of converter stations in operation; some more are in execution or in detailed planning.

The Guidelines and Parameter Lists to Functional Specifications are presented featuring planning, specification and execution of multi-vendor HVDC Grid Systems in Europe. Being elaborated by a team of experts from leading manufacturers of HVDC technology, Transmission System Operators (TSO's), Academia and Institutions in Europe, the present document provides a commonly agreed basis for an open market of compatible equipment and solutions for HVDC Grid Systems. Executing such systems and gaining operational experience is seen an important prerequisite for developing corresponding technical standards in the future.

By elaborating this document, special care has been taken to as far as possible describe the requirements in a technologically independent way. In order to achieve that, a function of interest is described by a comprehensive set of parameters. The parameters are selected based on a systematic analysis of physical phenomena relevant to achieve the requested functionality. The physical phenomena are categorized in order to show the mutual dependence of the individual parameters and ensure completeness of the physical aspects to be considered. Based on a clearly defined common language describing the functionalities requested, existing technologies can be applied or new dedicated technical solutions can be developed.

Reflecting the early stage of technology, these Guidelines and Parameter Lists to Functional Specifications need comprehensive explanations and background information for the technical parameters. This dual character of the content will be represented by two corresponding parts:

- Part I "Guidelines" containing the explanations and the background information in context with the Parameter Lists.
- Part II "Parameter Lists" containing the essential lists of parameters and values describing properties of the a.c. respectively d.c. system (operating conditions) and parameters describing the performance of the newly installed component (performance requirements).

## 1 Scope

### 1.1 General

These Guidelines and Parameter Lists to Functional Specifications describe specific functional requirements for HVDC Grid Systems. The terminology "HVDC Grid Systems" is used here describing HVDC systems for power transmission having more than two converter stations connected to a common d.c. circuit.

While this document focuses on requirements, that are specific for HVDC Grid Systems, some requirements are considered applicable to all HVDC systems in general, i.e. including point-to-point HVDC systems. Existing IEC, Cigré or other documents relevant have been used for reference as far as possible.

Corresponding to electric power transmission applications, this document is applicable to high voltage systems, i.e. only nominal d.c. voltages equal or higher than 50 kV with respect to earth are considered in this document.

**NOTE** While the physical principles of d.c. networks are basically voltage independent, the technical options for designing equipment get much wider with lower d.c. voltage levels, e.g. in case of converters or switchgear.

Both parts have the same outline and headlines to aid the reader.

### 1.2 About the present release

The present release of the Guidelines and Parameter Lists for Functional Specifications describes technical guidelines and specifications for HVDC Grid Systems which are characterized by having exactly one single connection between two converter stations, often referred to as radial systems. When developing the requirements for radial systems, care is taken not to build up potential show-stoppers for meshed systems. Meshed HVDC Grid Systems can be included into this specification at a later point in time.

The Guidelines and Parameter List to the Functional Specification of HVDC Grid Systems cover technical aspects of

- Coordination of HVDC Grid and a.c. Systems
- HVDC Grid System Characteristics
- HVDC Grid System Control
- HVDC Grid System Protection
- Models and Validation
- Beyond the present scope, the following aspects are proposed for future work:
- AC/DC converter stations
- HVDC Grid System Equipment
- HVDC Grid System Integration Tests

## 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 62747:2014, *Terminology for voltage-sourced converters (VSC) for high-voltage direct current (HVDC) systems (IEC 62747:2014)*

EN 61660-1:1997, *Short-circuit currents in d.c. auxiliary installations in power plants and substations — Part 1: Calculation of short-circuit currents (IEC 61660-1:1997)*

### 3 Terms, definitions and abbreviations

#### 3.1 Terms and definitions

For the purposes of this document, the following terms and definitions apply. ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

##### 3.1.1

##### **AC/DC converter unit**

indivisible operative unit comprising all equipment between the point of connection on the a.c. side and the point of connection on the d.c. side, essentially one or more converters, together with converter transformers, control equipment, essential protective and switching devices and auxiliaries, if any, used for conversion

[SOURCE: EN 62747:2014, modified – The definition was neutralised with respect to technology (not only VSC converters) and uses the terms PoC as defined in the present document]

##### 3.1.2

##### **AC/DC converter station**

part of an HVDC system which consists of one or more AC/DC converter units including d.c. switchgear, d.c. fault current controlling devices, if any, installed in a single location together with buildings, reactors, filters, reactive power supply, control, monitoring, protective, measuring and auxiliary equipment

[SOURCE: EN 62747:2014, modified – The definition was made specific with respect to AC/DC converter units, differentiating from DC/DC converter units. Furthermore, only the term AC/DC converter station is used in the present document]

##### 3.1.3

##### **Point of connection-DC (PoC-DC)**

electrical interface point at d.c. voltage