

**Short-circuit currents in three-phase a.c systems --
Part 3: Currents during two separate simultaneous line-
to-earth short-circuits and partial short-circuit currents
flowing through earth**

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

Käesolev Eesti standard EVS-EN 60909-3:2010 sisaldab Euroopa standardi EN 60909-3:2010 ingliskeelset teksti.

Standard on kinnitatud Eesti Standardikeskuse 30.04.2010 käskkirjaga ja jõustub sellekohase teate avaldamisel EVS Teatajas.

Euroopa standardimisorganisatsioonide poolt rahvuslikele liikmetele Euroopa standardi teksti kättesaadavaks tegemise kuupäev on 12.03.2010.

Standard on kättesaadav Eesti standardiorganisatsioonist.

This Estonian standard EVS-EN 60909-3:2010 consists of the English text of the European standard EN 60909-3:2010.

This standard is ratified with the order of Estonian Centre for Standardisation dated 30.04.2010 and is endorsed with the notification published in the official bulletin of the Estonian national standardisation organisation.

Date of Availability of the European standard text 12.03.2010.

The standard is available from Estonian standardisation organisation.

ICS 17.220.01, 29.240.20

Standardite reprodutseerimis- ja levitamiseõigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonilisse süsteemi või edastamine ükskõik millises vormis või millisel teel on keelatud ilma Eesti Standardikeskuse poolt antud kirjaliku loata.

Kui Teil on küsimusi standardite autorikaitse kohta, palun võtke ühendust Eesti Standardikeskusega:
Aru 10 Tallinn 10317 Eesti; www.evs.ee; Telefon: 605 5050; E-post: info@evs.ee

Right to reproduce and distribute Estonian Standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without permission in writing from Estonian Centre for Standardisation.

If you have any questions about standards copyright, please contact Estonian Centre for Standardisation:
Aru str 10 Tallinn 10317 Estonia; www.evs.ee; Phone: +372 605 5050; E-mail: info@evs.ee

**Short-circuit currents in three-phase a.c systems -
Part 3: Currents during two separate simultaneous line-to-earth
short-circuits and partial short-circuit currents flowing through earth
(IEC 60909-3:2009)**

Courants de court-circuit dans les réseaux triphasés à courant alternatif -
Partie 3: Courants durant deux courts-circuits monophasés simultanés séparés à la terre et courants de court-circuit partiels s'écoulant à travers la terre
(CEI 60909-3:2009)

Kurzschlussströme in Drehstromnetzen -
Teil 3: Ströme bei Doppelerdkurzschluss und Teilkurzschlussströme über Erde
(IEC 60909-3:2009)

This European Standard was approved by CENELEC on 2010-03-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 73/148/FDIS, future edition 3 of IEC 60909-3, prepared by IEC TC 73, Short-circuit currents, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 60909-3 on 2010-03-01.

This standard is to be used in conjunction with EN 60909-0:2001.

This European Standard supersedes EN 60909-3:2003.

The main changes with respect to EN 60909-3:2003 are listed below:

- New procedures are introduced for the calculation of reduction factors of the sheaths or shields and in addition the current distribution through earth and the sheaths or shields of three-core cables or of three single-core cables with metallic non-magnetic sheaths or shields earthed at both ends;
- The information for the calculation of the reduction factor of overhead lines with earth wires are corrected and given in the new Clause 7;
- A new Clause 8 is introduced for the calculation of current distribution and reduction factor of three-core cables with metallic sheath or shield earthed at both ends;
- The new Annexes C and D provide examples for the calculation of reduction factors and current distribution in case of cables with metallic sheath and shield earthed at both ends.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN and CENELEC shall not be held responsible for identifying any or all such patent rights.

The following dates were fixed:

- latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2010-12-01
- latest date by which the national standards conflicting with the EN have to be withdrawn (dow) 2013-03-01

Annex ZA has been added by CENELEC.

Endorsement notice

The text of the International Standard IEC 60909-3:2009 was approved by CENELEC as a European Standard without any modification.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60909-0	2001	Short-circuit currents in three-phase a.c. systems - Part 0: Calculation of currents	EN 60909-0	2001
IEC/TR 60909-2	2008	Short-circuit currents in three-phase a.c. systems - Part 2: Data of electrical equipment for short-circuit current calculations	-	-

CONTENTS

FOREWORD.....	5
1 Scope and object.....	7
2 Normative references	8
3 Terms and definitions	8
4 Symbols	10
5 Calculation of currents during two separate simultaneous line-to-earth short circuits	12
5.1 Initial symmetrical short-circuit current	12
5.1.1 Determination of $\underline{M}_{(1)}$ and $\underline{M}_{(2)}$	12
5.1.2 Simple cases of two separate simultaneous line-to-earth short circuits.....	13
5.2 Peak short-circuit current, symmetrical short circuit breaking current and steady-state short-circuit current	13
5.3 Distribution of the currents during two separate simultaneous line-to-earth short circuits.....	14
6 Calculation of partial short-circuit currents flowing through earth in case of an unbalanced short circuit.....	14
6.1 General.....	14
6.2 Line-to-earth short circuit inside a station	15
6.3 Line-to-earth short circuit outside a station	16
6.4 Line-to-earth short circuit in the vicinity of a station	18
6.4.1 Earth potential \underline{U}_{ETn} at the tower n outside station B	19
6.4.2 Earth potential of station B during a line-to earth short circuit at the tower n	19
7 Reduction factor for overhead lines with earth wires	20
8 Calculation of current distribution and reduction factor in case of cables with metallic sheath or shield earthed at both ends	21
8.1 Overview	21
8.2 Three-core cable	22
8.2.1 Line-to-earth short circuit in station B	22
8.2.2 Line-to-earth short circuit on the cable between station A and station B	23
8.3 Three single-core cables	26
8.3.1 Line-to-earth short circuit in station B	26
8.3.2 Line-to-earth short circuit on the cable between station A and station B	26
Annex A (informative) Example for the calculation of two separate simultaneous line-to-earth short-circuit currents.....	30
Annex B (informative) Examples for the calculation of partial short-circuit currents through earth	33
Annex C (informative) Example for the calculation of the reduction factor r_1 and the current distribution through earth in case of a three-core cable	43
Annex D (informative) Example for the calculation of the reduction factor r_3 and the current distribution through earth in case of three single-core cables	48

Figure 1 – Driving point impedance \underline{Z}_P of an infinite chain, composed of the earth wire impedance $\underline{Z}_Q = \underline{Z}'_Q d_T$ and the footing resistance R_T of the towers, with equal distances d_T between the towers	9
Figure 2 – Driving point impedance \underline{Z}_{Pn} of a finite chain with n towers, composed of the earth wire impedance $\underline{Z}_Q = \underline{Z}'_Q d_T$, the footing resistance R_T of the towers, with equal distances d_T between the towers and the earthing impedance \underline{Z}_{EB} of station B from Equation (29)	10
Figure 3 – Characterisation of two separate simultaneous line-to earth short circuits and the currents I_{KEE}	12
Figure 4 – Partial short-circuit currents in case of a line-to-earth short circuit inside station B	15
Figure 5 – Partial short-circuit currents in case of a line-to-earth short circuit at a tower T of an overhead line	16
Figure 6 – Distribution of the total current to earth I_{ETot}	17
Figure 7 – Partial short-circuit currents in the case of a line-to-earth short circuit at a tower n of an overhead line in the vicinity of station B	18
Figure 8 – Reduction factor r for overhead lines with non-magnetic earth wires depending on soil resistivity ρ	21
Figure 9 – Reduction factor of three-core power cables	23
Figure 10 – Reduction factors for three single-core power cables	27
Figure A.1 – Two separate simultaneous line-to-earth short circuits on a single fed overhead line (see Table 1)	30
Figure B.1 – Line-to-earth short circuit inside station B – System diagram for stations A, B and C	34
Figure B.2 – Line-to-earth short circuit inside station B – Positive-, negative- and zero-sequence systems with connections at the short-circuit location F within station B	34
Figure B.3 – Line-to-earth short circuit outside stations B and C at the tower T of an overhead line – System diagram for stations A, B and C	36
Figure B.4 – Line-to-earth short circuit outside stations B and C at the tower T of an overhead line – Positive-, negative- and zero-sequence systems with connections at the short-circuit location F	37
Figure B.5 – Earth potentials $u_{ETn} = U_{ETn}/U_{ET}$ with $U_{ET} = 1,912$ kV and $u_{EBn} = U_{EBn}/U_{EB}$ with $U_{EB} = 0,972$ kV, if the line-to-earth short circuit occurs at the towers $n = 1, 2, 3, \dots$ in the vicinity of station B	42
Figure C.1 – Example for the calculation of the cable reduction factor and the current distribution through earth in a 10-kV-network, $U_n = 10$ kV; $c = 1,1$; $f = 50$ Hz	44
Figure C.2 – Short-circuit currents and partial short-circuit currents through earth for the example in Figure C.1	45
Figure C.3 – Example for the calculation of current distribution in a 10-kV-network with a short circuit on the cable between A and B (data given in C.2.1 and Figure C.1)	46
Figure C.4 – Line-to-earth short-circuit currents, partial currents in the shield and partial currents through earth	47
Figure D.1 – Example for the calculation of the reduction factor and the current distribution in case of three single-core cables and a line-to-earth short circuit in station B	49
Figure D.2 – Positive-, negative- and zero-sequence system of the network in Figure D.1 with connections at the short-circuit location (station B)	50
Figure D.3 – Current distribution for the network in Figure D.1, depending on the length, ℓ , of the single-core cables between the stations A and B	51

Figure D.4 – Example for the calculation of the reduction factors r_3 and the current distribution in case of three single-core cables and a line-to-earth short circuit between the stations A and B	52
Figure D.5 – Positive-, negative- and zero-sequence system of the network in Figure D.4 with connections at the short-circuit location (anywhere between the stations A and B)	52
Figure D.6 – Current distribution for the cable in Figure D.4 depending on ℓ_A , $R_{EF} \rightarrow \infty$	54
Figure D.7 – Current distribution for the cable in Figure D.4 depending on ℓ_A , $R_{EF} = 5 \Omega$	56
Table 1 – Calculation of initial line-to-earth short-circuit currents in simple cases	13
Table 2 – Resistivity of the soil and equivalent earth penetration depth	20
Table C.1 – Results for the example in Figure C.1	45
Table C.2 – Results for the example in Figure C.3, $\ell = 5 \text{ km}$	47
Table C.3 – Results for the example in Figure C.3, $\ell = 10 \text{ km}$	47

SHORT-CIRCUIT CURRENTS IN THREE-PHASE AC SYSTEMS –

Part 3: Currents during two separate simultaneous line-to-earth short circuits and partial short-circuit currents flowing through earth

1 Scope and object

This part of IEC 60909 specifies procedures for calculation of the prospective short-circuit currents with an unbalanced short circuit in high-voltage three-phase a.c. systems operating at nominal frequency 50 Hz or 60 Hz, i. e.:

- a) currents during two separate simultaneous line-to-earth short circuits in isolated neutral or resonant earthed neutral systems;
- b) partial short-circuit currents flowing through earth in case of single line-to-earth short circuit in solidly earthed or low-impedance earthed neutral systems.

The currents calculated by these procedures are used when determining induced voltages or touch or step voltages and rise of earth potential at a station (power station or substation) and the towers of overhead lines.

Procedures are given for the calculation of reduction factors of overhead lines with one or two earth wires.

The standard does not cover:

- a) short-circuit currents deliberately created under controlled conditions as in short circuit testing stations, or
- b) short-circuit currents in the electrical installations on board ships or aeroplanes, or
- c) single line-to-earth fault currents in isolated or resonant earthed systems.

The object of this standard is to establish practical and concise procedures for the calculation of line-to-earth short-circuit currents during two separate simultaneous line-to-earth short circuits and partial short-circuit currents through earth, earth wires of overhead lines and sheaths or shields of cables leading to conservative results with sufficient accuracy. For this purpose, the short-circuit currents are determined by considering an equivalent voltage source at the short-circuit location with all other voltage sources set to zero. Resistances of earth grids in stations or footing resistances of overhead line towers are neglected, when calculating the short-circuit currents at the short-circuit location.

This standard is an addition to IEC 60909-0. General definitions, symbols and calculation assumptions refer to that publication. Special items only are defined or specified in this standard.

The calculation of the short-circuit currents based on the rated data of the electrical equipment and the topological arrangement of the system has the advantage of being possible both for existing systems and for systems at the planning stage. The procedure is suitable for determination by manual methods or digital computation. This does not exclude the use of special methods, for example the super-position method, adjusted to particular circumstances, if they give at least the same precision.

As stated in IEC 60909-0, short-circuit currents and their parameters may also be determined by system tests.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60909-0:2001, *Short-circuit currents in three-phase a.c. systems – Part 0: Calculation of currents*

IEC/TR 60909-2:2008, *Short-circuit currents in three-phase a.c. systems – Part 2: Data of electrical equipment for short-circuit current calculations*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

two separate simultaneous line-to earth short circuits

line-to-earth short circuits at different locations at the same time on different conductors of a three-phase a.c. network having a resonant earthed or an isolated neutral

3.2

initial short-circuit currents during two separate simultaneous line-to-earth

short circuits I_{KEE}''

r.m.s value of the initial short-circuit currents flowing at both short-circuit locations with the same magnitude

3.3

partial short-circuit current through earth $I_{\text{E}\delta}$

r.m.s. value of the current flowing through earth in a fictive line in the equivalent earth penetration depth δ

NOTE In case of overhead lines remote from the short-circuit location and the earthing system of a station, where the distribution of the current between earthed conductors and earth is nearly constant, the current through earth depends on the reduction factor of the overhead line (Figures 4 and 5). In case of cables with metallic sheaths or shields, earthed at both ends in the stations A and B, current through earth between the stations A and B (Figures 9a) and 10a)), respectively between the short-circuit location and the stations A or B (Figures 9b) and 10b)).

3.4

total current to earth I_{ETot} at the short-circuit location on the tower T of an overhead line

r. m. s. value of the current flowing to earth through the footing resistance of an overhead line tower far away from a station connected with the driving point impedances of the overhead line at both sides, see Figure 5

3.5

total current to earth I_{EBtot} at the short-circuit location in the station B

r.m.s. value of the current flowing to earth through the earthing system of a station B (power station or substation) with connected earthed conductors (earth wires of overhead lines or sheaths or shields or armouring of cables or other earthed conductors as for instance metallic water pipes), see Figure 4

3.6

current to earth $I_{\text{ET}n}$

r.m.s. value of the current flowing to earth causing the potential rise at an overhead line tower n in the vicinity of a station