

**Madalpingelised lülitus- ja juhtimisaparaadid. Osa 4-1:
Kontaktorid ja mootorikäivitid. Elektromehaanilised
kontaktorid ja mootorikäivitid**

Low-voltage switchgear and controlgear - Part 4-1:
Contactors and motor-starters - Electromechanical
contactors and motor-starters

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

Käesolev Eesti standard EVS-EN 60947-4-1:2010 sisaldab Euroopa standardi EN 60947-4-1:2010 ingliskeelset teksti.

Standard on kinnitatud Eesti Standardikeskuse 31.05.2010 käskkirjaga ja jõustub sellekohase teate avaldamisel EVS Teatajas.

Euroopa standardimisorganisatsioonide poolt rahvuslikele liikmetele Euroopa standardi teksti kättesaadavaks tegemise kuupäev on 09.04.2010.

Standard on kättesaadav Eesti standardiorganisatsioonist.

This Estonian standard EVS-EN 60947-4-1:2010 consists of the English text of the European standard EN 60947-4-1:2010.

This standard is ratified with the order of Estonian Centre for Standardisation dated 31.05.2010 and is endorsed with the notification published in the official bulletin of the Estonian national standardisation organisation.

Date of Availability of the European standard text 09.04.2010.

The standard is available from Estonian standardisation organisation.

ICS 29.120.99, 29.130.20

Standardite reprodutseerimis- ja levitamiseõigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonilisse süsteemi või edastamine ükskõik millises vormis või millisel teel on keelatud ilma Eesti Standardikeskuse poolt antud kirjaliku loata.

Kui Teil on küsimusi standardite autorikaitse kohta, palun võtke ühendust Eesti Standardikeskusega:
Aru 10 Tallinn 10317 Eesti; www.evs.ee; Telefon: 605 5050; E-post: info@evs.ee

Right to reproduce and distribute Estonian Standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without permission in writing from Estonian Centre for Standardisation.

If you have any questions about standards copyright, please contact Estonian Centre for Standardisation:
Aru str 10 Tallinn 10317 Estonia; www.evs.ee; Phone: +372 605 5050; E-mail: info@evs.ee

**Low-voltage switchgear and controlgear -
Part 4-1: Contactors and motor-starters -
Electromechanical contactors and motor-starters
(IEC 60947-4-1:2009)**

Appareillage à basse tension -
Partie 4-1: Contacteurs et démarreurs
de moteurs -
Contacteurs et démarreurs
électromécaniques
(CEI 60947-4-1:2009)

Niederspannungsschaltgeräte -
Teil 4-1: Schütze und Motorstarter -
Elektromechanische Schütze
und Motorstarter
(IEC 60947-4-1:2009)

This European Standard was approved by CENELEC on 2010-04-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 17B/1674/FDIS, future edition 3 of IEC 60947-4-1, prepared by SC 17B, Low-voltage switchgear and controlgear, of IEC TC 17, Switchgear and controlgear, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 60947-4-1 on 2010-04-01.

This standard is to be used in conjunction with EN 60947-1.

This European Standard supersedes EN 60947-4-1:2001 + A1:2002 + A2:2005.

This EN 60947-4-1 includes the following significant technical changes with respect to the EN 60947-4-1:2001 + A1:2002 + A2:2005:

- deletion of the test at $-5\text{ }^{\circ}\text{C}$ and $+20\text{ }^{\circ}\text{C}$ for thermal overload relays that are not compensated for ambient air temperature;
- addition of conditions on the tests according to Annex Q of EN 60947-1;
- EMC tests: clarification of acceptance criteria and alignment with EN 60947-1 for fast transient severity level;
- Annex B, test for Icd: modification of the duration of the dielectric test voltage from 5 s to 60 s;
- Annex B, electrical durability: improvement of the statistical aspects;
- Annex H: clarification and introduction of new extended functions within electronic overload relays;
- Annex K, procedure to determine data for electromechanical contactors used in functional safety applications: creation of this new annex.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN and CENELEC shall not be held responsible for identifying any or all such patent rights.

The following dates were fixed:

- latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2011-01-01
- latest date by which the national standards conflicting with the EN have to be withdrawn (dow) 2013-04-01

This European Standard has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association and covers essential requirements of EC Directive 2004/108/EC. See Annex ZZ.

Annexes ZA and ZZ have been added by CENELEC.

Endorsement notice

The text of the International Standard IEC 60947-4-1:2009 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60068-2-2:2007	NOTE	Harmonized as EN 60068-2-2:2007 (not modified).
IEC 60076-1:1993	NOTE	Harmonized as EN 60076-1:1997 (modified).
IEC 60269-1:2006	NOTE	Harmonized as EN 60269-1:2007 (not modified).
IEC 60269-2:2006	NOTE	Harmonized as EN 60269-2:2007 (modified).
IEC 60664-1:2007	NOTE	Harmonized as EN 60664-1:2007 (not modified).
IEC 61095:2009	NOTE	Harmonized as EN 61095:2009 (not modified).

This document is a preview generated by EVS

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60034-1	2004	Rotating electrical machines - Part 1: Rating and performance	EN 60034-1	2004
IEC 60085	2007	Electrical insulation - Thermal evaluation and designation	EN 60085	2008
IEC 60300-3-5	2001	Dependability management - Part 3-5: Application guide - Reliability test conditions and statistical test principles	-	-
IEC 60410	1973	Sampling plans and procedures for inspection - by attributes	-	-
IEC 60947-1	2007	Low-voltage switchgear and controlgear - Part 1: General rules	EN 60947-1	2007
IEC 60947-2	2006	Low-voltage switchgear and controlgear - Part 2: Circuit-breakers	EN 60947-2	2006
IEC 60947-3	2008	Low-voltage switchgear and controlgear - Part 3: Switches, disconnectors, switch- disconnectors and fuse-combination units	EN 60947-3	2009
IEC 60947-5-1	2003	Low-voltage switchgear and controlgear - Part 5-1: Control circuit devices and switching elements - Electromechanical control circuit devices	EN 60947-5-1 + corr. July 2005	2004 2005
IEC 61000-4-2	2008	Electromagnetic compatibility (EMC) - Part 4-2: Testing and measurement techniques - Electrostatic discharge immunity test	EN 61000-4-2	2009
IEC 61000-4-3	2006	Electromagnetic compatibility (EMC) - Part 4-3: Testing and measurement techniques - Radiated, radio-frequency, electromagnetic field immunity test	EN 61000-4-3	2006
IEC 61000-4-4	2004	Electromagnetic compatibility (EMC) - Part 4-4: Testing and measurement techniques - Electrical fast transient/burst immunity test	EN 61000-4-4	2004
IEC 61000-4-5	2005	Electromagnetic compatibility (EMC) - Part 4-5: Testing and measurement techniques - Surge immunity test	EN 61000-4-5	2006

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61000-4-6	2008	Electromagnetic compatibility (EMC) - Part 4-6: Testing and measurement techniques - Immunity to conducted disturbances, induced by radio-frequency fields	EN 61000-4-6	2009
IEC 61439-1 (mod)	2009	Low-voltage switchgear and controlgear assemblies - Part 1: General rules	EN 61439-1	2009
IEC 61508	Series	Functional safety of electrical/electronic/programmable electronic safety-related systems	EN 61508	Series
IEC 61511	Series	Functional safety - Safety instrumented systems for the process industry sector	EN 61511	Series
IEC 61513	2001	Nuclear power plants - Instrumentation and control for systems important to safety - General requirements for systems	-	-
IEC 61649	2008	Weibull analysis	EN 61649	2008
IEC 61810-1	2008	Electromechanical elementary relays - Part 1: General requirements	EN 61810-1	2008
IEC 62061	2005	Safety of machinery - Functional safety of safety-related electrical, electronic and programmable electronic control systems	EN 62061	2005
CISPR 11 (mod)	2003	Industrial scientific and medical (ISM) radio-frequency equipment - Electromagnetic disturbance characteristics - Limits and methods of measurement	EN 55011	2007
+ A1	2004		-	-
+ A2	2006		+ A2 ^{1) 2)}	2007
ISO 13849-1	2006	Safety of machinery - Safety-related parts of control systems - Part 1: General principles for design	-	-

¹⁾ EN 55011 includes A1 to CISPR 11 (mod).

²⁾ EN 55011 is superseded by prEN 55011(fragment 1), which is based on CISPR 11:200X (fragment 1)(CISPR/B/440/CDV).

Annex ZZ (informative)

Coverage of Essential Requirements of EC Directives

This European Standard has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association and within its scope the standard covers all relevant essential requirements as given in Article 1 of Annex I of the Directive 2004/108/EC.

Compliance with this standard provides one means of conformity with the specified essential requirements of the Directives concerned.

WARNING: Other requirements and other EC Directives may be applicable to the products falling within the scope of this standard.

This document is a preview generated by EVS

CONTENTS

FOREWORD.....	6
1 Scope and object.....	8
1.1 Scope.....	8
1.1.1 AC and DC contactors	8
1.1.2 AC motor-starters	8
1.2 Exclusions.....	10
1.3 Object.....	10
2 Normative references	11
3 Terms, definitions, symbols and abbreviations.....	12
3.1 General.....	12
3.2 Alphabetical index of terms	12
3.3 Terms and definitions concerning contactors	13
3.4 Terms and definitions concerning starters	15
3.5 Terms and definitions concerning characteristic quantities	19
3.6 Symbols and abbreviations.....	19
4 Classification.....	20
5 Characteristics of contactors and starters.....	20
5.1 Summary of characteristics	20
5.2 Type of equipment.....	20
5.2.1 Kind of equipment.....	20
5.2.2 Number of poles	20
5.2.3 Kind of current (a.c. or d.c.).....	20
5.2.4 Interrupting medium (air, oil, gas, vacuum, etc.)	20
5.2.5 Operating conditions of the equipment.....	20
5.3 Rated and limiting values for main circuits.....	21
5.3.1 Rated voltages	21
5.3.2 Currents or powers	22
5.3.3 Rated frequency	24
5.3.4 Rated duties	24
5.3.5 Normal load and overload characteristics	25
5.3.6 Rated conditional short-circuit current	27
5.4 Utilization category.....	27
5.4.1 General	27
5.4.2 Assignment of utilization categories based on the results of tests	27
5.5 Control circuits	29
5.6 Auxiliary circuits	30
5.7 Characteristics of relays and releases (overload relays).....	30
5.7.1 Summary of characteristics.....	30
5.7.2 Types of relay or release	30
5.7.3 Characteristic values	30
5.7.4 Designation and current settings of overload relays.....	32
5.7.5 Time-current characteristics of overload relays.....	32
5.7.6 Influence of ambient air temperature	33
5.8 Co-ordination with short-circuit protective devices	33
5.9 Void	33

5.10	Types and characteristics of automatic change-over devices and automatic acceleration control devices	33
5.10.1	Types	33
5.10.2	Characteristics	33
5.11	Types and characteristics of auto-transformers for two-step auto-transformer starters	34
5.12	Types and characteristics of starting resistors for rheostatic rotor starters	34
6	Product information	34
6.1	Nature of information	34
6.1.1	Identification	34
6.1.2	Characteristics, basic rated values and utilization	35
6.2	Marking	36
6.3	Instructions for installation, operation and maintenance	36
7	Normal service, mounting and transport conditions	37
8	Constructional and performance requirements	37
8.1	Constructional requirements	37
8.1.1	General	37
8.1.2	Materials	37
8.1.3	Current-carrying parts and their connections	37
8.1.4	Clearances and creepage distances	37
8.1.5	Actuator	37
8.1.6	Indication of the contact position	38
8.1.7	Additional requirements for equipment suitable for isolation	38
8.1.8	Terminals	38
8.1.9	Additional requirements for equipment provided with a neutral pole	38
8.1.10	Provisions for protective earthing	38
8.1.11	Enclosures for equipment	38
8.1.12	Degrees of protection of enclosed equipment	38
8.1.13	Conduit pull-out, torque and bending with metallic conduits	39
8.2	Performance requirements	39
8.2.1	Operating conditions	39
8.2.2	Temperature rise	44
8.2.3	Dielectric properties	46
8.2.4	Normal load and overload performance requirements	46
8.2.5	Co-ordination with short-circuit protective devices	51
8.2.6	Void	52
8.2.7	Additional requirements for combination starters and combination switching devices suitable for isolation	52
8.3	Electromagnetic compatibility (EMC)	52
8.3.1	General	52
8.3.2	Immunity	52
8.3.3	Emission	53
9	Tests	53
9.1	Kinds of test	53
9.1.1	General	53
9.1.2	Type tests	54
9.1.3	Routine tests	54
9.1.4	Sampling tests	54
9.1.5	Special tests	55

9.2	Compliance with constructional requirements	55
9.3	Compliance with performance requirements	55
9.3.1	Test sequences	55
9.3.2	General test conditions	56
9.3.3	Performance under no load, normal load and overload conditions	56
9.3.4	Performance under short-circuit conditions	64
9.3.5	Overload current withstand capability of contactors	69
9.3.6	Routine tests and sampling tests	69
9.4	EMC tests	70
9.4.1	General	70
9.4.2	Immunity	70
9.4.3	Emission	71
Annex A	(normative) Marking and identification of terminals of contactors and associated overload relays	81
Annex B	(normative) Special tests	85
Annex C	Void	93
Annex D	(informative) Items subject to agreement between manufacturer and user	94
Annex E	(informative) Examples of control circuit configurations	95
Annex F	(normative) Requirements for auxiliary contact linked with power contact (mirror contact)	98
Annex G	(informative) Rated operational currents and rated operational powers of switching devices for electrical motors	101
Annex H	(normative) Extended functions within electronic overload relays	105
Annex I	(informative) AC1 contactors for use with semiconductor controlled motor loads	111
Annex J	Void	112
Annex K	(normative) Procedure to determine data for electromechanical contactors used in functional safety applications	113
Bibliography	122
Figure 1	– Typical curves of currents and torques during a star-delta start (see 1.1.2.2.1)	73
Figure 2	– Typical curves of currents and torques during an auto-transformer start (see 1.1.2.2.2)	74
Figure 3	– Typical variants of protected starters, combination starters, protected switching devices and combination switching devices	75
Figure 4	– Example of three-phase diagram of a rheostatic rotor starter with three starting steps and one direction of rotation (in the case when all the mechanical switching devices are contactors)	76
Figure 5	– Typical methods and diagrams of starting alternating-current induction motors by means of auto-transformers	77
Figure 6	– Examples of speed/time curves corresponding to cases a), b), c), d), e) and f) of 5.3.5.5 (the dotted parts of the curves correspond to the periods when no current flows through the motor)	78
Figure 7	– Multiple of current setting limits for ambient air temperature compensated time-delay overload relays (see 8.2.1.5.1)	79
Figure 8	– Thermal memory test	80
Figure B.1	– Examples of time-current withstand characteristic	92

Figure F.1 – Mirror contact.....	99
Figure H.1 – Test circuit for the verification of the operating characteristic of a ground/earth fault relay	110
Figure K.1 – Plot of Weibull median rank regression	121
Table 1 – Utilization categories	29
Table 2 – Trip classes of overload relays	32
Table 3 – Limits of operation of time-delay overload relays when energized on all poles.....	42
Table 4 – Limits of operation of three-pole time-delay overload relays when energized on two poles only	43
Table 5 – Temperature rise limits for insulated coils in air and in oil.....	44
Table 6 – Intermittent duty test cycle data.....	45
Table 7 – Making and breaking capacities – Making and breaking conditions according to utilization category.....	47
Table 8 – Relationship between current broken I_C and off-time for the verification of rated making and breaking capacities	48
Table 9 – Operational current determination for utilization categories AC-6a and AC-6b when derived from AC-3 ratings	49
Table 10 – Conventional operational performance – Making and breaking conditions according to utilization category.....	50
Table 11 – Overload current withstand requirements	51
Table 12 – Specific acceptance criteria for immunity tests	53
Table 13 – Value of the prospective test current according to the rated operational current.....	66
Table 14 – EMC immunity tests.....	70
Table 15 – Conducted radio-frequency emission test limits	72
Table 16 – Radiated emission test limits	72
Table B.1 – Verification of the number of on-load operating cycles – Conditions for making and breaking corresponding to the several utilization categories.....	88
Table B.2 – Test conditions	91
Table F.1 – Test voltage according to altitude.....	99
Table G.1 – Rated operational powers and rated operational currents of motors	102
Table H.1 – Operating time of ground/earth fault relays	107
Table K.1 – Failure mode of contactors.....	115
Table K.2 – Typical failure ratios for normally open contactors.....	119
Table K.3 – Example of 15 sorted ascending times to failure of contactors	120

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 4-1: Contactors and motor-starters – Electromechanical contactors and motor-starters

1 Scope and object

1.1 Scope

This part of IEC 60947 applies to the types of equipment listed in 1.1.1 and 1.1.2 whose main contacts are intended to be connected to circuits the rated voltage of which does not exceed 1 000 V a.c. or 1 500 V d.c.

Starters and/or contactors dealt with in this standard are not normally designed to interrupt short-circuit currents. Therefore, suitable short-circuit protection (see 9.3.4) forms part of the installation but not necessarily of the contactor or the starter.

In this context, this standard gives requirements for:

- contactors associated with overload and/or short-circuit protective devices;
- starters associated with separate short-circuit protective devices and/or with separate short-circuit and integrated overload protective devices;
- contactors or starters combined, under specified conditions, with their own short-circuit protective devices. Such combinations, e.g. combination starters or protected starters are rated as units.

For circuit-breakers and fuse-combination units used as short-circuit protective devices in combination starters and in protected starters, the requirements of IEC 60947-2 and IEC 60947-3 respectively apply.

Equipment covered by this standard is as follows.

1.1.1 AC and DC contactors

AC and DC contactors intended for closing and opening electric circuits and, if combined with suitable relays (see 1.1.2), for protecting these circuits against operating overloads which may occur therein.

NOTE For contactors combined with suitable relays and which are intended to provide short-circuit protection, the relevant conditions specified for circuit-breakers (IEC 60947-2) additionally apply.

This standard applies also to the actuators of contactor relays and to the contacts dedicated exclusively to the coil circuit of a contactor.

Contactors or starters with an electronically controlled electromagnet are also covered by this standard.

1.1.2 AC motor-starters

AC motor-starters intended to start and accelerate motors to normal speed, to ensure continuous operation of motors, to switch off the supply from the motor and to provide means for the protection of motors and associated circuits against operating overloads.

For overload relays for starters, including those based on electronic technology with or without extended functions according to Annex H, the requirements of this standard apply.

1.1.2.1 Direct-on-line (full voltage) a.c. starters

Direct-on-line starters intended to start and accelerate a motor to normal speed, to provide means for the protection of the motor and its associated circuits against operating overloads, and to switch off the supply from the motor.

This standard applies also to reversing starters.

1.1.2.2 Reduced voltage a.c. starters

Reduced voltage a.c. starters intended to start and accelerate a motor to normal speed by connecting the line voltage across the motor terminals in more than one step or by gradually increasing the voltage applied to the terminals, to provide means for the protection of the motor and its associated circuits against operating overloads, and to switch off the supply from the motor.

Automatic change-over devices may be used to control the successive switching operations from one step to the others. Such automatic change-over devices are, for example, time-delay contactor relays or specified time all-or-nothing relays, under-current devices and automatic acceleration control devices (see 5.10).

1.1.2.2.1 Star-delta starters

Star-delta starters intended to start a three-phase motor in the star connection, to ensure continuous operation in the delta connection to provide means for the protection of the motor and its associated circuits against operating overloads, and to switch off the supply from the motor.

The star-delta starters dealt with in this standard are not intended for reversing motors rapidly and, therefore, utilization category AC-4 does not apply.

NOTE In the star connection, the current in the line and the torque of the motor are about one-third of the corresponding values for delta connection. Therefore, star-delta starters are used when the inrush current due to the starting is to be limited, or when the driven machine requires a limited torque for starting. Figure 1 indicates typical curves of starting current, of starting torque of the motor and of torque of the driven machine.

1.1.2.2.2 Two-step auto-transformer starters

Two-step auto-transformer starters, intended to start and accelerate an a.c. induction motor from rest with reduced torque to normal speed and to provide means for the protection of the motor and its associated circuits against operating overloads, and to switch off the supply from the motor.

This standard applies to auto-transformers which are part of the starter or which constitute a unit specially designed to be associated with the starter.

Auto-transformer starters with more than two steps are not covered by this standard.

The auto-transformer starters dealt with in this standard are not intended for inching duty or reversing motors rapidly and, therefore, utilization category AC-4 does not apply.

NOTE In the starting position, the current in the line and the torque of the motor related to the motor starting with rated voltage are reduced approximately as the square of the ratio (starting voltage):(rated voltage). Therefore, auto-transformer starters are used when the inrush current due to the starting is to be limited or when the driven machine requires a limited torque for starting. Figure 2 indicates typical curves of starting current, of starting torque of the motor and of torque of the driven machine.

1.1.2.3 Rheostatic rotor starters

Starters intended to start an a.c. induction motor having a wound rotor by cutting out resistors previously inserted in the rotor circuit, to provide means for the protection of the motor against operating overloads and to switch off the supply from the motor.

In the case of asynchronous slip-ring motors (wound-rotors), the highest voltage between open slip-rings is not greater than twice the rated insulation voltage of the switching devices inserted in the rotor circuit (see 5.3.1.1.2).

NOTE This requirement is based on the fact that the electric stresses are less severe in the rotor than in the stator and are of short duration.

This standard applies also to starters for two directions of rotation when reversal of connections is made with the motor stopped (see 5.3.5.5). Operations including inching and plugging necessitate additional requirements and are subject to agreement between manufacturer and user.

This standard applies to resistors which are part of the starter or constitute a unit specially designed to be associated with the starter.

1.2 Exclusions

This standard does not apply to:

- d.c. starters;
- star-delta starters, rheostatic rotor starters, two-step auto-transformer starters intended for special applications and designed for continuous operation in the starting position;
- unbalanced rheostatic rotor starters, i.e. where the resistances do not have the same value in all phases;
- equipment designed not only for starting, but also for adjustment of speed;
- liquid starters and those of the "liquid-vapour" type;
- semiconductor contactors and starters making use of semiconductor contactors in the main circuit;
- rheostatic stator starters;
- contactors or starters designed for special applications;
- auxiliary contacts of contactors and contacts of contactor relays. These are dealt with in IEC 60947-5-1.

1.3 Object

The object of this standard is to state:

- a) the characteristics of contactors and starters and associated equipment;
- b) the conditions applicable to contactors and starters with reference to:
 - 1) their operation and behaviour,
 - 2) their dielectric properties,
 - 3) the degrees of protection provided by their enclosures, where applicable,
 - 4) their construction;
- c) the tests intended for confirming that these conditions have been met, and the methods to be adopted for these tests;
- d) the information to be given with the equipment or in the manufacturer's literature.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60034-1:2004, *Rotating electrical machines – Part 1: Rating and performance*

IEC 60085:2007, *Electrical insulation – Thermal evaluation and designation*

IEC 60300-3-5:2001, *Dependability management – Part 3-5: Application guide – Reliability test conditions and statistical test principles*

IEC 60410:1973, *Sampling plans and procedures for inspection by attributes*

IEC 60947-1:2007, *Low-voltage switchgear and controlgear – Part 1: General rules*

IEC 60947-2:2006, *Low-voltage switchgear and controlgear – Part 2: Circuit-breakers*

IEC 60947-3:2008, *Low-voltage switchgear and controlgear – Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units*

IEC 60947-5-1:2003, *Low-voltage switchgear and controlgear – Part 5-1: Control circuit devices and switching elements – Electromechanical control circuit devices*

IEC 61000-4-2:2008, *Electromagnetic compatibility (EMC) – Part 4-2: Testing and measurement techniques – Electrostatic discharge immunity test*

IEC 61000-4-3:2006, *Electromagnetic compatibility (EMC) – Part 4-3: Testing and measurement techniques – Radiated, radio-frequency, electromagnetic field immunity test*
Amendment 1 (2007)

IEC 61000-4-4:2004, *Electromagnetic compatibility (EMC) – Part 4-4: Testing and measurement techniques – Electrical fast transient/burst immunity test*

IEC 61000-4-5:2005, *Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test*

IEC 61000-4-6:2008, *Electromagnetic compatibility (EMC) – Part 4-6: Testing and measurement techniques – Immunity to conducted disturbances, induced by radio-frequency fields*

IEC 61439-1:2009, *Low-voltage switchgear and controlgear assemblies – Part 1: General rules*

IEC 61508 (all parts), *Functional safety of electrical/electronic/programmable electronic safety-related systems*

IEC 61511 (all parts), *Functional safety – Safety instrumented systems for the process industry sector*

IEC 61513:2001, *Nuclear power plants – Instrumentation and control for systems important to safety – General requirements for systems*

IEC 61649:2008, *Weibull analysis*

IEC 61810-1:2008, *Electromechanical elementary relays – Part 1: General requirements*
(available in English only)

IEC 62061:2005, *Safety of machinery – Functional safety of safety-related electrical, electronic and programmable electronic control systems*

CISPR 11:2003, *Industrial, scientific and medical (ISM) radio-frequency equipment – Electromagnetic disturbance characteristics – Limits and methods of measurement*

Amendment 1 (2004)

Amendment 2 (2006)

ISO 13849-1:2006, *Safety of machinery – Safety-related parts of control systems – Part 1: General principles for design*

3 Terms, definitions, symbols and abbreviations

3.1 General

For the purposes of this document, the terms and definitions of Clause 2 of IEC 60947-1, as well as the following terms, definitions, symbol and abbreviations apply.

3.2 Alphabetical index of terms

	Reference
A	
auto-transformer starter	3.4.5.2
C	
closed transition (with an auto-transformer starter or star-delta starter)	3.4.23
combination starter	3.4.8
combination switching device	3.4.27
CO operation	3.5.2
contactor (mechanical)	3.3.1
D	
direct-on-line starter	3.4.2
E	
electromagnetic contactor	3.3.2
electromagnetic starter	3.4.10
electronic overload relay with current imbalance detection	H.2.2
electronic overload relay with ground/earth fault function	H.2.1
electronic overload relay with phase reversal function	H.2.4
electronic overload relay with under power detection	H.2.6
electronically energized coil of electromagnet	3.3.8
electro-pneumatic contactor	3.3.4
electro-pneumatic starter	3.4.13
I	
inching (jogging)	3.4.24
inhibit current (I_{IC})	H.2.7
inhibit time	3.4.30
J	
jam sensitive (electronic overload) relay	3.4.29
L	
latched contactor	3.3.5