

**Electromagnetic compatibility (EMC) -  
Part 2-2: Environment - Compatibility  
levels for low-frequency conducted  
disturbances and signalling in public  
low-voltage power supply systems**

Electromagnetic compatibility (EMC) - Part 2-2:  
Environment - Compatibility levels for low-frequency  
conducted disturbances and signalling in public low-  
voltage power supply systems

## EESTI STANDARDI EESSÖNA

## NATIONAL FOREWORD

Käesolev Eesti standard EVS-EN 61000-2-2:2003 sisaldb Euroopa standardi EN 61000-2-2:2002 ingliskeelset teksti.	This Estonian standard EVS-EN 61000-2-2:2003 consists of the English text of the European standard EN 61000-2-2:2002.
Käesolev dokument on jõustatud 05.02.2003 ja selle kohta on avaldatud teade Eesti standardiorganisatsiooni ametlikus väljaandes.	This document is endorsed on 05.02.2003 with the notification being published in the official publication of the Estonian national standardisation organisation.
Standard on kätesaadav Eesti standardiorganisatsioonist.	The standard is available from Estonian standardisation organisation.

<b>Käsitlusala:</b> This standard is concerned with conducted disturbances in the frequency range from 0 kHz to 9 kHz, with an extension up to 148,5 kHz specifically for mains signalling systems. It gives compatibility levels for public low voltage a.c. distribution systems having a nominal voltage up to 420 V, single-phase or 690 V, three-phase and a nominal frequency of 50 Hz or 60 Hz. Compatibility levels are specified for electromagnetic disturbances of the types which can be expected in public low voltage power supply systems, for guidance in: - the limits to be set for disturbance emission into public power supply systems; - the immunity limits to be set by product committees and others for the equipment exposed to the conducted disturbances present in public power supply systems.	<b>Scope:</b> This standard is concerned with conducted disturbances in the frequency range from 0 kHz to 9 kHz, with an extension up to 148,5 kHz specifically for mains signalling systems. It gives compatibility levels for public low voltage a.c. distribution systems having a nominal voltage up to 420 V, single-phase or 690 V, three-phase and a nominal frequency of 50 Hz or 60 Hz. Compatibility levels are specified for electromagnetic disturbances of the types which can be expected in public low voltage power supply systems, for guidance in: - the limits to be set for disturbance emission into public power supply systems; - the immunity limits to be set by product committees and others for the equipment exposed to the conducted disturbances present in public power supply systems.
--	--

**ICS** 33.100.01

**Võtmesõnad:** enviro, influence quantities, interference rejections, interferences, limits (mathematics), low frequencies, low voltage, low-frequency engineering, magnetic field effects, magnetoelectric effects, mathematics, measurement, radio frequencies, signal transmission

EUROPEAN STANDARD

**EN 61000-2-2**

NORME EUROPÉENNE

EUROPÄISCHE NORM

June 2002

ICS 33.100.01

English version

**Electromagnetic compatibility (EMC)**  
**Part 2-2: Environment -**  
**Compatibility levels for low-frequency conducted disturbances**  
**and signalling in public low-voltage power supply systems**  
(IEC 61000-2-2:2002)

Compatibilité électromagnétique (CEM)  
Partie 2-2: Environnement -  
Niveaux de compatibilité pour les  
perturbations conduites à basse  
fréquence et la transmission des signaux  
sur les réseaux publics d'alimentation  
basse tension  
(CEI 61000-2-2:2002)

Elektromagnetische Verträglichkeit (EMV)  
Teil 2-2: Umgebungsbedingungen -  
Verträglichkeitspegel für niederfrequente  
leitungsgeführte Störgrößen und  
Signalübertragung in öffentlichen  
Niederspannungsnetzen  
(IEC 61000-2-2:2002)

This European Standard was approved by CENELEC on 2002-05-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Malta, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.

**CENELEC**

European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**Central Secretariat: rue de Stassart 35, B - 1050 Brussels**

## Foreword

The text of document 77A/367/FDIS, future edition 2 of IEC 61000-2-2, prepared by SC 77A, Low frequency phenomena, of IEC TC 77, Electromagnetic compatibility, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 61000-2-2 on 2002-05-01.

The following dates were fixed:

- latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2003-02-01
- latest date by which the national standards conflicting with the EN have to be withdrawn (dow) 2005-05-01

Annexes designated "normative" are part of the body of the standard.

Annexes designated "informative" are given for information only.

In this standard, annex ZA is normative and annexes A and B are informative.

Annex ZA has been added by CENELEC.

---

## Endorsement notice

The text of the International Standard IEC 61000-2-2:2002 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60038	NOTE	Harmonized as HD 472 S1:1989 (modified).
IEC 61000-2-4	NOTE	Harmonized as EN 61000-2-4:1994 (not modified).
IEC 61000-3-2	NOTE	Harmonized as EN 61000-3-2:2000 (modified).
IEC 61037	NOTE	Harmonized as EN 61037:1992 (modified) + A1:1996 (not modified) + A2:1998 (not modified).

---

## Annex ZA (normative)

### **Normative references to international publications with their corresponding European publications**

This European Standard incorporates by dated or undated reference, provisions from other publications. These normative references are cited at the appropriate places in the text and the publications are listed hereafter. For dated references, subsequent amendments to or revisions of any of these publications apply to this European Standard only when incorporated in it by amendment or revision. For undated references the latest edition of the publication referred to applies (including amendments).

**NOTE** When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60050-101	- 1)	International Electrotechnical Vocabulary (IEV) Part 101: Mathematics	-	-
IEC 60050-161	- 1)	Chapter 161: Electromagnetic compatibility	-	-
IEC 60664-1 (mod)	- 1)	Insulation coordination for equipment within low-voltage systems Part 1: Principles, requirements and tests	HD 625.1 S1 + corr. November	1996 2) 1996
IEC/TR3 61000-2-1	- 1)	Electromagnetic compatibility (EMC) Part 2: Environment - Section 1: Description of the environment - Electromagnetic environment for low-frequency conducted disturbances and signalling in public power supply systems	-	-
IEC 61000-3-3	- 1)	Part 3-3: Limits - Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current <= 16 A per phase and not subject to conditional connection	EN 61000-3-3 + corr. July	1995 2) 1997
IEC 61000-4-7	- 1)	Part 4-7: Testing and measurement techniques - General guide on harmonics and interharmonics measurements and instrumentation, for power supply systems and equipment connected thereto	EN 61000-4-7	1993 2)

1) Undated reference.

2) Valid edition at date of issue.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61000-4-15	- <sup>1)</sup>	Part 4-15: Testing and measurement techniques - Flickermeter - Functional and design specifications	EN 61000-4-15	1998 <sup>2)</sup>

This document is a preview generated by EVS

NORME  
INTERNATIONALE  
INTERNATIONAL  
STANDARD

CEI  
IEC

61000-2-2

Deuxième édition  
Second edition  
2002-03

---

---

PUBLICATION FONDAMENTALE EN CEM  
BASIC EMC PUBLICATION

---

---

**Compatibilité électromagnétique (CEM) –**

**Partie 2-2:**

**Environnement – Niveaux de compatibilité  
pour les perturbations conduites à basse  
fréquence et la transmission des signaux  
sur les réseaux publics d'alimentation  
basse tension**

**Electromagnetic compatibility (EMC) –**

**Part 2-2:**

**Environment – Compatibility levels for low-  
frequency conducted disturbances and signalling  
in public low-voltage power supply systems**



Numéro de référence  
Reference number  
CEI/IEC 61000-2-2:2002

## **Numérotation des publications**

Depuis le 1er janvier 1997, les publications de la CEI sont numérotées à partir de 60000. Ainsi, la CEI 34-1 devient la CEI 60034-1.

## **Editions consolidées**

Les versions consolidées de certaines publications de la CEI incorporant les amendements sont disponibles. Par exemple, les numéros d'édition 1.0, 1.1 et 1.2 indiquent respectivement la publication de base, la publication de base incorporant l'amendement 1, et la publication de base incorporant les amendements 1 et 2.

## **Informations supplémentaires sur les publications de la CEI**

Le contenu technique des publications de la CEI est constamment revu par la CEI afin qu'il reflète l'état actuel de la technique. Des renseignements relatifs à cette publication, y compris sa validité, sont disponibles dans le Catalogue des publications de la CEI (voir ci-dessous) en plus des nouvelles éditions, amendements et corrigenda. Des informations sur les sujets à l'étude et l'avancement des travaux entrepris par le comité d'études qui a élaboré cette publication, ainsi que la liste des publications parues, sont également disponibles par l'intermédiaire de:

- **Site web de la CEI ([www.iec.ch](http://www.iec.ch))**
- **Catalogue des publications de la CEI**

Le catalogue en ligne sur le site web de la CEI ([www.iec.ch/catlg-f.htm](http://www.iec.ch/catlg-f.htm)) vous permet de faire des recherches en utilisant de nombreux critères, comprenant des recherches textuelles, par comité d'études ou date de publication. Des informations en ligne sont également disponibles sur les nouvelles publications, les publications remplaçées ou retirées, ainsi que sur les corrigenda.

- **IEC Just Published**

Ce résumé des dernières publications parues ([www.iec.ch/JP.htm](http://www.iec.ch/JP.htm)) est aussi disponible par courrier électronique. Veuillez prendre contact avec le Service client (voir ci-dessous) pour plus d'informations.

- **Service clients**

Si vous avez des questions au sujet de cette publication ou avez besoin de renseignements supplémentaires, prenez contact avec le Service clients:

Email: [custserv@iec.ch](mailto:custserv@iec.ch)

Tél: +41 22 919 02 11

Fax: +41 22 919 03 00

## **Publication numbering**

As from 1 January 1997 all IEC publications are issued with a designation in the 60000 series. For example, IEC 34-1 is now referred to as IEC 60034-1.

## **Consolidated editions**

The IEC is now publishing consolidated versions of its publications. For example, edition numbers 1.0, 1.1 and 1.2 refer, respectively, to the base publication, the base publication incorporating amendment 1 and the base publication incorporating amendments 1 and 2.

## **Further information on IEC publications**

The technical content of IEC publications is kept under constant review by the IEC, thus ensuring that the content reflects current technology. Information relating to this publication, including its validity, is available in the IEC Catalogue of publications (see below) in addition to new editions, amendments and corrigenda. Information on the subjects under consideration and work in progress undertaken by the technical committee which has prepared this publication, as well as the list of publications issued, is also available from the following:

- **IEC Web Site ([www.iec.ch](http://www.iec.ch))**
- **Catalogue of IEC publications**

The on-line catalogue on the IEC web site ([www.iec.ch/catlg-e.htm](http://www.iec.ch/catlg-e.htm)) enables you to search by a variety of criteria including text searches, technical committees and date of publication. Online information is also available on recently issued publications, withdrawn and replaced publications, as well as corrigenda.

- **IEC Just Published**

This summary of recently issued publications ([www.iec.ch/JP.htm](http://www.iec.ch/JP.htm)) is also available by email. Please contact the Customer Service Centre (see below) for further information.

- **Customer Service Centre**

If you have any questions regarding this publication or need further assistance, please contact the Customer Service Centre:

Email: [custserv@iec.ch](mailto:custserv@iec.ch)

Tel: +41 22 919 02 11

Fax: +41 22 919 03 00

NORME  
INTERNATIONALE  
INTERNATIONAL  
STANDARD

CEI  
IEC

61000-2-2

Deuxième édition  
Second edition  
2002-03

---

---

PUBLICATION FONDAMENTALE EN CEM  
BASIC EMC PUBLICATION

---

---

**Compatibilité électromagnétique (CEM) –**

**Partie 2-2:**

**Environnement – Niveaux de compatibilité  
pour les perturbations conduites à basse  
fréquence et la transmission des signaux  
sur les réseaux publics d'alimentation  
basse tension**

**Electromagnetic compatibility (EMC) –**

**Part 2-2:**

**Environment – Compatibility levels for low-  
frequency conducted disturbances and signalling  
in public low-voltage power supply systems**

© IEC 2002 Droits de reproduction réservés — Copyright - all rights reserved

Aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'éditeur.

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembé, PO Box 131, CH-1211 Geneva 20, Switzerland  
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: [inmail@iec.ch](mailto:inmail@iec.ch) Web: [www.iec.ch](http://www.iec.ch)



Commission Electrotechnique Internationale  
International Electrotechnical Commission  
Международная Электротехническая Комиссия

CODE PRIX  
PRICE CODE

U

*Pour prix, voir catalogue en vigueur  
For price, see current catalogue*

## SOMMAIRE

AVANT-PROPOS .....	4
INTRODUCTION .....	8
1    Domaine d'application et objet .....	10
2    Références normatives .....	12
3    Définitions .....	12
3.1    Définitions générales .....	12
3.2    Définitions relatives aux phénomènes .....	14
4    Niveaux de compatibilité .....	18
4.1    Commentaires généraux.....	18
4.2    Fluctuations de tension et flicker.....	18
4.3    Harmoniques .....	20
4.4    Inter-harmoniques .....	22
4.5    Creux de tension et coupures brèves .....	24
4.6    Déséquilibre de tension .....	26
4.7    Surtensions transitoires .....	26
4.8    Variations temporaires de la fréquence du réseau.....	26
4.9    Composantes continues.....	26
4.10    Systèmes de transmission de signaux sur le réseau.....	28
Annexe A (informative) Le rôle des niveaux de compatibilité et de planification en CEM.....	32
A.1    Le besoin de niveaux de compatibilité .....	32
A.2    Relation entre niveau de compatibilité et niveaux d'immunité .....	32
A.3    Relation entre niveau de compatibilité et limites d'émission .....	34
A.4    Niveaux de planification .....	36
A.5    Illustration des niveaux de compatibilité, d'émission, d'immunité et de planification.....	38
Annexe B (informative) Présentation de quelques phénomènes de perturbation .....	40
B.1    Décomposition de tensions et courants non sinusoïdaux .....	40
B.2    Inter-harmoniques et composantes de tension aux fréquences supérieures à celle du rang 50.....	44
B.3    Creux de tension et coupures brèves de l'alimentation.....	52
B.4    Surtensions transitoires.....	54
B.5    Composantes continues .....	54
Bibliographie .....	56

## CONTENTS

FOREWORD .....	5
INTRODUCTION .....	9
1 Scope and object .....	11
2 Normative references .....	13
3 Definitions .....	13
3.1 General definitions .....	13
3.2 Phenomena related definitions .....	15
4 Compatibility levels .....	19
4.1 General comment .....	19
4.2 Voltage fluctuations and flicker .....	19
4.3 Harmonics .....	21
4.4 Interharmonics .....	23
4.5 Voltage dips and short supply interruptions .....	25
4.6 Voltage unbalance .....	27
4.7 Transient overvoltages .....	27
4.8 Temporary power frequency variation .....	27
4.9 DC component .....	27
4.10 Mains signalling .....	29
Annex A (Informative) The function of compatibility levels and planning levels in EMC .....	33
A.1 The need for compatibility levels .....	33
A.2 Relation between compatibility level and immunity levels .....	33
A.3 Relation between compatibility level and emission limits .....	35
A.4 Planning levels .....	37
A.5 Illustration of compatibility, emission, immunity and planning levels .....	39
Annex B (informative) Discussion of some disturbance phenomena .....	41
B.1 Resolution of non-sinusoidal voltages and currents .....	41
B.2 Interharmonics and voltage components at frequencies above that of the 50 <sup>th</sup> harmonic ..	45
B.3 Voltage dips and short supply interruptions .....	53
B.4 Transient overvoltages .....	55
B.5 DC component .....	55
Bibliography .....	57

## COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

### COMPATIBILITÉ ÉLECTROMAGNÉTIQUE (CEM) –

#### Partie 2-2: Environnement – Niveaux de compatibilité pour les perturbations conduites à basse fréquence et la transmission des signaux sur les réseaux publics d'alimentation basse tension

### AVANT-PROPOS

- 1) La CEI (Commission Électrotechnique Internationale) est une organisation mondiale de normalisation composée de l'ensemble des comités électrotechniques nationaux (Comités nationaux de la CEI). La CEI a pour objet de favoriser la coopération internationale pour toutes les questions de normalisation dans les domaines de l'électricité et de l'électronique. A cet effet, la CEI, entre autres activités, publie des Normes internationales. Leur élaboration est confiée à des comités d'études, aux travaux desquels tout Comité national intéressé par le sujet traité peut participer. Les organisations internationales, gouvernementales et non gouvernementales, en liaison avec la CEI, participent également aux travaux. La CEI collabore étroitement avec l'Organisation Internationale de Normalisation (ISO), selon des conditions fixées par accord entre les deux organisations.
- 2) Les décisions ou accords officiels de la CEI en ce qui concerne les questions techniques, préparés par les comités d'études où sont représentés tous les Comités nationaux s'intéressant à ces questions, expriment dans la plus grande mesure possible un accord international sur les sujets examinés.
- 3) Ces décisions constituent des recommandations internationales publiées sous forme de normes, de rapports techniques ou de guides et agréées comme telles par les Comités nationaux.
- 4) Dans le but d'encourager l'unification internationale, les Comités nationaux de la CEI s'engagent à appliquer de façon transparente, dans toute la mesure possible, les Normes internationales de la CEI dans leurs normes nationales et régionales. Toute divergence entre la norme de la CEI et la norme nationale ou régionale correspondante doit être indiquée en termes clairs dans cette dernière.
- 5) La CEI n'a fixé aucune procédure concernant le marquage comme indication d'approbation et sa responsabilité n'est pas engagée quand un matériel est déclaré conforme à l'une de ses normes.
- 6) L'attention est attirée sur le fait que certains des éléments de la présente Norme internationale peuvent faire l'objet de droits de propriété intellectuelle ou de droits analogues. La CEI ne saurait être tenue pour responsable de ne pas avoir identifié de tels droits de propriété et de ne pas avoir signalé leur existence.

La Norme internationale CEI 61000-2-2 a été établie par le sous-comité 77A: Phénomènes basse fréquence, du comité d'études 77 de la CEI: Compatibilité électromagnétique. Elle a le statut de publication fondamentale en CEM conformément au guide 107 de la CEI.

Cette deuxième édition annule et remplace la première édition, parue en 1990. Cette deuxième édition constitue une révision technique.

Le texte de cette norme est issu des documents suivants:

FDIS	Rapport de vote
77A/367/FDIS	77A/376/RVD

Le rapport de vote indiqué dans le tableau ci-dessus donne toute information sur le vote ayant abouti à l'approbation de cette norme.

Cette publication a été rédigée selon les Directives ISO/CEI, Partie 3.

Les annexes A et B sont données uniquement à titre d'information.

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ELECTROMAGNETIC COMPATIBILITY (EMC) –****Part 2-2: Environment – Compatibility levels for low-frequency conducted disturbances and signalling in public low-voltage power supply systems****FOREWORD**

- 1) The IEC (International Electrotechnical Commission) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of the IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, the IEC publishes International Standards. Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. The IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of the IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested National Committees.
- 3) The documents produced have the form of recommendations for international use and are published in the form of standards, technical specifications, technical reports or guides and they are accepted by the National Committees in that sense.
- 4) In order to promote international unification, IEC National Committees undertake to apply IEC International Standards transparently to the maximum extent possible in their national and regional standards. Any divergence between the IEC Standard and the corresponding national or regional standard shall be clearly indicated in the latter.
- 5) The IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with one of its standards.
- 6) Attention is drawn to the possibility that some of the elements of this International Standard may be the subject of patent rights. The IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61000-2-2 has been prepared by subcommittee 77A: Low frequency phenomena, of IEC technical committee 77: Electromagnetic compatibility. It has the status of a basic EMC publication in accordance with IEC guide 107.

This second edition cancels and replaces the first edition, published in 1990. This second edition constitutes a technical revision.

The text of this standard is based on the following documents:

FDIS	Report on voting
77A/367/FDIS	77A/376/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 3.

Annexes A and B are for information only.

Le comité a décidé que le contenu de cette publication ne sera pas modifié avant 2012. A cette date, la publication sera

- reconduite;
- supprimée;
- remplacée par une édition révisée, ou
- amendée.

The committee has decided that the contents of this publication will remain unchanged until 2012. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

## INTRODUCTION

La CEI 61000 est publiée sous forme de plusieurs parties conformément à la structure suivante:

### **Partie 1: Généralités**

Considérations générales (introduction, principes fondamentaux)

Définitions, terminologie

### **Partie 2: Environnement**

Description de l'environnement

Classification de l'environnement

Niveaux de compatibilité

### **Partie 3: Limites**

Limites d'émission

Limites d'immunité (dans la mesure où elles ne relèvent pas des comités de produits)

### **Partie 4: Techniques d'essais et de mesure**

Techniques de mesure

Techniques d'essai

### **Partie 5: Guides d'installation et d'atténuation**

Guides d'installation

Méthodes et dispositifs d'atténuation

### **Partie 6: Normes génériques**

### **Partie 9: Divers**

Chaque partie est à son tour subdivisée en plusieurs parties, publiées soit comme Normes internationales, soit comme spécifications techniques ou rapports techniques, dont certaines ont déjà été publiées en tant que sections. D'autres seront publiées sous le numéro de la partie, suivi d'un tiret et complété d'un second chiffre identifiant la subdivision (exemple: 61000-6-1).

Des informations détaillées sur les différents types de perturbations que l'on peut s'attendre à trouver sur les réseaux publics d'alimentation électrique figurent dans la CEI 61000-2-1.

## INTRODUCTION

IEC 61000 is published in separate parts according to the following structure:

### **Part 1: General**

- General considerations (introduction, fundamental principles)
- Definitions, terminology

### **Part 2: Environment**

- Description of the environment
- Classification of the environment
- Compatibility levels

### **Part 3: Limits**

- Emission limits
- Immunity limits (in so far as they do not fall under the responsibility of the product committees)

### **Part 4: Testing and measurement techniques**

### **Part 5: Installation and mitigation guidelines**

- Installation guidelines
- Mitigation methods and devices

### **Part 6: Generic standards**

### **Part 9: Miscellaneous**

Each part is further subdivided into several parts, published either as International Standards or as technical specifications or technical reports, some of which have already been published as sections. Others will be published with the part number followed by a dash and completed by a second number identifying the subdivision (example: 61000-6-1).

Detailed information on the various types of disturbances that can be expected on public power supply systems can be found in IEC 61000-2-1.

## COMPATIBILITÉ ÉLECTROMAGNÉTIQUE (CEM) –

### Partie 2-2: Environnement – Niveaux de compatibilité pour les perturbations conduites à basse fréquence et la transmission des signaux sur les réseaux publics d'alimentation basse tension

#### 1 Domaine d'application et objet

La présente norme est relative aux perturbations conduites dans le domaine de fréquences de 0 kHz à 9 kHz, avec une extension jusqu'à 148,5 kHz pour les systèmes de transmission de signaux sur le réseau. Elle fournit les valeurs numériques des niveaux de compatibilité pour les réseaux de distribution publics alternatifs basse tension, avec une tension nominale maximale de 420 V en monophasé, ou 690 V en triphasé, et une fréquence nominale de 50 Hz ou 60 Hz.

Les niveaux de compatibilité spécifiés dans cette norme s'appliquent au point de couplage commun. Aux bornes d'un matériel alimenté par les réseaux décrits ci-dessus, la sévérité des perturbations peut, dans la plupart des cas, être considérée comme égale à celle au point de couplage commun. Il en va différemment dans certaines situations, notamment dans le cas d'une longue ligne dédiée à l'alimentation d'une installation définie, ou dans le cas d'une perturbation générée ou amplifiée dans l'installation dont l'équipement fait partie.

Les niveaux de compatibilité sont donnés pour les perturbations électromagnétiques auxquelles on peut s'attendre sur les réseaux de distribution publics basse tension, dans le but d'aider à définir:

- les limites devant être établies pour les émissions perturbatrices sur les réseaux publics de distribution d'énergie (comprenant les niveaux de planification tels qu'ils sont définis en 3.1.5);
- les limites d'immunité devant être établies par les comités de produits ou autres concernant les équipements soumis aux perturbations conduites par les réseaux publics de distribution d'énergie.

Les phénomènes perturbateurs considérés sont:

- les fluctuations de tension et le flicker;
- les harmoniques jusques et y compris le rang 50;
- les inter-harmoniques jusqu'au rang 50;
- les distorsions de tension aux fréquences supérieures (au-dessus du rang 50);
- les creux de tension et les coupures brèves;
- le déséquilibre de tension;
- les surtensions transitoires;
- les variations de fréquence fondamentale;
- les composantes continues;
- les systèmes de transmission de signaux sur le réseau.

La plupart des ces phénomènes sont décrits dans la CEI 61000-2-1. Au cas où il n'est pas possible maintenant d'établir des niveaux de compatibilité, quelques informations sont fournies.

## ELECTROMAGNETIC COMPATIBILITY (EMC) –

### Part 2-2 : Environment – Compatibility levels for low-frequency conducted disturbances and signalling in public low-voltage power supply systems

#### 1 Scope and object

This standard is concerned with conducted disturbances in the frequency range from 0 kHz to 9 kHz, with an extension up to 148,5 kHz specifically for mains signalling systems. It gives compatibility levels for public low voltage a.c. distribution systems having a nominal voltage up to 420 V, single-phase or 690 V, three-phase and a nominal frequency of 50 Hz or 60 Hz.

The compatibility levels specified in this standard apply at the point of common coupling. At the power input terminals of equipment receiving its supply from the above systems the severity levels of the disturbances can, for the most part, be taken to be the same as the levels at the point of common coupling. In some situations this is not so, particularly in the case of a long line dedicated to the supply of a particular installation, or in the case of a disturbance generated or amplified within the installation of which the equipment forms a part.

Compatibility levels are specified for electromagnetic disturbances of the types which can be expected in public low voltage power supply systems, for guidance in:

- the limits to be set for disturbance emission into public power supply systems (including the planning levels defined in 3.1.5).
- the immunity limits to be set by product committees and others for the equipment exposed to the conducted disturbances present in public power supply systems.

The disturbance phenomena considered are:

- voltage fluctuations and flicker;
- harmonics up to and including order 50;
- inter-harmonics up to the 50<sup>th</sup> harmonic;
- voltage distortions at higher frequencies (above the 50<sup>th</sup> harmonic);
- voltage dips and short supply interruptions;
- voltage unbalance;
- transient overvoltages;
- power frequency variation;
- d.c. components;
- mains signalling.

Most of these phenomena are described in IEC 61000-2-1. In cases where it is not yet possible to establish compatibility levels, some information is provided.

## 2 Références normatives

Les documents de référence suivants sont indispensables pour l'application du présent document. Pour les références datées, seule l'édition citée s'applique. Pour les références non datées, la dernière édition du document de référence s'applique (y compris les éventuels amendements).

CEI 60050-101, *Vocabulaire Électrotechnique International (VEI) – Chapitre 101: Mathématiques*

CEI 60050-161, *Vocabulaire Électrotechnique International (VEI) – Chapitre 161: Compatibilité électromagnétique*

CEI 60664-1, *Coordination de l'isolement des matériels dans les systèmes (réseaux) à basse tension – Partie 1: Principes, prescriptions et essais*

CEI/TR3 61000-2-1, *Compatibilité électromagnétique (CEM) – Partie 2: Environnement – Section 1: Description de l'environnement – Environnement électromagnétique pour les perturbations conduites basse fréquence et la transmission de signaux sur les réseaux publics d'alimentation*

CEI 61000-3-3, *Compatibilité électromagnétique (CEM) – Partie 3: Limites – Section 3: Limitation des fluctuations de tension et du flicker dans les réseaux basse tension pour les équipements ayant un courant appelé  $\leq 16 \text{ A}$*

CEI 61000-4-7, *Compatibilité électromagnétique (CEM) – Partie 4: Techniques d'essai et de mesure – Section 7: Guide général relatif aux mesures d'harmoniques et d'interharmoniques, ainsi qu'à l'appareillage de mesure, applicable aux réseaux d'alimentation et aux appareils qui y sont raccordés*

CEI 61000-4-15, *Compatibilité électromagnétique (CEM) – Partie 4: Techniques d'essai et de mesure – Section 15: Flickermètre – Spécifications fonctionnelles et de conception*

## 3 Définitions

Pour les besoins de la présente partie de la CEI 61000, les définitions données dans la CEI 60050-101, la CEI 60050-161 et ses amendements 1 et 2 ainsi que les suivantes s'appliquent.

### 3.1 Définitions générales

#### 3.1.1

##### **perturbation (électromagnétique)**

tout phénomène électromagnétique qui, de par sa présence dans l'environnement électromagnétique, peut faire dévier un équipement électrique de sa performance attendue

[VEI 161-01-05, modifiée]

#### 3.1.2

##### **niveau de perturbation**

amplitude d'une perturbation électromagnétique, mesurée et évaluée au moyen d'une méthode spécifiée

[VEI 161-03-01, modifiée]

## 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-101, *International Electrotechnical Vocabulary (IEV) – Part 101: Mathematics*

IEC 60050-161, *International Electrotechnical Vocabulary (IEV) – Part 161: Electromagnetic compatibility*

IEC 60664-1, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC/TR3 61000-2-1, *Electromagnetic compatibility (EMC) – Part 2: Environment – Section 1: Description of the environment – Electromagnetic environment for low-frequency conducted disturbances and signalling in public power supply systems*

IEC 61000-3-3, *Electromagnetic compatibility (EMC) – Part 3: Limits – Section 3: Limitation of voltage fluctuations and flicker in low-voltage supply systems for equipment with rated current  $\leq 16\text{ A}$*

IEC 61000-4-7, *Electromagnetic compatibility (EMC) – Part 4: Testing and measurement techniques – Section 7: General guide on harmonics and interharmonics measurements and instrumentation, for power supply systems and equipment connected thereto*

IEC 61000-4-15, *Electromagnetic compatibility (EMC) – Part 4: Testing and measurement techniques – Section 15: Flickermeter – Functional and design specifications*

## 3 Definitions

For the purposes of this part of IEC 61000, the definitions given in IEC 60050-101, IEC 60050-161 and its amendments 1 and 2, as well as the following, apply.

### 3.1 General definitions

#### 3.1.1

#### (electromagnetic) disturbance

any electromagnetic phenomenon which, by being present in the electromagnetic environment, can cause electrical equipment to depart from its intended performance

[IEV 161-01-05, modified]

#### 3.1.2

#### disturbance level

the amount or magnitude of an electromagnetic disturbance, measured and evaluated in a specified way

[IEV 161-03-01, modified]