

INTERNATIONAL STANDARD

IEC
60870-6-802

Second edition
2002-04

Telecontrol equipment and systems –

Part 6-802:

Telecontrol protocols compatible with ISO standards and ITU-T recommendations – TASE.2 Object models

Matériels et systèmes de téléconduite –

Partie 6-802:

Protocoles de téléconduite compatibles avec les normes ISO et les recommandations de l'UIT-T – Modèles d'objets TASE.2



Reference number
IEC 60870-6-802:2002(E)

Publication numbering

As from 1 January 1997 all IEC publications are issued with a designation in the 60000 series. For example, IEC 34-1 is now referred to as IEC 60034-1.

Consolidated editions

The IEC is now publishing consolidated versions of its publications. For example, edition numbers 1.0, 1.1 and 1.2 refer, respectively, to the base publication, the base publication incorporating amendment 1 and the base publication incorporating amendments 1 and 2.

Further information on IEC publications

The technical content of IEC publications is kept under constant review by the IEC, thus ensuring that the content reflects current technology. Information relating to this publication, including its validity, is available in the IEC Catalogue of publications (see below) in addition to new editions, amendments and corrigenda. Information on the subjects under consideration and work in progress undertaken by the technical committee which has prepared this publication, as well as the list of publications issued, is also available from the following:

- **IEC Web Site** (www.iec.ch)

- **Catalogue of IEC publications**

The on-line catalogue on the IEC web site (www.iec.ch/catlg-e.htm) enables you to search by a variety of criteria including text searches, technical committees and date of publication. On-line information is also available on recently issued publications, withdrawn and replaced publications, as well as corrigenda.

- **IEC Just Published**

This summary of recently issued publications (www.iec.ch/JP.htm) is also available by email. Please contact the Customer Service Centre (see below) for further information.

- **Customer Service Centre**

If you have any questions regarding this publication or need further assistance, please contact the Customer Service Centre:

Email: custserv@iec.ch

Tel: +41 22 919 02 11

Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

IEC
60870-6-802

Second edition
2002-04

Telecontrol equipment and systems –

Part 6-802:

Telecontrol protocols compatible with ISO standards and ITU-T recommendations – TASE.2 Object models

Matériels et systèmes de téléconduite –

Partie 6-802:

Protocoles de téléconduite compatibles avec les normes ISO et les recommandations de l'UIT-T – Modèles d'objets TASE.2

© IEC 2002 — Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembé, PO Box 131, CH-1211 Geneva 20, Switzerland
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

PRICE CODE

XC

For price, see current catalogue

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	5
1 Scope.....	6
2 Normative references.....	6
3 Definitions.....	6
4 Abbreviations.....	6
5 Object models.....	7
5.1 Supervisory Control and Data Acquisition.....	7
5.1.1 IndicationPoint Object.....	7
5.1.2 ControlPoint Object.....	10
5.1.3 Protection Equipment Event Object Model.....	11
5.2 Transfer Accounts.....	14
5.2.1 TransferAccount Object.....	14
5.2.2 TransmissionSegment Object.....	17
5.2.3 ProfileValue Object.....	18
5.2.4 AccountRequest Object.....	19
5.3 Device Outage Object.....	20
5.4 InformationBuffer Object.....	22
5.5 Power Plant Objects.....	23
5.5.1 Availability Report Object.....	23
5.5.2 Real Time Status Object.....	26
5.5.3 Forecast Schedule Object.....	29
5.5.4 Curve Object.....	30
5.5.5 Power System Dynamics Objects.....	31
5.6 General Data Report Object.....	31
5.6.1 Abstract Object Model.....	31
5.7 General Data Response Object.....	34
5.7.1 Abstract Object Model.....	34
6 MMS Types for Object Exchange.....	35
6.1 Supervisory Control and Data Acquisition Types.....	35
6.1.1 IndicationPoint Type Descriptions.....	35
6.1.2 ControlPoint Type Descriptions.....	38
6.1.3 Protection Equipment Type Descriptions.....	39
6.2 Transfer Account Types.....	40
6.2.1 TransferAccount Type Descriptions.....	40
6.2.2 TransmissionSegment Type Descriptions.....	41
6.2.3 Transmission Segment Type Descriptions.....	42
6.2.4 ProfileValue Type Descriptions.....	42
6.2.5 Account Request Type Descriptions.....	42
6.3 Device Outage Type Descriptions.....	42
6.4 InformationBuffer Type Descriptions.....	44

6.5	Power Plant Type Descriptions	44
6.5.1	Availability Report Type Descriptions.....	45
6.5.2	Real Time Status Type Descriptions.....	46
6.5.3	Forecast Type Descriptions.....	46
6.5.4	Curve Type Descriptions	47
6.6	Power System Dynamics.....	47
6.7	Matrix Data Types.....	47
6.8	GeneralDataReport Type Descriptions	49
6.9	GeneralDataResponse Type Descriptions	49
7	Mapping of Object Models to MMS Types.....	50
7.1	Supervisory Control and Data Mapping	50
7.1.1	Indication Object Mapping.....	50
7.1.2	ControlPoint Object Mapping.....	51
7.1.3	Protection Event Mapping	53
7.2	Transfer Accounts Mapping	55
7.2.1	TransferAccount Mapping	55
7.2.2	TransmissionSegment Mapping	59
7.2.3	ProfileValue Mapping	61
7.2.4	AccountRequest Mapping	62
7.3	Device Outage Mapping.....	62
7.4	Information Buffer Mapping.....	64
7.5	Power Plant Mapping	64
7.5.1	Availability Report Mapping	64
7.5.2	Real Time Status Mapping	67
7.5.3	Forecast Mapping	69
7.5.4	Curve Mapping	70
7.6	General Data Report Mapping.....	71
7.7	General Data Response Mapping.....	75
8	Use of Supervisory Control Objects.....	75
8.1	Use of IndicationPoint Model.....	76
8.2	Use of ControlPoint Model	76
9	Conformance	77
	Annex A (informative) Transfer account examples	78

INTERNATIONAL ELECTROTECHNICAL COMMISSION

TELECONTROL EQUIPMENT AND SYSTEMS –

**Part 6-802: Telecontrol protocols compatible with
ISO standards and ITU-T recommendations –
TASE.2 Object models**

FOREWORD

- 1) The IEC (International Electrotechnical Commission) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of the IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, the IEC publishes International Standards. Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. The IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of the IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested National Committees.
- 3) The documents produced have the form of recommendations for international use and are published in the form of standards, technical specifications, technical reports or guides and they are accepted by the National Committees in that sense.
- 4) In order to promote international unification, IEC National Committees undertake to apply IEC International Standards transparently to the maximum extent possible in their national and regional standards. Any divergence between the IEC Standard and the corresponding national or regional standard shall be clearly indicated in the latter.
- 5) The IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with one of its standards.
- 6) Attention is drawn to the possibility that some of the elements of this International Standard may be the subject of patent rights. The IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60870-6-802 has been prepared by IEC technical committee 57: Power system control and associated communications.

This second edition cancels and replaces the first edition published in 1997 and constitutes a technical revision.

The text of this standard is based on the following documents:

FDIS	Report on voting
57/575/FDIS	57/583/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

Annex A is for information only.

The committee has decided that the contents of this publication will remain unchanged until 2004. At this date, the publication will be:

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

INTRODUCTION

The primary purpose of Telecontrol Application Service Element (TASE.2) is to transfer data between control systems and to initiate control actions. Data is represented by object instances. This part of IEC 60870 proposes object models from which to define object instances. The object models represent objects for transfer. The local system may not maintain a copy of every attribute of an object instance.

The object models presented herein are specific to "control centre" or "utility" operations and applications; objects required to implement the TASE.2 protocol and services are found in IEC 60870-6-503. Since needs will vary, the object models presented here provide only a base; extensions or additional models may be necessary for two systems to exchange data not defined within this standard.

It is by definition that the attribute values (i.e. data) are managed by the owner (i.e. source) of an object instance. The method of acquiring the values are implementation dependent; therefore accuracy is a local matter.

The notation of the object modelling used for the objects specified in clause 5 is defined in IEC 60870-6-503. It should be noted that this part of IEC 60870 is based on the TASE.2 services and protocol. To understand the modelling and semantics of this standard, some basic knowledge of IEC 60870-6-503 is recommended.

Clause 5 describes the control centre-specific object models and their application. They are intended to provide information to explain the function of the data.

Clause 6 defines a set of MMS type descriptions for use in exchanging the values of instances of the defined object models. It is important to note that not all attributes of the object models are mapped to types. Some attributes are described simply to define the processing required by the owner of the data and are never exchanged between control centres. Other attributes are used to determine the specific types of MMS variables used for the mapping, and therefore do not appear as exchanged values themselves. A single object model may also be mapped onto several distinct MMS variables, based on the type of access and the TASE.2 services required.

Clause 7 describes the mapping of instances of each object type MMS variables and named variable lists for implementing the exchange.

Clause 8 describes device-specific codes and semantics to be used with the general objects.

An informative annex is included which describes some typical interchange scheduling scenarios, along with the use of TASE.2 objects to implement the schedule exchange.

TELECONTROL EQUIPMENT AND SYSTEMS –

Part 6-802: Telecontrol protocols compatible with ISO standards and ITU-T recommendations – TASE.2 Object models

1 Scope

This part of IEC 60870 specifies a method of exchanging time-critical control centre data through wide-area and local-area networks using a full ISO compliant protocol stack. It contains provisions for supporting both centralized and distributed architectures. The standard includes the exchange of real-time data indications, control operations, time series data, scheduling and accounting information, remote program control and event notification.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60870-5-101:1995, *Telecontrol equipment and systems – Part 5: Transmission protocols – Section 101: Companion standard for basic telecontrol tasks*

IEC 60870-6-503:2002, *Telecontrol equipment and systems – Part 6: Telecontrol protocols compatible with ISO standards and ITU-T recommendations – Section 503: TASE.2 Services and protocol*

ISO 9506-1:2000, *Industrial automation systems – Manufacturing message specification – Part 1: Service definition*

ISO 9506-2:2000, *Industrial automation systems – Manufacturing message specification – Part 2: Protocol specification*

3 Definitions

For the purposes of this part of IEC 60870, the definitions in the above referenced standards apply.

4 Abbreviations

For the purposes of this part of IEC 60870, all the abbreviations defined in the above referenced standards apply.