

Madalpingelised aparaadikoosted. Osa 6: Lattliinid

**Low-voltage switchgear and controlgear assemblies -
Part 6: Busbar trunking systems (busways)**

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 61439-6:2013 sisaldab Euroopa standardi EN 61439-6:2012 ingliskeelset teksti.	This Estonian standard EVS-EN 61439-6:2013 consists of the English text of the European standard EN 61439-6:2012.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 31.08.2012.	Date of Availability of the European standard is 31.08.2012.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 29.130.20

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Aru 10, 10317 Tallinn, Eesti; www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:
Aru 10, 10317 Tallinn, Estonia; www.evs.ee; phone 605 5050; e-mail info@evs.ee

**Low-voltage switchgear and controlgear assemblies -
Part 6: Busbar trunking systems (busways)**
(IEC 61439-6:2012)

Ensembles d'appareillage
à basse tension -
Partie 6: Systèmes de canalisation
préfabriquée
(CEI 61439-6:2012)

Niederspannungs-
Schaltgerätekombinationen -
Teil 6: Schienenverteilersysteme
(busways)
(IEC 61439-6:2012)

This European Standard was approved by CENELEC on 2012-06-27. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 17D/452/FDIS, future edition 1 of IEC 61439-6, prepared by IEC/TC SC 17D "Low-voltage switchgear and controlgear assemblies" of IEC TC 17 "Switchgear and controlgear" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61439-6:2012.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2013-03-27
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2015-06-27

This document supersedes EN 60439-2:2000 + A1:2005.

EN 61439-6:2012 includes the following significant technical changes with respect to EN 60439-2:2000 + A1:2005:

- alignment of the second edition of EN 61439-1:2011 regarding the structure and technical content, as applicable;
- introduction of new verifications, accordingly;
- correction of inconsistencies in resistance, reactance and impedance measurements and calculations;
- numerous editorial improvements.

This standard is to be read in conjunction with EN 61439-1:2011.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For the relationship with EU Directive see informative Annex ZZ, which is an integral part of this document.

Endorsement notice

The text of the International Standard IEC 61439-6:2012 was approved by CENELEC as a European Standard without any modification.

The Bibliography of EN 61439-1:2011 is applicable with the addition of the following notes for the standards indicated:

IEC 60570:2003	NOTE	Harmonised as EN 60570:2003 (modified).
IEC 60909-0:2001	NOTE	Harmonised as EN 60909-0:2001 (not modified).
IEC 61439 series	NOTE	Harmonised as EN 61439 series (partly modified).
IEC 61534 series	NOTE	Harmonised as EN 61534 series (not modified).

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

This clause of EN 61439-1:2011 is applicable with the addition of the following references:

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60332-3-10	2000	Tests on electric and optical fibre cables under fire conditions - Part 3-10: Test for vertical flame spread of vertically-mounted bunched wires or cables - Apparatus	EN 60332-3-10 ¹⁾	2009
IEC 60439-2	2000	Low-voltage switchgear and controlgear assemblies - Part 2: Particular requirements for busbar trunking systems (busways)	EN 60439-2	2000
IEC 61439-1	2011	Low-voltage switchgear and controlgear assemblies - Part 1: General rules	EN 61439-1	2011
IEC 61786	1998	Measurement of low-frequency magnetic and electric fields with regard to exposure of human beings - Special requirements for instruments and guidance for measurement	-	-
ISO 834-1	1999	Fire-resistance tests - Elements of building construction - Part 1: General requirements	-	-

¹⁾ EN 60332-3-10 includes A1 to IEC 60332-3-10.

Annex ZZ (informative)

Coverage of Essential Requirements of EU Directive 2004/108/EC

This European Standard has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association and within its scope the standard covers all relevant essential requirements as given in Article 1 of Annex I of the EU Directive 2004/108/EC.

Compliance with this standard provides one means of conformity with the specified essential requirements of the Directive concerned.

WARNING: Other requirements and other EU Directives may be applicable to the products falling within the scope of this standard.

CONTENTS

FOREWORD.....	3
1 Scope.....	5
2 Normative references	5
3 Terms and definitions	6
4 Symbols and abbreviations.....	8
5 Interface characteristics	8
6 Information	12
7 Service conditions	12
8 Constructional requirements.....	13
9 Performance requirements	14
10 Design verifications	15
11 Routine verifications	27
Annexes	28
Annex C (informative) Specification schedule	29
Annex D (informative) Design verification	33
Annex AA (informative) Voltage drop of the system.....	34
Annex BB (informative) Phase conductor characteristics.....	35
Annex CC (informative) Fault-loop zero-sequence impedances.....	37
Annex DD (informative) Fault-loop resistances and reactances	39
Annex EE (informative) Determination of the magnetic field in the vicinity of the BTS	41
Bibliography.....	42
Figure 101 – Mechanical load test of a straight unit	16
Figure 102 – Mechanical load test of a joint	16
Figure 103 – Test arrangement for verification of a fire-barrier BTU	27
Figure BB.1 – Phase conductors characteristics determination	35
Figure CC.1 – Fault loop zero-sequence impedances determination	37
Figure DD.1 – Fault loop resistances and reactances determination	39
Figure EE.1 – Magnetic field measurement arrangement	41
Table 101 – Rated diversity factor for a tap-off unit.....	10
Table 102 – Phase conductor characteristics	11
Table 103 – Fault-loop characteristics	11
Table 104 – Characteristics to be used for fault currents calculations	12
Table 105 – Conditioning for the thermal cycling test	18
Table C.1 – User specification schedule	29
Table D.1 – Design verifications	33

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR ASSEMBLIES –

Part 6: Busbar trunking systems (busways)

1 Scope

NOTE 1 Throughout this part, the abbreviation BTS is used for a busbar trunking system. Where reference to Part 1 is made, the term ASSEMBLY therefore reads as "BTS".

This part of IEC 61439 lays down the definitions and states the service conditions, construction requirements, technical characteristics and verification requirements for low voltage BTS (see 3.101) as follows:

- BTS for which the rated voltage does not exceed 1 000 V in case of a.c. or 1 500 V in case of d.c.;
- BTS intended for use in connection with the generation, transmission, distribution and conversion of electric energy, and for the control of electric energy consuming equipment;
- BTS designed for use under special service conditions, for example in ships, in rail vehicles, and for domestic applications (operated by unskilled persons), provided that the relevant specific requirements are complied with;

NOTE 2 Supplementary requirements for BTS in ships are covered by IEC 60092-302.

- BTS designed for electrical equipment of machines. Supplementary requirements for BTS forming part of a machine are covered by the IEC 60204 series.

This standard applies to all BTS whether they are designed, manufactured and verified on a one-off basis or fully standardized and manufactured in quantity.

The manufacture and/or assembly may be carried out by a manufacturer other than the original manufacturer (see 3.10.1 and 3.10.2 of Part 1).

This standard does not apply to individual devices and self-contained components, such as motor starters, fuse switches, electronic equipment, etc. which will comply with the relevant product standard.

This standard does not apply to the specific types of ASSEMBLIES covered by other parts of the IEC 61439 series, to supply track systems in accordance with IEC 60570, to cable trunking and ducting systems in accordance with the IEC 61084 series, nor to power track systems in accordance with the IEC 61534 series.

2 Normative references

This clause of Part 1 is applicable except as follows.

Addition:

IEC 60332-3-10:2000, *Tests on electric and optical fibre cables under fire conditions – Part 3-10: Test for vertical flame spread of vertically-mounted bunched wires or cables – Apparatus*

IEC 60439-2:2000, *Low-voltage switchgear and controlgear assemblies – Part 2: Particular requirements for busbar trunking systems (busways)*

IEC 61439-1:2011, *Low-voltage switchgear and controlgear assemblies – Part 1: General rules*

IEC 61786:1998, *Measurement of low-frequency magnetic and electric fields with regard to exposure of human beings – Special requirements for instruments and guidance for measurements*

ISO 834-1:1999, *Fire-resistance tests – Elements of building construction – Part 1: General requirements*

3 Terms and definitions

This clause of Part 1 is applicable except as follows.

Additional definitions:

3.101

busbar trunking system

BTS

busway

enclosed ASSEMBLY used to distribute and control electrical energy for all types of loads, intended for industrial, commercial and similar applications, in the form of a conductor system comprising busbars which are spaced and supported by insulating material in a duct, trough or similar enclosure

[SOURCE: IEC 60050-441:1984, 441-12-07 modified]

Note 1 to entry: See 3.1.1 of Part 1 for the definition of ASSEMBLY.

Note 2 to entry: The BTS may consist of a full range of mechanical and electrical components such as:

- busbar trunking units with or without tap-off facilities;
- phase transposition, expansion, flexible, feeder and adapter units;
- tap-off units;
- additional conductors for communication and/or control.

Note 3 to entry: The term "busbar" does not presuppose the geometrical shape, size and dimensions of the conductor.

3.102

busbar trunking unit

BTU

unit of a BTS complete with busbars, their supports and insulation, external enclosure and any fixing and connecting means to other units, with or without tap-off facilities

Note 1 to entry: BTUs may have different geometrical shapes such as straight length, elbow, tee or cross.

3.103

busbar trunking run

BT run

number of BTUs connected together to form the BTS, excluding the tap-off units

3.104

busbar trunking unit with tap-off facilities

BTU with tap-off facilities

BTU designed to enable tap-off units to be installed at one or more points as predetermined by the original manufacturer