

GAASIKÜTTEL TÖÖTAVAD ENDOTERMILISE
MOOTORIGA SOOJUSPUMBAD. OSA 2: OHUTUS

Gas-fired endothermic engine driven heat pumps - Part
2: Safety

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 16905-2:2020 sisaldab Euroopa standardi EN 16905-2:2020 ingliskeelset teksti.	This Estonian standard EVS-EN 16905-2:2020 consists of the English text of the European standard EN 16905-2:2020.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 22.01.2020.	Date of Availability of the European standard is 22.01.2020.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 27.080

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

English Version

Gas-fired endothermic engine driven heat pumps - Part 2: Safety

Pompes à chaleur à moteur endothermique alimenté
au gaz - Partie 2: Sécurité

Gasbefeuerte endothermische Motor-Wärmepumpen -
Teil 2: Sicherheit

This European Standard was approved by CEN on 4 November 2019.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents

Page

European foreword.....	4
1 Scope.....	5
1.1 Scope of EN 16905.....	5
1.2 Scope of EN 16905-2.....	5
2 Normative references.....	6
3 Terms and definitions.....	7
4 Classification.....	8
4.1 General.....	8
4.2 Classification of GEHP appliances.....	8
4.3 GEHP appliance classification according to the maximum water side operating pressure (PMS):	8
5 Design requirements.....	9
5.1 Structure.....	9
5.2 Material.....	12
5.3 EMC / electrical requirements.....	19
6 Operational requirements.....	20
6.1 General requirements.....	20
6.2 Soundness.....	20
6.3 Heat input at standard rating conditions.....	21
6.4 Limit temperatures.....	21
6.5 Limit operating conditions.....	22
6.6 Insulation resistance.....	22
6.7 Transient overvoltage.....	22
6.8 Withstand voltage.....	23
6.9 Waterproof performance.....	23
6.10 Sound power level.....	23
6.11 Engine perform.....	23
6.12 Power failure.....	25
6.13 Abnormalities.....	25
6.14 Starting current.....	25
7 Test methods.....	25
7.1 General test conditions.....	25
7.2 Soundness.....	27
7.3 Heat input at standard rating conditions.....	29
7.4 Limit temperatures.....	29
7.5 Limit operating conditions.....	30
7.6 Insulation resistance test.....	31
7.7 Transient overvoltage test.....	31
7.8 Withstand voltage test.....	31
7.9 Waterproof performance test.....	31
7.10 Sound power level test.....	32
7.11 Engine performance.....	32
7.12 Power failure test.....	33
7.13 Abnormalities test.....	33

7.14	Starting current test	33
8	Risk assessment	33
9	Marking and instructions	34
9.1	GEHP appliance marking	34
9.2	Installation instructions.....	36
9.3	User's instructions.....	38
9.4	Gas conversion instructions.....	38
9.5	Presentation	39
Annex A (informative) Calculation of conversion of NO _x		40
Annex B (normative) Engine startup test method		41
B.1	General	41
B.2	Test condition	41
B.3	Test method.....	41
Annex C (normative) CO concentration test method		42
C.1	General	42
C.2	Test condition	42
Annex D (normative) NO _x concentration test method.....		45
D.1	Definitions.....	45
D.2	General	45
Annex E (normative) Power failure test method.....		48
E.1	General	48
E.2	Test method.....	48
Annex F (informative) Examples for marking.....		49
F.1	Data-plate (see 9.1.1)	49
F.2	Additional data-plate (see 9.1.2).....	49
Annex G (informative) Examples for NO _x calculation		50
G.1	E _{rpm} equivalent calculation	50
G.2	NO _x ppm to mg/kWh conversation.....	50
G.3	Temperature and humidity correction formula calculation	50
Bibliography		51

European foreword

This document (EN 16905-2:2020) has been prepared by Technical Committee CEN/TC 299 “Gas-fired sorption appliances, indirect fired sorption appliances, gas-fired endothermic engine heat pumps and domestic gas-fired washing and drying appliances”, the secretariat of which is held by UNI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by July 2020 and conflicting national standards shall be withdrawn at the latest by July 2020.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association.

This standard comprises the following parts under the general title, *Gas-fired endothermic engine driven heat pumps*:

- *Part 1: Terms and definitions;*
- *Part 2: Safety;*
- *Part 3: Tests conditions;*
- *Part 4: Tests methods;*
- *Part 5: Calculation of seasonal performances in heating and cooling mode.*

These documents will be reviewed whenever new mandates could apply.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

1 Scope

1.1 Scope of EN 16905

This European Standard specifies the requirements, test methods and test conditions for the rating and performance calculation of air conditioners and heat pumps using either air, water or brine as heat transfer media, with gas-fired endothermic engine driven compressors when used for space heating, cooling and refrigeration, hereafter referred to as "GEHP appliance".

This European Standard only applies to GEHP appliances with a maximum heat input (based on net calorific value) not exceeding 70 kW at standard rating conditions.

This standard only applies to GEHP appliances under categories I_{2H}, I_{2E}, I_{2Er}, I_{2R}, I_{2E(S)B}, I_{2L}, I_{2LL}, I_{2ELL}, I_{2E(R)B}, I_{2ES}, I_{2E(R)}, I_{3P}, I_{3B}, I_{3B/P}, II_{2H3+}, II_{2Er3+}, II_{2H3B/P}, II_{2L3B/P}, II_{2E3B/P}, II_{2ELL3B/P}, II_{2L3P}, II_{2H3P}, II_{2E3P} and II_{2Er3P} according to EN 437:2018.

This standard only applies to GEHP appliances having:

- a) gas fired endothermic engines under the control of fully automatic control systems;
- b) closed system refrigerant circuits in which the refrigerant does not come into direct contact with the fluid to be cooled or heated;
- c) where the temperature of the heat transfer fluid of the heating system (heating water circuit) does not exceed 105 °C during normal operation;
- d) where the maximum operating pressure in the
 - 1) heating water circuit (if installed) does not exceed 6 bar
 - 2) domestic hot water circuit (if installed) does not exceed 10 bar.

This European Standard applies to GEHP appliances only when used for space heating or space cooling or for refrigeration, with or without heat recovery.

The GEHP appliances having their condenser cooled by air and by the evaporation of external additional water are not covered by this European Standard.

Packaged units, single split and multisplit systems are covered by this European Standard. Single duct and double duct units are covered by this European Standard.

The above GEHP appliances can have one or more primary or secondary functions.

This European Standard is applicable to GEHP appliances that are intended to be type tested. Requirements for GEHP appliances that are not type tested would need to be subject to further consideration.

In the case of packaged units (consisting of several parts), the standard applies only to those designed and supplied as a complete package.

NOTE All the symbols given in this text are used regardless of the language used.

1.2 Scope of EN 16905-2

This part of EN 16905 specifies the safety requirements, the safety test conditions and the safety test methods of gas-fired endothermic engine driven heat pumps for heating and/or cooling mode including the engine heat recovery.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 161, *Automatic shut-off valves for gas burners and gas appliances*

EN 378-2, *Refrigerating systems and heat pumps — Safety and environmental requirements — Part 2: Design, construction, testing, marking and documentation*

EN 437:2018, *Test gases — Test pressures — Appliance categories*

EN 549, *Rubber materials for seals and diaphragms for gas appliances and gas equipment*

EN 1561:2011, *Founding — Grey cast irons*

EN 10029, *Hot-rolled steel plates 3 mm thick or above — Tolerances on dimensions and shape*

EN 10226-1, *Pipe threads where pressure tight joints are made on the threads — Part 1: Taper external threads and parallel internal threads — Dimensions, tolerances and designation*

EN 10226-2, *Pipe threads where pressure tight joints are made on the threads — Part 2: Taper external threads and taper internal threads — Dimensions, tolerances and designation*

EN 12102-1:2017, *Air conditioners, liquid chilling packages, heat pumps, process chillers and dehumidifiers with electrically driven compressors — Determination of the sound power level — Part 1: Air conditioners, liquid chilling packages, heat pumps for space heating and cooling, dehumidifiers and process chillers*

EN 12102-2:2019, *Air conditioners, liquid chilling packages, heat pumps, process chillers and dehumidifiers with electrically driven compressors — Determination of the sound power level — Part 2: Heat pump water heaters*

EN 14800, *Corrugated safety metal hose assemblies for the connection of domestic appliances using gaseous fuels*

EN 16436-1, *Rubber and plastics hoses, tubing and assemblies for use with propane and butane and their mixture in the vapour phase — Part 1: Hoses and tubings*

EN 16905-1, *Gas-fired endothermic engine driven heat pumps — Part 1: Terms and definitions*

EN 16905-3:2017, *Gas-fired endothermic engine driven heat pumps — Part 3: Test conditions*

EN 16905-4:2017, *Gas-fired endothermic engine driven heat pumps — Part 4: Test methods*

EN 55014-1, *Electromagnetic compatibility — Requirements for household appliances, electric tools and similar apparatus — Part 1: Emission (CISPR 14-1)*

EN 55014-2, *Electromagnetic compatibility — Requirements for household appliances, electric tools and similar apparatus — Part 2: Immunity — Product family standard*

EN 60335-1, *Household and similar electrical appliances — Safety Part 1: General requirements (IEC 60335-1)*

EN 60335-2-40:2003, *Household and similar electrical appliances — Safety — Part 2-40: Particular requirements for electrical heat pumps, air-conditioners and dehumidifiers (IEC 60335-2-40:2002)*

EN 60335-2-102, *Household and similar electrical appliances — Safety — Part 2-102: Particular requirements for gas, oil and solid-fuel burning appliances having electrical connections (IEC 60335-2-102)*

EN 60529, *Degrees of protection provided by enclosures (IP Code) (IEC 60529)*

EN 61000-3-2, *Electromagnetic compatibility (EMC) — Part 3-2: Limits — Limits for harmonic current emissions (equipment input current ≤ 16 A per phase) (IEC 61000-3-2)*

EN 61000-3-3, *Electromagnetic compatibility (EMC) — Part 3-3: Limits — Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current ≤ 16 A per phase and not subject to conditional connection (IEC 61000-3-3)*

EN 61000-3-11, *Electromagnetic compatibility (EMC) — Part 3-11: Limits — Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems — Equipment with rated current ≤ 75 A and subject to conditional connection (IEC 61000-3-11)*

EN 61000-3-12, *Electromagnetic compatibility (EMC) — Part 3-12: Limits — Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current > 16 A and ≤ 75 A per phase (IEC 61000-3-12)*

EN 61000-6-1, *Electromagnetic compatibility (EMC) — Part 6-1: Generic standards — Immunity for residential, commercial and light-industrial environments (IEC 61000-6-1)*

EN 61000-6-3, *Electromagnetic compatibility (EMC) — Part 6-3: Generic standards — Emission standard for residential, commercial and light-industrial environments (IEC 61000-6-3)*

EN ISO 2553, *Welding and allied processes — Symbolic representation on drawings — Welded joints (ISO 2553)*

EN ISO 3166-1, *Codes for the representation of names of countries and their subdivisions — Part 1: Country codes (ISO 3166-1)*

EN ISO 4063, *Welding and allied processes — Nomenclature of processes and reference numbers (ISO 4063)*

EN ISO 7010, *Graphical symbols — Safety colours and safety signs — Registered safety signs (ISO 7010)*

ISO 857-2, *Welding and allied processes — Vocabulary — Part 2: Soldering and brazing processes and related terms*

ISO/TR 25901-3, *Welding and allied processes — Vocabulary — Part 3: Welding processes*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 16905-1 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>