

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Explosive atmospheres –
Part 29-1: Gas detectors – Performance requirements of detectors for flammable
gases**

**Atmosphères explosives –
Partie 29-1: Détecteurs de gaz – Exigences d'aptitude à la fonction des
détecteurs de gaz inflammables**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2007 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00



INTERNATIONAL STANDARD

NORME INTERNATIONALE

Explosive atmospheres –

Part 29-1: Gas detectors – Performance requirements of detectors for flammable gases

Atmosphères explosives –

Partie 29-1: Détecteurs de gaz – Exigences d'aptitude à la fonction des détecteurs de gaz inflammables

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

X

EXPLOSIVE ATMOSPHERES –

Part 29-1: Gas detectors – Performance requirements of detectors for flammable gases

INTERPRETATION SHEET 1

This interpretation sheet has been prepared by IEC technical committee 31: Equipment for explosive atmospheres.

The text of this interpretation sheet is based on the following documents:

ISH	Report on voting
31/809/ISH	31/817/RVD

Full information on the voting for the approval of this interpretation sheet can be found in the report on voting indicated in the above table.

There has been a request for formal interpretation of the drop test fail criterion in the performance standard IEC 60079-29-1 (2007), Subclause 5.4.14.

The fail criterion is:

“The apparatus shall be considered to have failed this test if there is a loss of function (e.g. alarm, pump function, controls, display) after the test”.

Question:

Is the interpretation of this text, that the loss of function, even in a short period during the interruption and until restart of the equipment will fail the test? Or is a permanent loss of function needed to fail the equipment, e.g. a broken display or a pump, which cannot restart?

Bouncing of a battery spring in the moment of impact can cause the drop out of power in battery supplied equipment, and make it shut down. Is this considered as sufficient to fail the test? Or would it be sufficient safe situation for the user if the equipment could restart and show the correct measurement?

Interpretation:

Any loss of function after the test including any change of state is considered a failure since there is continued dependency on the life safety device even under adverse affects such as an accidental drop of the device during use. Automatic or manual re-starting is not acceptable.

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	8
1 Scope.....	9
2 Normative references	10
3 Definitions	10
3.1 Gas properties.....	10
3.2 Types of instruments	12
3.3 Sensors.....	13
3.4 Supply of gas to instrument	13
3.5 Signals and alarms.....	13
3.6 Times	14
3.7 Miscellaneous	14
4 General requirements	15
4.1 Introduction	15
4.2 Construction	16
4.2.1 General	16
4.2.2 Indicating devices	16
4.2.3 Alarm or output functions	17
4.2.4 Fault signals	18
4.2.5 Adjustments	18
4.2.6 Battery-powered apparatus.....	18
4.2.7 Stand-alone gas detection apparatus for use with separate control units	18
4.2.8 Separate control units for use with stand-alone gas detection apparatus	19
4.2.9 Software-controlled apparatus	19
4.3 Labelling and marking	21
4.4 Instruction manual	21
5 Test methods	22
5.1 Introduction	22
5.2 General requirements for tests	22
5.2.1 Samples and sequence of tests	22
5.2.2 Preparation of apparatus before testing	23
5.2.3 Mask for calibration and tests	24
5.3 Normal conditions for test.....	24
5.3.1 General	24
5.3.2 Test gas(es)	24
5.3.3 Standard test gas	25
5.3.4 Flow rate for test gases	25
5.3.5 Voltage.....	25
5.3.6 Temperature.....	25
5.3.7 Pressure.....	25
5.3.8 Humidity	25
5.3.9 Stabilization time	26
5.3.10 Orientation	26
5.3.11 Communications options.....	26

5.3.12	Gas detection apparatus as part of systems	26
5.4	Test methods	26
5.4.1	General	26
5.4.2	Unpowered storage	26
5.4.3	Calibration and adjustment	26
5.4.4	Stability (continuous duty apparatus only).....	27
5.4.5	Stability (spot-reading apparatus only).....	28
5.4.6	Alarm set point(s)	28
5.4.7	Temperature.....	29
5.4.8	Pressure.....	29
5.4.9	Humidity	29
5.4.10	Air velocity	29
5.4.11	Flow rate for aspirated apparatus	30
5.4.12	Orientation	30
5.4.13	Vibration.....	30
5.4.14	Drop test for portable and transportable apparatus	31
5.4.15	Warm-up time.....	31
5.4.16	Time of response (not applicable to spot-reading apparatus)	32
5.4.17	Minimum time to operate (spot-reading apparatus)	32
5.4.18	High gas concentration operation above the measuring range	32
5.4.19	Battery capacity.....	33
5.4.20	Power supply variations.....	33
5.4.21	Power supply interruptions, voltage transients and step changes of voltage	34
5.4.22	Addition of sampling probe	34
5.4.23	Dust (for apparatus where the air is sampled by natural diffusion only)	34
5.4.24	Poisons and other gases	34
5.4.25	Electromagnetic immunity.....	35
5.4.26	Field calibration kit	36
5.4.27	Software verification	36
Annex A	(normative) Performance requirements	37
Annex B	(informative) Determination of time of response	42
Bibliography	49
Figure 1	– Warm-up time in clean air (typical)	15
Figure 2	– Warm-up time in standard test gas (typical)	15
Figure B.1	– Schematic example of equipment for use with aspirated apparatus.....	44
Figure B.2	– Schematic example of equipment during application of clean air or test gas	45
Figure B.3	– Schematic example of equipment showing change-over from clean air to test gas to begin the time of response measurement (arrows indicate movement of applicators).....	45

Figure B.4 – Schematic example of applicator and sensor inlet during application of test gas or clean air	46
Figure B.5 – Example of automated test chamber	47
Figure B.6 – Apparatus for step change and flooding tests.....	48
Table A.1 – Performance requirements	37

This document is a preview generated by EVS

INTERNATIONAL ELECTROTECHNICAL COMMISSION

EXPLOSIVE ATMOSPHERES –**Part 29-1: Gas detectors –
Performance requirements of detectors for flammable gases**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60079-29-1 has been prepared by IEC technical committee 31: Equipment for explosive atmospheres.

This first edition of IEC 60079-29-1 cancels and replaces the first edition of IEC 61779-1 to IEC 61779-5:1998 series and constitutes a technical revision.

The main changes with respect to the previous edition are listed below:

- Subclause 4.2.3 (Alarm or output functions) was modified to ensure alarm devices can not be adjustable outside their measuring range and to include requirements for de-activation of alarm devices.
- Subclause 4.2.7 (Stand-alone gas detection apparatus for use with separate control units) was added to allow separate evaluation of detection apparatus providing an industry recognized output signal.

- Subclause 4.2.8 (Separate control units for use with stand-alone gas detection apparatus) was added to allow separate evaluation of control unit apparatus using an industry recognized input signal.
- Subclause 4.2.9 (Software-controlled apparatus) was added to the document for improved evaluation of software. The added text is based upon the guiding principles and requirements of EN 50271.
- Subclause 4.5 (Diffusion sensors) was removed from the document based upon the redundant protection allowance for equipment used in Zone 0 areas, such as Ex d ia rated equipment.
- Subclause 5.2.1.1 was modified to require the center wavelength of the optical filters of two apparatus at the minimum and maximum limit of this standard.
- Subclause 5.2.1.2 was modified to allow the order of testing within each block to be conducted at the discretion of the test laboratory.
- Subclause 5.3.11 (Communications options) was added to ensure maximum transaction rates are applied during testing.
- Subclause 5.3.12 (Gas detection apparatus as part of systems) was added to ensure maximum transaction rates are applied during testing.
- Subclause 5.4.6 (Alarm set point(s)) was modified to include text related to alarms that are activated at decreasing concentrations.
- Subclause 5.4.10 (Air velocity) was modified to include testing at 3 m/s and 6 m/s.
- Subclause 5.4.16 (Time of response) was modified to exclude recovery time test requirements for Group II apparatus with a volume fraction up to 100 % LFL indication.
- Subclause 5.4.18 (High gas concentration operation above the measuring range) was modified to define the sequence of tests.
- Annex A (Performance requirements) has undergone major modifications by eliminating the gas/vapour table and replacing the annex with the performance requirements of Parts 2 to 5 of the former edition. Additionally, performance requirements of Parts 2 to 5 were adjusted for consistency as appropriate. The intent of this change is to condense Parts 1 to 5 within a single standard.

This part of IEC 60079-29 is to be used in conjunction with the following standards:

- IEC 60079-0, Electrical apparatus for explosive gas atmospheres – Part 0: General requirements
- IEC 60079-29-2, Explosive atmospheres – Part 29-2: Gas detectors – Selection, installation, use and maintenance of detectors for flammable gases and oxygen.

The text of this standard is based on the following documents:

FDIS	Report on voting
31/695/FDIS	31/711/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 60079 series, under the general title: *Explosive atmospheres*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INTRODUCTION

Guidance for the selection, installation, use and maintenance of gas detecting apparatus are set out in IEC 60079-29-2: Explosive atmospheres – Part 29-2: Gas detectors – Selection, installation, use and maintenance of detectors for flammable gases and oxygen.

This document is a preview generated by EVS

EXPLOSIVE ATMOSPHERES –

Part 29-1: Gas detectors – Performance requirements of detectors for flammable gases

1 Scope

This part of IEC 60079-29 specifies general requirements for construction, testing and performance, and describes the test methods that apply to portable, transportable and fixed apparatus for the detection and measurement of flammable gas or vapour concentrations with air. The apparatus, or parts thereof, are intended for use in potentially explosive atmospheres (see 3.1.8) and in mines susceptible to firedamp.

This standard is also applicable when an apparatus manufacturer makes any claims regarding any special features of construction or superior performance that exceed these minimum requirements. In these cases, all such claims should be verified and the test procedures should be extended or supplemented, where necessary, to verify the performance claimed by the manufacturer. When verifying the superior performance of one criterion, other performance criteria are not required to meet the standards minimum requirements, however, these reduced claimed performance criteria (as confirmed in the manufactures Installation Manual) should also be verified. (e.g. temperature range of 0 °C to 60 °C; 0 °C to 40 °C at $\pm 10\%$ accuracy and 40 °C to 60 °C at $\pm 15\%$ (manufacturers claimed accuracy). The additional tests should be agreed between the manufacturer and test laboratory and identified and described in the test report.

This standard is applicable to flammable gas detection apparatus intended to provide an indication, alarm or other output function; the purpose of which is to give a warning of a potential explosion hazard and in some cases, to initiate automatic or manual protective action(s).

This standard is applicable to apparatus, including the integral sampling systems of aspirated apparatus, intended to be used for commercial, industrial and non-residential safety applications.

This standard does not apply to external sampling systems, or to apparatus of laboratory or scientific type, or to apparatus used only for process control purposes. It also does not apply to open path (line of sight) area monitors. For apparatus used for sensing the presence of multiple gases, this standard applies only to the detection of flammable gas or vapour.

This standard supplements and modifies the general requirements of IEC 60079-0. Where a requirement of this standard conflicts with a requirement of IEC 60079-0, the requirement of IEC 60079-29-1 will take precedence.

NOTE 1 IEC 60079-29-1 is intended to provide for the supply of apparatus giving a level of safety and performance suitable for general purpose applications. However, for specific applications, a prospective purchaser (or an appropriate authority) may additionally require the apparatus to be submitted to particular tests or approval. For example, group I apparatus (i.e. apparatus to be used in mines susceptible to firedamp) may not be permitted to be used without the additional, prior approval of the relevant authority in mines under its jurisdiction. Such particular tests/approval are to be regarded as additional to and separate from the provisions of the standards referred to above and do not preclude certification to or compliance with these standards.

NOTE 2 All apparatus calibrated on specific gases or vapours can not be expected to correctly indicate on other gases or vapours.

NOTE 3 For the purposes of this standard, the terms "lower flammable limit (LFL)" and "lower explosive limit (LEL)" are deemed to be synonymous, and likewise the terms "upper flammable limit (UFL)" and "upper explosive limit (UEL)" are deemed to be synonymous. For ease of reference, the two abbreviations LFL and UFL may be used hereinafter to denote these two sets of terms. It should be recognized that particular authorities having jurisdiction may have overriding requirements that dictate the use of one of these sets of terms and not the other.

NOTE 4 For the purposes of this standard, the term "indicating up to a volume fraction of X %" includes apparatus with an upper limit of the measuring range equal to or less than X %.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60079-0: *Electrical apparatus for explosive gas atmospheres – Part 0: General requirements*

IEC 60079-20: *Electrical apparatus for explosive gas atmospheres – Part 20: Data for flammable gases and vapours, relating to the use of electrical apparatus*

IEC 60079-29-2, *Explosive atmospheres – Part 29-2: Gas detectors – Selection, installation, use and maintenance of detectors for flammable gases and oxygen*

IEC 61000-4-1: *Electromagnetic compatibility (EMC) – Part 4-1: Testing and measurement techniques – Overview of IEC 61000-4 series*. Basic EMC publication

IEC 61000-4-3: *Electromagnetic compatibility (EMC) – Part 4-3: Testing and measurement techniques – Radiated, radio-frequency, electromagnetic field immunity test*. Basic EMC publication

IEC 61000-4-4: *Electromagnetic compatibility (EMC) – Part 4-4: Testing and measurement techniques – Electrical fast transient/burst immunity test* – Basic EMC publication

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60079-0 and the following apply.

NOTE Additional definitions applicable to explosive atmospheres can be found in Chapter 426 of the International Electrotechnical Vocabulary (IEV) IEC 60050 (426).

3.1 Gas properties

3.1.1

ambient air

normal atmosphere surrounding the apparatus

3.1.2

clean air

air that is free of flammable gases and interfering or contaminating substances