

**Communication networks and systems
in substations - Part 7-2: Basic
communication structure for substation
and feeder equipment - Abstract
communication service interface (ACSI)**

Communication networks and systems in
substations - Part 7-2: Basic communication
structure for substation and feeder equipment -
Abstract communication service interface (ACSI)

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

<p>Käesolev Eesti standard EVS-EN 61850-7-2:2003 sisaldab Euroopa standardi EN 61850-7-2:2003 ingliskeelset teksti.</p> <p>Käesolev dokument on jõustatud 09.09.2003 ja selle kohta on avaldatud teade Eesti standardiorganisatsiooni ametlikus väljaandes.</p> <p>Standard on kättesaadav Eesti standardiorganisatsioonist.</p>	<p>This Estonian standard EVS-EN 61850-7-2:2003 consists of the English text of the European standard EN 61850-7-2:2003.</p> <p>This document is endorsed on 09.09.2003 with the notification being published in the official publication of the Estonian national standardisation organisation.</p> <p>The standard is available from Estonian standardisation organisation.</p>
----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

<p>Käsitlusala: Applies to the ACSI communication in substations and feeder applications. The ACSI provides the abstract interface describing communications between a client and a remote server; and the abstract interface for fast and reliable system-wide event distribution between an application in one device and many remote applications in different devices and for transmission of sampled measured values</p>	<p>Scope: Applies to the ACSI communication in substations and feeder applications. The ACSI provides the abstract interface describing communications between a client and a remote server; and the abstract interface for fast and reliable system-wide event distribution between an application in one device and many remote applications in different devices and for transmission of sampled measured values</p>
------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

ICS 33.200

Võtmesõnad: buildings, electrical equ, in, modelling, network control system, organization of data, power supplies, project management, signal transmission, specification (approval), specifications, stations, substation, system management, telecommunication, telecommunications

Communication networks and systems in substations
Part 7-2: Basic communication structure for substation
and feeder equipment –
Abstract communication service interface (ACSI)
(IEC 61850-7-2:2003)

Réseaux et systèmes de communication
dans les postes
Partie 7-2: Structure des communications
de base pour les postes électriques
et les équipements de lignes –
Interface abstraite des services
de communication (ACSI)
(CEI 61850-7-2:2003)

Kommunikationsnetze und -systeme
in Stationen
Teil 7-2: Grundlegende
Kommunikationsstruktur für stations- und
feldbezogene Ausrüstung –
Abstrakte Schnittstelle für
Kommunikationsdienste (ACSI)
(IEC 61850-7-2:2003)

This European Standard was approved by CENELEC on 2003-04-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Luxembourg, Malta, Netherlands, Norway, Portugal, Slovakia, Spain, Sweden, Switzerland and United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

The text of document 57/612/FDIS, future edition 1 of IEC 61850-7-2, prepared by IEC TC 57, Power system control and associated communications, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 61850-7-2 on 2003-04-01.

The following dates were fixed:

- latest date by which the EN has to be implemented
at national level by publication of an identical
national standard or by endorsement (dop) 2004-02-01
- latest date by which the national standards conflicting
with the EN have to be withdrawn (dow) 2006-04-01

Annexes designated "normative" are part of the body of the standard.

In this standard, annexes A and ZA are normative.

Annex ZA has been added by CENELEC.

Endorsement notice

The text of the International Standard IEC 61850-7-2:2003 was approved by CENELEC as a European Standard without any modification.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

This European Standard incorporates by dated or undated reference, provisions from other publications. These normative references are cited at the appropriate places in the text and the publications are listed hereafter. For dated references, subsequent amendments to or revisions of any of these publications apply to this European Standard only when incorporated in it by amendment or revision. For undated references the latest edition of the publication referred to applies (including amendments).

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC/TS 61850-2	- ¹⁾	Communication networks and systems in substations Part 2: Glossary	-	-
IEC 61850-5	- ¹⁾	Part 5: Communication requirements for functions and devices models	-	-
IEC 61850-7-1	- ¹⁾	Part 7-1: Basic communication structure for substation and feeder equipment - Principles and models	-	-
IEC 61850-7-3	- ¹⁾	Part 7-3: Basic communication structure for substation and feeder equipment - Common data classes	EN 61850-7-3	2003 ²⁾
IEC 61850-7-4	- ¹⁾	Part 7-4: Basic communication structure for substation and feeder equipment - Compatible logical node classes and data classes	EN 61850-7-4	2003 ²⁾
IEC 61850-8-1	- ¹⁾	Part 8-1: Specific communication service mapping (SCSM) - Mappings to MMS (ISO/IEC 9506 Part 1 and Part 2) and to ISO/IEC 8802-3	-	-

¹⁾ Undated reference.

²⁾ Valid edition at date of issue.

INTERNATIONAL STANDARD

IEC
61850-7-2

First edition
2003-05

**Communication networks and systems
in substations –**

**Part 7-2:
Basic communication structure
for substation and feeder equipment –
Abstract communication service interface (ACSI)**



Reference number
IEC 61850-7-2:2003(E)

Publication numbering

As from 1 January 1997 all IEC publications are issued with a designation in the 60000 series. For example, IEC 34-1 is now referred to as IEC 60034-1.

Consolidated editions

The IEC is now publishing consolidated versions of its publications. For example, edition numbers 1.0, 1.1 and 1.2 refer, respectively, to the base publication, the base publication incorporating amendment 1 and the base publication incorporating amendments 1 and 2.

Further information on IEC publications

The technical content of IEC publications is kept under constant review by the IEC, thus ensuring that the content reflects current technology. Information relating to this publication, including its validity, is available in the IEC Catalogue of publications (see below) in addition to new editions, amendments and corrigenda. Information on the subjects under consideration and work in progress undertaken by the technical committee which has prepared this publication, as well as the list of publications issued, is also available from the following:

- **IEC Web Site** (www.iec.ch)

- **Catalogue of IEC publications**

The on-line catalogue on the IEC web site (http://www.iec.ch/searchpub/cur_fut.htm) enables you to search by a variety of criteria including text searches, technical committees and date of publication. On-line information is also available on recently issued publications, withdrawn and replaced publications, as well as corrigenda.

- **IEC Just Published**

This summary of recently issued publications (http://www.iec.ch/online_news/justpub/jp_entry.htm) is also available by email. Please contact the Customer Service Centre (see below) for further information.

- **Customer Service Centre**

If you have any questions regarding this publication or need further assistance, please contact the Customer Service Centre:

Email: custserv@iec.ch
Tel: +41 22 919 02 11
Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

IEC
61850-7-2

First edition
2003-05

Communication networks and systems in substations –

Part 7-2: Basic communication structure for substation and feeder equipment – Abstract communication service interface (ACSI)

© IEC 2003 — Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembé, PO Box 131, CH-1211 Geneva 20, Switzerland
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

PRICE CODE

XH

For price, see current catalogue

CONTENTS

FOREWORD	8
INTRODUCTION	10
1 Scope	11
2 Normative references	11
3 Terms and definitions	12
4 Abbreviated terms	13
5 ACSI overview and basic concepts	14
5.1 General	14
5.2 Overview of basic information models	15
5.3 Overview of the other service models	16
5.4 Overview of ACSI services	19
5.5 Type definitions	20
5.5.1 Data attribute types	20
5.5.2 BasicTypes	21
5.5.3 Common ACSI types	22
6 SERVER class model	26
6.1 SERVER class definition	26
6.1.1 SERVER class syntax	26
6.1.2 SERVER class attributes	27
6.2 Server class services	27
6.2.1 Overview of directory and GetDefinition services	27
6.2.2 GetServerDirectory	28
7 Application association model	29
7.1 Introduction	29
7.2 Concept of application associations	29
7.3 Access control	29
7.4 TWO-PARTY-APPLICATION-ASSOCIATION (TPAA) class model	30
7.4.1 TWO-PARTY-APPLICATION-ASSOCIATION (TPAA) class definition	30
7.4.2 Two-party application association services	32
7.5 MULTICAST-APPLICATION-ASSOCIATION (MCAA) class	34
7.5.1 MULTICAST-APPLICATION-ASSOCIATION (MCAA) class definition	34
8 LOGICAL-DEVICE class model	36
8.1 LOGICAL-DEVICE class definition	36
8.1.1 LOGICAL-DEVICE class syntax	36
8.1.2 LOGICAL-DEVICE class attributes	36
8.2 LOGICAL-DEVICE class services	37
8.2.1 GetLogicalDeviceDirectory	37
9 LOGICAL-NODE class model	38
9.1 LOGICAL-NODE class definition	38
9.1.1 LOGICAL-NODE class syntax	38
9.1.2 LOGICAL-NODE class attributes	38
9.2 LOGICAL-NODE class services	40
9.2.1 Overview	40
9.2.2 GetLogicalNodeDirectory	40
9.2.3 GetAllDataValues	41

10	DATA class model.....	42
10.1	General	42
10.2	DATA class definition	42
10.2.1	DATA class syntax	42
10.2.2	DATA class attributes.....	45
10.3	Relation of DATA, common DATA, and compatible DATA classes	52
10.4	DATA class services	52
10.4.1	General definitions and overview	52
10.4.2	GetDataValues.....	53
10.4.3	SetDataValues	54
10.4.4	GetDataDirectory	55
10.4.5	GetDataDefinition.....	56
11	DATA-SET class model.....	56
11.1	General	56
11.2	DATA-SET class definition	58
11.2.1	DATA-SET class syntax	58
11.2.2	DATA-SET class attributes	58
11.3	DATA-SET class services	59
11.3.1	Overview.....	59
11.3.2	GetDataSetValues.....	59
11.3.3	SetDataSetValues	60
11.3.4	CreateDataSet	61
11.3.5	DeleteDataSet.....	61
11.3.6	GetDataSetDirectory	62
12	Substitution model	63
13	SETTING-GROUP-CONTROL-BLOCK class model.....	65
13.1	General	65
13.2	SGCB class definition	66
13.2.1	SGCB class syntax.....	66
13.2.2	SGCB class attributes	67
13.3	SGCB class services.....	68
13.3.1	Overview.....	68
13.3.2	SelectActiveSG	68
13.3.3	SelectEditSG.....	69
13.3.4	SetSGValues	70
13.3.5	ConfirmEditSGValues.....	71
13.3.6	GetSGValues	71
13.3.7	GetSGCBValues	72
14	REPORT-CONTROL-BLOCK and LOG-CONTROL-BLOCK class models	74
14.1	Overview	74
14.2	REPORT-CONTROL-BLOCK class model	76
14.2.1	Basic concepts.....	76
14.2.2	BUFFERED-REPORT-CONTROL-BLOCK (BRCB) class definition.....	76
14.2.3	BRCB class services	82
14.2.4	UNBUFFERED-REPORT-CONTROL-BLOCK (URCB) class definition.....	94
14.2.5	URCB class services	95
14.3	LOG-CONTROL-BLOCK class model	96
14.3.1	General.....	96
14.3.2	LCB class definition.....	97

14.3.3	LOG class definition	101
14.3.4	Procedures to generate the log entries	104
14.3.5	LOG services	104
15	Generic substation event class model (GSE)	107
15.1	Overview	107
15.2	GOOSE-CONTROL-BLOCK (GoCB) class.....	109
15.2.1	GoCB definition	109
15.2.2	GOOSE service Definitions	111
15.2.3	Generic object oriented substation event (GOOSE) message.....	116
15.3	Generic substation state event (GSSE) control block (GsCB).....	117
15.3.1	GsCB class definition	117
15.3.2	Generic substation state event (GSSE) control block class attributes	119
15.3.3	GSSE service definitions	120
15.3.4	Generic substation state event (GSSE) message.....	124
16	Transmission of sampled value class model	126
16.1	Overview	126
16.2	Transmission of sampled values using multicast.....	127
16.2.1	MSVCB class definition	127
16.2.2	Multicast sampled value class services.....	129
16.3	Transmission of sampled values using unicast	132
16.3.1	USVCB class definition.....	132
16.3.2	Unicast sampled value services.....	134
16.4	Sampled value format	137
16.4.1	MsvID or UsvID	138
16.4.2	OptFlds.....	138
16.4.3	DatSet	138
16.4.4	Sample [1..n].....	138
16.4.5	SmpCnt.....	138
16.4.6	RefrTm	139
16.4.7	ConfRev.....	139
16.4.8	SmpSynch.....	139
16.4.9	SmpRate.....	139
17	CONTROL class model	139
17.1	Introduction.....	139
17.2	Control with normal security	140
17.2.1	Direct control with normal security	140
17.2.2	SBO control with normal security.....	141
17.3	Control with enhanced security.....	143
17.3.1	Introduction.....	143
17.3.2	Direct control with enhanced security.....	143
17.3.3	SBO control with enhanced security.....	144
17.4	Time-activated operate	146
17.5	CONTROL class service definitions.....	147
17.5.1	Overview.....	147
17.5.2	Service parameter definition	148
17.5.3	Service specification	150
18	Time and time-synchronization model.....	154
18.1	General	154
18.2	External information	154

19	Naming conventions	155
19.1	Class naming and class specializations	155
19.2	Referencing an instance of a class	156
19.3	Scope	158
20	File transfer	159
20.1	File transfer model	159
20.1.1	FileName	159
20.1.2	FileSize [0..1]	159
20.1.3	LastModified	159
20.2	File services	160
20.2.1	GetFile	160
20.2.2	SetFile	160
20.2.3	DeleteFile	161
20.2.4	GetFileAttributeValues	162
	Annex A (normative) ACSI conformance statement	163
A.1	General	163
A.2	ACSI models conformance statement	164
A.3	ACSI service conformance statement	165
	Bibliography	169
	Index	170
	Figure 1 – Excerpt of conceptual model	15
	Figure 2 – Basic conceptual class model of the ACSI	16
	Figure 3 – Conceptual service model of the ACSI	17
	Figure 4 – Data attribute type concept	20
	Figure 5 – Overview about GetDirectory and GetDefinition services	27
	Figure 6 – Access views of a server	30
	Figure 7 – Normal operation	31
	Figure 8 – Aborting association	31
	Figure 9 – Principle of multicast application association	35
	Figure 10 – Class diagram of DATA and DataAttributeType	43
	Figure 11 – Example of DATA	44
	Figure 12 – Relation of TrgOp and Reporting	50
	Figure 13 – Relation of DATA classes	52
	Figure 14 – Excerpt of data class services	53
	Figure 15 – Dynamic creation of data set instances	57
	Figure 16 – Principles of substitution	64
	Figure 17 – Basic model of the settings model	65
	Figure 18 – Setting group state machine	67
	Figure 19 – Basic building blocks for reporting and logging	75
	Figure 20 – BRCB state machine	78

Figure 21 – Buffer time	80
Figure 22 – Report example on the use of sequence number	84
Figure 23 – Data set members and reporting	86
Figure 24 – Report example.....	87
Figure 25 – Log model overview	96
Figure 26 – GoCB model	108
Figure 27 – Specifics for GsCB model.....	118
Figure 28 – Model for transmission of sampled values	126
Figure 29 – Principle of the control model	140
Figure 30 – State machine of direct control with normal security.....	141
Figure 31 – Direct control with normal security	141
Figure 32 – State machine of SBO control with normal security	142
Figure 33 – State machine of direct control with enhanced security	143
Figure 34 – State machine SBO control with enhanced security	144
Figure 35 – Select before operate with enhanced security – positive case	145
Figure 36 – Select before operate with enhanced security – negative case (no status change).....	145
Figure 37 – Time-activated operate	147
Figure 38 – Time model and time synchronization (principle).....	154
Figure 39 – Specializations	155
Figure 40 – Object names and object reference	158
Table 1 – ACSI classes	19
Table 2 – BasicTypes	21
Table 3 – ObjectName type	22
Table 4 – ObjectReference type.....	22
Table 5 – ServiceError type	23
Table 6 – PACKED-LIST type	23
Table 7 – TimeStamp type	24
Table 8 – TimeQuality definition.....	24
Table 9 – TimeAccuracy	25
Table 10 – TriggerConditions type	26
Table 11 – SERVER class definition	26
Table 12 – TWO-PARTY-APPLICATION-ASSOCIATION (TPAA) class definition.....	31
Table 13 – MULTICAST-APPLICATION-ASSOCIATION (MCAA) class definition	35
Table 14 – LOGICAL-DEVICE (LD) class definition	36
Table 15 – LOGICAL-NODE (LN) class definition	38
Table 16 – DATA class definition	45
Table 17 – DAType definition	46
Table 18 – Functional constraints	48
Table 19 – Trigger option.....	49
Table 20 – COMMON-DATA class definition	51
Table 21 – DATA-SET (DS) class definition	58

Table 22 – SGCB class definition.....	66
Table 23 – BRCB class definition.....	77
Table 24 – Report format specification.....	83
Table 25 – URCB class definition.....	94
Table 26 – LCB class definition.....	97
Table 27 – LOG class definition	102
Table 28 – GOOSE control block class definition	109
Table 29 – GOOSE message definition.....	116
Table 30 – GSSE control block class definition	118
Table 31 – GSSE message definition.....	125
Table 32 – MSVCB class definition	127
Table 33 – USVCB class definition.....	132
Table 34 – Sampled value (SV) format definition.....	138
Table 35 – Control services	147
Table 36 – Control time-stamp definition.....	148
Table 37 – Test status definition	148
Table 38 – Check condition definition.....	148
Table 39 – Additional cause diagnosis definition	149
Table 40 – AddCause semantic	149
Table 41 – TimeActivatedOperate response definition.....	150
Table 42 – List of ObjectReferences	156
Table 43 – FILE class definition.....	159
Table A.1 – Basic conformance statement	163
Table A.2 – ACSI models conformance statement.....	164
Table A.3 – ACSI service conformance statement.....	165

INTERNATIONAL ELECTROTECHNICAL COMMISSION

COMMUNICATION NETWORKS AND SYSTEMS IN SUBSTATIONS –**Part 7-2: Basic communication structure
for substation and feeder equipment –
Abstract communication service interface (ACSI)**

FOREWORD

- 1) The IEC (International Electrotechnical Commission) is a worldwide organisation for standardisation comprising all national electrotechnical committees (IEC National Committees). The object of the IEC is to promote international co-operation on all questions concerning standardisation in the electrical and electronic fields. To this end and in addition to other activities, the IEC publishes International Standards. Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organisations liaising with the IEC also participate in this preparation. The IEC collaborates closely with the International Organisation for Standardisation (ISO) in accordance with conditions determined by agreement between the two organisations.
- 2) The formal decisions or agreements of the IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested National Committees.
- 3) The documents produced have the form of recommendations for international use and are published in the form of standards, technical specifications, technical reports or guides and they are accepted by the National Committees in that sense.
- 4) In order to promote international unification, IEC National Committees undertake to apply IEC International Standards transparently to the maximum extent possible in their national and regional standards. Any divergence between the IEC Standard and the corresponding national or regional standard shall be clearly indicated in the latter.
- 5) The IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with one of its standards.
- 6) Attention is drawn to the possibility that some of the elements of this International Standard may be the subject of patent rights. The IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61850-7-2 has been prepared by IEC technical committee 57: Power system control and associated communications.

The text of this standard is based on the following documents:

FDIS	Report on voting
57/612/FDIS	57/629/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

IEC 61850 consists of the following parts, under the general title *Communication networks and systems in substations*:

- Part 1: Introduction and overview ¹
- Part 2: Glossary ¹
- Part 3: General requirements
- Part 4: System and project management

¹ To be published.

- Part 5: Communication requirements for functions and device models ²
- Part 6: Configuration description language for communication in electrical substations related to IEDs ²
- Part 7-1: Basic communication structure for substation and feeder equipment – Principles and models
- Part 7-2: Basic communication structure for substation and feeder equipment – Abstract communication service interface (ACSI)
- Part 7-3: Basic communication structure for substation and feeder equipment – Common data classes
- Part 7-4: Basic communication structure for substation and feeder equipment – Compatible logical node classes and data classes
- Part 8-1: Specific communication service mapping (SCSM) – Mappings to MMS (ISO/IEC 9506-1 and ISO/IEC 9506-2) and to ISO/IEC 8802-3 ²
- Part 9-1: Specific communication service mapping (SCSM) – Sampled values over serial unidirectional multidrop point to point link
- Part 9-2: Specific communication service mapping (SCSM) – Sampled values over ISO/IEC 8802-3 ²
- Part 10: Conformance testing ²

The committee has decided that the contents of this publication will remain unchanged until 2005. At this date the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition; or
- amended.

A bilingual version of this publication may be issued at a later date.

² To be published.

INTRODUCTION

This document is part of a set of specifications which details a layered substation communication architecture. This architecture has been chosen to provide abstract definitions of classes and services such that the specifications are independent of specific protocol stacks, implementations, and operating systems.

The IEC 61850 series is intended to provide interoperability between a variety of substation and feeder devices. Communication between these devices is achieved by the definition of a hierarchical class model (for example, logical device, logical node, data, data set, report control, or log) and services provided by these classes (for example, get, set, report, define, delete) in parts IEC 61850-7-x.

This part of IEC 61850 defines the abstract communication service interface (ACSI) for use in the utility substation domain that require real-time cooperation of intelligent electronic devices. The ACSI has been defined so as to be independent of the underlying communication systems. Specific communication service mappings³ (SCSM) are specified in part 8-x and part 9-x of this standard.

This part of IEC 61850 defines the abstract communication service interface in terms of

- a hierarchical class model of all information that can be accessed via a communication network,
- services that operate on these classes, and
- parameters associated with each service.

The ACSI description technique abstracts away from all the different approaches to implement the cooperation of the various devices.

NOTE 1 Abstraction in ACSI has two meanings. First, only those aspects of a real device (for example, a breaker) or a real function that are visible and accessible over a communication network are modelled. This abstraction leads to the hierarchical class models and their behaviour defined in IEC 61850-7-2, IEC 61850-7-3, and IEC 61850-7-4. Second, the ACSI abstracts from the aspect of concrete definitions on how the devices exchange information; only a conceptual cooperation is defined. The concrete information exchange is defined in the SCSMs.

NOTE 2 This part of IEC 61850 does not provide comprehensive tutorial material. It is recommended that IEC 61850-5 and IEC 61850-7-1 be read first in conjunction with IEC 61850-7-2 and IEC 61850-7-3.

NOTE 3 Examples use names of classes (e.g. XCBR for a class of a logical node) defined in IEC 61850-7-4 and IEC 61850-7-3. The normative names are defined in IEC 61850-7-4 and IEC 61850-7-3 only.

³ The ACSI is independent of the specific mapping. Mappings to standard application layers or middle ware technologies are possible.

COMMUNICATION NETWORKS AND SYSTEMS IN SUBSTATIONS –

Part 7-2: Basic communication structure for substation and feeder equipment – Abstract communication service interface (ACSI)

1 Scope

This part of IEC 61850 applies to the ACSI communication in substations and feeder applications. The ACSI provides the following abstract interfaces.

- a) Abstract interface describing communications between a client and a remote server for
 - real-time data access and retrieval,
 - device control,
 - event reporting and logging,
 - publisher/subscriber,
 - self-description of devices (device data dictionary),
 - data typing and discovery of data types, and
 - file transfer.
- b) Abstract interface for fast and reliable system-wide event distribution between an application in one device and many remote applications in different devices (publisher/subscriber) and for transmission of sampled measured values (publisher/subscriber).

This part of IEC 61850 may also be applied to describe device models and functions for additional activities, such as:

- substation to substation information exchange,
- substation to control centre information exchange,
- power plant to control centre information exchange,
- information exchange for distributed generation, or
- information exchange for metering.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61850-2, *Communication networks and systems in substations – Part 2: Glossary*

IEC 61850-5, *Communication networks and systems in substations – Part 5: Communication requirements for functions and devices models*

IEC 61850-7-1, *Communication networks and systems in substations – Part 7-1: Basic communication structure for substation and feeder equipment – Principles and models*

IEC 61850-7-3, *Communication networks and systems in substations – Part 7-3: Basic communication structure for substation and feeder equipment – Common data classes*

IEC 61850-7-4, *Communication networks and systems in substations – Part 7-4: Basic communication structure for substation and feeder equipment – Compatible logical node classes and data classes*

IEC 61850-8-1: *Communication networks and systems in substations – Part 8-1: Specific communication service mapping (SCSM) – Mappings to MMS (ISO/IEC 9506-1 and ISO/IEC 9506-2) and to ISO/IEC 8802-3*

3 Terms and definitions

For the purpose of this document, the terms and definitions provided in IEC 61850-2 and the following definitions apply.

3.1

class

description of a set of objects that share the same attributes, services, relationships, and semantics

3.2

client

entity that requests a service from a server and that receives unsolicited messages from a server

3.3

device

entity that performs control, actuating and/or sensing functions and interfaces to other such entities within an automation system

NOTE Devices alone do not perform energy transport functions.

3.4

external equipment

entity that is stand-alone, or interfaces to an automation system, and that performs energy transport functions

EXAMPLE Transformer, circuit-breaker, line.

NOTE 1 Equipment can contain devices.

NOTE 2 Equipment cannot have a direct connection to the communication network – only devices can be directly connected to the communication network.

3.5

instance (of a class)

entity that has unique identity, to which a set of services can be applied, and which has a state that stores the effects of the services

NOTE Instance is a synonym for the term object.

3.6

Logical device

entity that represents a set of typical substation functions

3.7

Logical node

entity that represents a typical substation function