

# INTERNATIONAL STANDARD

## NORME INTERNATIONALE

**Uninterruptible power systems (UPS) –  
Part 1: General and safety requirements for UPS**

**Alimentations sans interruption (ASI) –  
Partie 1: Exigences générales et règles de sécurité pour les ASI**



## THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2008 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland  
Email: [inmail@iec.ch](mailto:inmail@iec.ch)  
Web: [www.iec.ch](http://www.iec.ch)

### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: [www.iec.ch/searchpub](http://www.iec.ch/searchpub)

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: [www.iec.ch/online\\_news/justpub](http://www.iec.ch/online_news/justpub)

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: [www.iec.ch/webstore/custserv](http://www.iec.ch/webstore/custserv)

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: [csc@iec.ch](mailto:csc@iec.ch)

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

### A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

### A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: [www.iec.ch/searchpub/cur\\_fut-f.htm](http://www.iec.ch/searchpub/cur_fut-f.htm)

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: [www.iec.ch/online\\_news/justpub](http://www.iec.ch/online_news/justpub)

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: [www.electropedia.org](http://www.electropedia.org)

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: [www.iec.ch/webstore/custserv/custserv\\_entry-f.htm](http://www.iec.ch/webstore/custserv/custserv_entry-f.htm)

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: [csc@iec.ch](mailto:csc@iec.ch)

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00



# INTERNATIONAL STANDARD

## NORME INTERNATIONALE

**Uninterruptible power systems (UPS) –  
Part 1: General and safety requirements for UPS**

**Alimentations sans interruption (ASI) –  
Partie 1: Exigences générales et règles de sécurité pour les ASI**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

PRICE CODE  
CODE PRIX

## CONTENTS

FOREWORD.....	6
1 Scope and specific applications.....	8
1.1 Scope.....	8
1.2 Specific applications.....	8
2 Normative references .....	9
3 Terms and definitions .....	10
3.1 General definitions .....	10
3.2 UPS electrical ratings .....	11
3.3 Load types .....	11
3.4 Connection to the supply .....	12
3.5 Circuits and circuit characteristics .....	12
3.6 Insulation .....	12
3.7 Equipment mobility .....	12
3.8 Insulation classes of UPS .....	12
3.9 Earth fault .....	12
3.10 Enclosures .....	12
3.11 Accessibility .....	12
3.12 Components .....	12
3.13 Power distribution.....	12
3.14 Flammability.....	12
3.15 Miscellaneous .....	12
3.16 Clearances and creepage distances .....	12
3.17 Telecommunication networks .....	13
4 General conditions for tests .....	13
4.1 Introduction .....	13
4.2 Type test .....	13
4.3 Operating parameters for tests .....	13
4.4 UPS loading during tests .....	14
4.5 Components .....	14
4.6 Power interfaces .....	14
4.7 Markings and instructions .....	15
4.7.1 General .....	15
4.7.2 Power rating .....	15
4.7.3 Safety instructions .....	15
4.7.4 Main voltage adjustment .....	17
4.7.5 Power outlets .....	17
4.7.6 Fuses .....	17
4.7.7 Wiring terminals .....	17
4.7.8 Battery terminals .....	17
4.7.9 Controls and indicators .....	18
4.7.10 Isolation of multiple power sources .....	18
4.7.11 IT power systems .....	18
4.7.12 Protection in building installation .....	18
4.7.13 High leakage current .....	18
4.7.14 Thermostats and other regulating devices .....	18
4.7.15 Language .....	18

4.7.16	Durability of markings .....	18
4.7.17	Removable parts .....	18
4.7.18	Replaceable batteries .....	19
4.7.19	Operator access with a tool .....	19
4.7.20	Battery .....	19
4.7.21	Installation instructions .....	20
5	Fundamental design requirements .....	20
5.1	Protection against electric shock and energy hazards .....	20
5.1.1	Protection for UPS intended to be used in operator access areas .....	20
5.1.2	Protection for UPS intended to be used in service access areas .....	21
5.1.3	Protection for UPS intended to be used in restricted access areas .....	21
5.1.4	Backfeed protection .....	21
5.1.5	Emergency switching (disconnect) device .....	22
5.2	Requirements for auxiliary circuits .....	22
5.2.1	Safety extra low voltage circuits – SELV .....	22
5.2.2	Telephone network voltage circuits – TNV .....	22
5.2.3	Limited current circuits .....	22
5.2.4	External signalling circuits .....	22
5.2.5	Limited power source .....	22
5.3	Protective earthing and bonding .....	22
5.3.1	General .....	22
5.3.2	Protective earthing .....	23
5.3.3	Protective bonding .....	23
5.4	AC and d.c. power isolation .....	24
5.4.1	General .....	24
5.4.2	Disconnect devices .....	24
5.5	Overcurrent and earth fault protection .....	24
5.5.1	General .....	24
5.5.2	Basic requirements .....	24
5.5.3	Battery circuit protection .....	25
5.6	Protection of personnel – Safety interlocks .....	25
5.6.1	Operator protection .....	25
5.6.2	Service person protection .....	26
5.7	Clearances, creepage distances and distances through insulation .....	27
6	Wiring, connections and supply .....	27
6.1	General .....	27
6.1.1	Introduction .....	27
6.1.2	Dimensions and ratings of busbars and insulated conductors .....	28
6.2	Connection to power .....	28
6.2.1	General provisions for connection to power .....	28
6.2.2	Means of connection .....	28
6.3	Wiring terminals for external power conductors .....	28
7	Physical requirements .....	29
7.1	Enclosure .....	29
7.2	Stability .....	29
7.3	Mechanical strength .....	29
7.4	Construction details .....	29
7.4.1	Introduction .....	29
7.4.2	Openings .....	30

7.4.3	Gas concentration .....	30
7.4.4	Equipment movement .....	30
7.5	Resistance to fire .....	30
7.6	Battery location .....	30
7.6.1	Battery location and installation .....	30
7.6.2	Accessibility and maintainability .....	31
7.6.3	Distance .....	31
7.6.4	Case insulation .....	31
7.6.5	Wiring .....	31
7.6.6	Electrolyte spillage .....	31
7.6.7	Ventilation .....	31
7.6.8	Charging voltages .....	32
7.7	Temperature rise .....	32
8	Electrical requirements and simulated abnormal conditions .....	33
8.1	General provisions for earth leakage .....	33
8.2	Electric strength .....	33
8.3	Abnormal operating and fault conditions .....	33
8.3.1	General .....	33
8.3.2	Simulation of faults .....	34
8.3.3	Conditions for tests .....	34
9	Connection to telecommunication networks .....	35
Annex A (normative)	Tests for resistance to heat and fire .....	36
Annex B (normative)	Motor tests under abnormal conditions .....	37
Annex C (normative)	Transformers .....	38
Annex D (normative)	Measuring instruments for touch current tests .....	39
Annex E (normative)	Temperature rise of a winding .....	40
Annex F (normative)	Measurements of clearances and creepage distances .....	41
Annex G (normative)	Alternative method for determining minimum clearances .....	42
Annex H (informative)	Guidance on protection against ingress of water and foreign objects .....	43
Annex I (normative)	Backfeed protection test .....	45
Annex J (informative)	Table of electrochemical potentials .....	48
Annex K (normative)	Thermal controls .....	49
Annex L (normative)	Reference loads .....	50
Annex M (normative)	Ventilation of battery compartments .....	54
Annex N (normative)	Minimum and maximum cross-sections of copper conductors suitable for connection (see 6.3) .....	57
Annex O (informative)	Guidance for disconnection of batteries during shipment .....	58
Bibliography	.....	60
Figure I.1	– Test circuit for load-induced change of reference potential – single-phase output .....	46
Figure I.2	– Test circuit for load-induced change of reference potential – three-phase output .....	46
Figure O.1	– Precautionary label for products shipped with the battery disconnected .....	58
Figure O.2	– Precautionary label for products shipped with the battery connected .....	59

Table 1 – Temperature limits .....	32
Table 2 – Permitted temperature limits for magnetic windings at the end of stored energy mode of operation .....	33
Table H.1 – Degrees of protection against foreign objects indicated by the first characteristic numeral .....	43
Table H.2 – Degrees of protection against water indicated by the second characteristic numeral .....	44
Table N.1 – Conductor cross-sections (extract from IEC 60439-1) .....	57

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

**UNINTERRUPTIBLE POWER SYSTEMS (UPS) –****Part 1: General and safety requirements for UPS**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62040-1 has been prepared by subcommittee 22H: Uninterruptible power systems (UPS), of IEC technical committee 22: Power electronic systems and equipment.

This standard cancels and replaces the first edition of IEC 62040-1-1, published in 2004 and IEC 62040-1-2, published in 2004 and constitutes a technical revision. This standard merges all requirements of previous IEC 62040-1-1 and IEC 62040-1-2, with the addition of the following:

- update of normative references including IEC 60950-1 as Reference Document (RD);
- harmonization and alignment with current world recognized best practices;
- enhancement of backfeed protection, definition of ground-fault, revision of temperature rise tables and of hydrogen concentration in battery compartments.



The text of this standard is based on the following documents:

FDIS	Report on voting
22H/104/FDIS	22H/106/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

It is to be used with IEC 60950-1, Edition 2.0, which is referred to in this standard as "RD".

In this standard, the following print types are used:

- requirements proper and normative annexes: in roman type;
- compliance statements and test specifications: *in italic type*;
- notes and other informative matter: in smaller roman type;
- normative conditions within tables: in smaller roman type;
- terms that are defined in Clause 3: **bold**.

A list of all parts of the IEC 62040 series, under the general title: *Uninterruptible power systems (UPS)*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

The contents of the corrigendum of September 2008 have been included in this copy.

# UNINTERRUPTIBLE POWER SYSTEMS (UPS) –

## Part 1: General and safety requirements for UPS

### 1 Scope and specific applications

#### 1.1 Scope

This part of IEC 62040 applies to **uninterruptible power systems (UPS)** with an electrical energy storage device in the d.c. link. It is used with IEC 60950-1, which is referred to in this standard as "RD" (reference document).

NOTE **UPS** applications generally make use of a chemical battery as the energy storage device. Alternative devices may be suitable, and as such, where "battery" appears in the text of this standard, where applicable, this may be understood as "energy storage device".

When a clause is referred to by the phrase "The definitions or the provisions of item/RD apply", this phrase is intended to mean that the definitions or provisions in that clause of IEC 60950-1 apply, except any which are clearly inapplicable to **uninterruptible power systems**. National requirements additional to those in IEC 60950-1 apply and are found as notes under relevant clauses of the RD.

The primary function of the **UPS** covered by this standard is to ensure continuity of an alternating power source. The **UPS** may also serve to improve the quality of the power source by keeping it within specified characteristics.

This standard is applicable to **UPS** which are movable, stationary, fixed or for building-in, for use in low-voltage distribution systems and intended to be installed in any **operator** accessible area or in **restricted access locations** as applicable. It specifies requirements to ensure safety for the **operator** and layman who may come into contact with the equipment and, where specifically stated, for the **service person**.

This standard is intended to ensure the safety of installed **UPS**, both as a single **UPS** unit or as a system of interconnected **UPS** units, subject to installing, operating and maintaining the **UPS** in the manner prescribed by the manufacturer.

This standard does not cover **UPS** based on rotating machines.

Electromagnetic compatibility (EMC) requirements and definitions are given in IEC 62040-2.

#### 1.2 Specific applications

Even if this standard does not cover all types of **UPS**, it may be taken as a guide for such equipment. Requirements additional to those specified in this standard may be necessary for specific applications, e.g. related to **UPS** that operate:

- while exposed to extremes of temperature; to excessive dust, moisture, or vibration; to flammable gases; to corrosive or to explosive atmospheres;
- where ingress of water and foreign objects are possible;

NOTE 1 Annex H provides guidance on such requirements and on relevant testing.

- in vehicles, on board ships or aircraft, in tropical countries, or at elevations greater than 1 000 m;

NOTE 2 Guidance for performance of **UPS** operating at elevations greater than 1 000 m is provided in 4.1.1 of IEC 62040-3.

- with trapezoidal output waveforms and long run times (greater than 30 min);

NOTE 3 In addition to complying with 5.3.1.2 of IEC 62040-3, voltage distortion tests for the purpose of load compatibility should also be performed.

- subject to transient overvoltages exceeding those of overvoltage category II according to IEC 60664;

NOTE 4 Subclause G.2.1/RD provides guidance for additional protection against transient overvoltages at the mains supply to the **UPS**. Where such additional protection is an integral part of the equipment insulation requirements, creepage distances and clearance distances from the mains through to the load side of the additional protection may be judged as category III or IV as required. All further downstream insulation requirements, creepage distances, and clearance distances on the load side of the additional protection may be judged as category I or II as required.

- in electromedical applications with the **UPS** located within 1,5 m of the patient contact area;
- in systems classified as emergency power systems by an authority having jurisdiction.

NOTE 5 Additional requirements may also apply in accordance with local regulations.

## 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60364-4-42, *Electrical installations of buildings – Part 4-42: Protection for safety – Protection against thermal effects*

IEC 60417, *Graphical symbols for use on equipment*

IEC 60529, *Degrees of protection provided by enclosures (IP Code)*

IEC 60664 (all parts), *Insulation coordination for equipment within low-voltage systems*

IEC 60755, *General requirements for residual current operated protective devices*

IEC 60950-1:2005, *Information technology equipment – Safety – Part 1: General requirements*

IEC 61000-2-2, *Electromagnetic compatibility (EMC) – Part 2-2: Environment – Compatibility levels for low-frequency conducted disturbances and signaling in public low-voltage power supply systems*

IEC 61008-1, *Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCBs) – Part 1: General rules*

IEC 61009-1, *Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs) – Part 1: General rules*

IEC 62040-2:2005, *Uninterruptible power systems (UPS) – Part 2: Electromagnetic compatibility (EMC) requirements*

IEC 62040-3:1999, *Uninterruptible power systems (UPS) – Part 3: Method of specifying the performance and test requirements*