### **EESTI STANDARD**

7:500

Elektrimõõteseadmed. Usaldatavus. Osa 32-1: Vastupidavus. Metroloogiliste omaduste stabiilsuse kontroll kõrgema temperatuuri oludes

Electricity metering equipment - Dependability - Part 32-1: Durability - Testing of the stability of metrological characteristics by applying elevated temperature



#### EESTI STANDARDI EESSÕNA

#### NATIONAL FOREWORD

See Eesti standard EVS-EN 62059-32-1:2012 sisaldab Euroopa standardi EN 62059-32-1:2012	This Estonian standard EVS-EN 62059-32-1:2012 consists of the English text of the European standard		
ingliskeelset teksti.	EN 62059-32-1:2012.		
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.		
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 23.03.2012.	Date of Availability of the European standard is 23.03.2012.		
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.		
17			

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile <u>standardiosakond@evs.ee</u>.

ICS 17.220, 19.020, 91.140.50

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega: Aru 10, 10317 Tallinn, Eesti; <u>www.evs.ee</u>; telefon 605 5050; e-post <u>info@evs.ee</u>

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation: Aru 10, 10317 Tallinn, Estonia; www.evs.ee; phone 605 5050; e-mail info@evs.ee

# EUROPEAN STANDARD

### EN 62059-32-1

NORME EUROPÉENNE EUROPÄISCHE NORM

March 2012

ICS 17.220; 19.020; 91.140.50

English version

#### Electricity metering equipment -Dependability -Part 32-1: Durability -Testing of the stability of metrological characteristics by applying elevated temperature (IEC 62059 32 1:2011)

(IEC 62059-32-1:2011)

Appareils de comptage d'électricité -Sûreté de fonctionnement -Partie 32-1: Durabilité -Contrôle de stabilité des caractéristiques métrologiques en appliquant une température élevée (CEI 62059-32-1:2011) Elektrizitätszähler -Zuverlässigkeit -Teil 32-1: Haltbarkeit -Prüfung der Stabilität der metrologischen Eigenschaften unter Anwendung erhöhter Temperatur (IEC 62059-32-1:2011)

This European Standard was approved by CENELEC on 2012-01-11. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

# CENELEC

European Committee for Electrotechnical Standardization Comité Européen de Normalisation Electrotechnique Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

© 2012 CENELEC - All rights of exploitation in any form and by any means reserved worldwide for CENELEC members.

#### Foreword

The text of document 13/1483/FDIS, future edition 1 of IEC 62059-32-1, prepared by IEC/TC 13, "Electrical energy measurement, tariff- and load control", was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 62059-32-1:2012.

The following dates are fixed:

•	latest date by which the document has	(dop)	2012-10-11
	to be implemented at national level by		
	publication of an identical national		
	standard or by endorsement		
•	latest date by which the national	(dow)	2015-01-11
	standards conflicting with the		
	document have to be withdrawn		

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For the relationship with EU Directive(s) see informative Annex ZZ, which is an integral part of this document.

#### **Endorsement notice**

The text of the International Standard IEC 62059-32-1:2011 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 62053-11:2003 NOTE	Harmonized as EN 62053-11:2003 (not modified).
IEC 62053-22:2003 NOTE	Harmonized as EN 62053-22:2003 (not modified).
IEC 62053-23:2003 NOTE	Harmonized as EN 62053-23:2003 (not modified).
IEC 62055-31:2005 NOTE	Harmonized as EN 62055-31:2005 ((not modified).

#### Annex ZA

#### (normative)

## Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

Publication	Year	<u>Title</u>	<u>EN/HD</u>	Year
IEC 60068-2-2	2007	Environmental testing - Part 2-2: Tests - Test B: Dry heat	EN 60068-2-2	2007
IEC 62052-11	2003	Electricity metering equipment (AC) - Generequirements, tests and test conditions - Part 11: Metering equipment	eral EN 62052-11	2003
IEC 62053-21	2003	Electricity metering equipment Particular requirements - Part 21: Static meters for active energy (classes 1 and 2)	EN 62053-21	2003
			0	S

#### Annex ZZ

#### (informative)

#### **Coverage of Essential Requirements of EU Directives**

This European Standard has been prepared under the mandate M/374 given to CENELEC by the European Commission and within its scope, this part 32-1 of EN 62059 specifies a method for testing the stability of metrological characteristics of electricity meters, suitable for verification of conformity with the durability requirements.

The standard covers the Essential Requirement 5, Durability, Annex I of the Directive 2004/22/EC of the European Parliament and of the council of 31 March 2004 on measuring instruments (MID):

"A measuring instrument shall be designed to maintain an adequate stability of its metrological characteristics over a period of time estimated by the manufacturer, provided that it is properly installed, maintained and used according to the manufacturer's instruction when in the environmental conditions for which it is intended."

Compliance with this standard provides one means of conformity with the specified essential requirements of the Directives concerned.

WARNING - Other requirements and other EU Directives may be applicable to the products falling within the scope of this standard.

#### CONTENTS

FO	REW	ORD	3		
INT	ROD	UCTION	5		
1	Scop	pe	6		
2	Normative references				
3	Terms and definitions				
4	General				
5	Initial measurements				
6	Conditioning				
7	7 Intermediate measurements – verification of energy measurement and registration				
	7.1 General		9		
	7.2	Method A: Test method using a reference meter	9		
		7.2.1 Test conditions	9		
		7.2.2 Test using a reference standard meter	10		
		7.2.3 Test using a reference meter of the same type as the MUT	10		
	7.3	Method B: Test method using a stable load	11		
	7.4	Final temperature ramp	12		
8	Reco	overy	12		
9	Final	I measurements and acceptance criteria	12		
10	Information to be given in the test report13				
Bib	liogra	iphy	14		

#### INTRODUCTION

Electricity meters are products designed for high reliability and durability to operate continuously for extended periods without supervision.

To manage metering assets effectively, it is important to have tools for predicting and estimating life characteristics of various types.

IEC 62059-41 provides methods for predicting the failure rate – assumed to be constant – of metering equipment, based on the parts stress method.

IEC 62059-31-1 provides a method for estimating life characteristics using accelerated reliability testing by operating the test specimens at elevated temperature and humidity. Future parts of IEC 62059-31 may be established to cover accelerated reliability testing, applying other stresses.

This standard, IEC 62059-32-1 provides a test method to evaluate one important aspect of durability, the stability of metrology characteristics, by operating a test specimen at the upper limit of the specified operating range of temperature, voltage and current for an extended period. Future parts of IEC 62059-32 may be established to cover other kinds of stress or other aspects of durability.

na ge oi 32 may

#### ELECTRICITY METERING EQUIPMENT – DEPENDABILITY –

#### Part 32-1: Durability – Testing of the stability of metrological characteristics by applying elevated temperature

#### 1 Scope

The stability of metrological characteristics is one important aspect of durability.

This part of IEC 62059 specifies a method for testing the stability of metrological characteristics of electricity meters, by operating a test specimen at the upper limit of the specified operating range of temperature, voltage and current for an extended period.

Functional performance other than the accuracy of energy measurement is out of the scope of this standard.

Note, that from the results of this test, no conclusion can be drawn for the length of period during which the stability of the metrological characteristics will be maintained when the meter is operated under usual conditions.

This International Standard is applicable to all types of electricity meters in the scope of IEC TC 13.

#### 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-2-2:2007, Environmental testing – Part 2-2: Tests – Test B: Dry heat

IEC 62052-11:2003, *Electricity metering equipment (AC) – General requirements, tests and test conditions – Part 11: Metering equipment* 

IEC 62053-21:2003, *Electricity metering equipment (a.c.) – Particular requirements – Part 21: Static meters for active energy (classes 1 and 2)* 

#### 3 Terms and definitions

For the purposes of this document, the terms and definitions in IEC 62052-11 as well as the following apply.

#### 3.1

#### durability

the ability of an item to perform a required function under given conditions of use and maintenance, until a limiting state is reached

NOTE A limiting state of an item may be characterized by the end of the useful life, unsuitability or any economic or technological reasons or other relevant factors.