

Fixed firefighting systems - Water mist systems - Part 8-
Test protocol for machinery in enclosures exceeding
260 m³ for open nozzle systems

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 14972-8:2020 sisaldab Euroopa standardi EN 14972-8:2020 ingliskeelset teksti.	This Estonian standard EVS-EN 14972-8:2020 consists of the English text of the European standard EN 14972-8:2020.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 22.01.2020.	Date of Availability of the European standard is 22.01.2020.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 13.220.20

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:

Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

ICS 13.220.20

English Version

Fixed firefighting systems - Water mist systems - Part 8- Test protocol for machinery in enclosures exceeding 260 m³ for open nozzle systems

Installations fixes de lutte contre l'incendie - Systèmes
à brouillard d'eau - Partie 8 : Protocole d'essai des
systèmes à buses ouvertes pour machines situées dans
des enceintes de plus de 260 m³

Ortsfeste Brandbekämpfungsanlagen - Feinsprüh-
Löschanlagen - Teil 8: Prüfprotokoll für Maschinen in
Gehäusen über 260 m³ für offene Düsensysteme

This European Standard was approved by CEN on 11 November 2019.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents

Page

European foreword.....	3
1 Scope.....	4
2 Normative references.....	4
3 Terms and definitions.....	4
4 General requirements.....	4
5 Test enclosure requirements.....	5
6 Machinery mock-up requirement.....	7
7 Test equipment requirements.....	9
8 Instrumentation requirements.....	10
9 Fire tests requirements.....	11
9.1 General.....	11
9.2 Low pressure, exposed, diesel spray fire.....	12
9.3 Low pressure, angled, diesel spray fire.....	12
9.4 Low pressure, concealed, diesel spray fire.....	14
9.5 High pressure, exposed, diesel spray.....	14
9.6 Low pressure-low flow, concealed, diesel spray and pool fires.....	15
9.7 Concealed, heptane pool fire.....	15
9.8 Flowing fire.....	16
9.9 Wood crib and heptane pool fire.....	16
10 Test report.....	17

European foreword

This document (EN 14972-8:2020) has been prepared by Technical Committee CEN/TC 191 “Fixed firefighting systems”, the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by July 2020 and conflicting national standards shall be withdrawn at the latest by July 2020.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

EN 14972, *Fixed firefighting systems — Water mist systems* consists of the following parts:

- *Part 1: Design, installation, inspection and maintenance;*
- *Part 2: Test protocol for shopping areas for automatic nozzle systems;*
- *Part 3: Test protocol for office, school and hotel for automatic nozzle systems;*
- *Part 4: Test protocol for non-storage occupancies for automatic nozzle systems;*
- *Part 5: Test protocol for car garages for automatic nozzle systems;*
- *Part 6: Test protocol for false floors and false ceilings for automatic nozzle systems;*
- *Part 7: Test protocol for commercial low hazard occupancies for automatic nozzle systems;*
- *Part 8: Test protocol for machinery in enclosures exceeding 260 m³ for open nozzle systems;*
- *Part 9: Test protocol for machinery in enclosures not exceeding 260 m³ for open nozzle systems;*
- *Part 10: Test protocol for atrium protection with sidewall nozzles for open nozzle systems;*
- *Part 11: Test protocol for cable tunnels for open nozzle systems;*
- *Part 12: Test protocol for commercial deep fat cooking fryers for open nozzle systems;*
- *Part 13: Test protocol for wet benches and other similar processing equipment for open nozzle systems;*
- *Part 14: Test protocol for combustion turbines in enclosures exceeding 260 m³ for open nozzle systems;*
- *Part 15: Test protocol for combustion turbines in enclosures not exceeding 260 m³ for open nozzle systems;*
- *Part 16: Test protocol for industrial oil cookers for open nozzle systems;*
- *Part 17: Test protocol for residential occupancies for automatic nozzle systems.*

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

1 Scope

This document specifies fire testing requirements for water mist systems used for fire protection of machinery in enclosures with volumes exceeding 260 m³.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 14972-1:—¹⁾, *Fixed firefighting systems — Water mist systems — Part 1: Design, installation, inspection and maintenance*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 14972-1¹⁾ and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

— ISO Online browsing platform: available at <http://www.iso.org/obp>

— IEC Electropedia: available at <https://www.electropedia.org/>

3.1

machinery enclosure

<water mist systems> any enclosure containing equipment that uses fuel and/or lubrication fluids with volatilities less than or equal to heptane

4 General requirements

4.1 The water mist system, operating without manual intervention, shall successfully complete all described performance fire tests for their specific applications.

4.2 The fire tests shall be conducted until the fire is extinguished, as required by the applicable fire test.

4.3 System components, component locations, operating conditions and test enclosure details shall remain unaltered throughout all of the fire tests for a given application.

4.4 All fire tests shall be conducted using the specifications from the manufacturer's DIOM manual in regard to nozzle placement, spray flux, and spray duration. Sprays can be continuous or intermittent in time. In the case of intermittent, or cycled, sprays, the time period during which the system is not discharging shall not be greater than 50 % of one complete on/off cycle. The system off period shall not exceed one minute.

4.5 In conjunction with the performance fire tests, all twin fluid water mist systems (except for those applying compressed air) shall be subjected to a straight discharge test with no fire to evaluate the resulting discharge and oxygen concentration. This evaluation shall be conducted using the maximum extinguishing agent flow and pressure. The discharge duration for the test shall be the maximum required for the system and occupancy to be protected. Oxygen measurements shall be recorded at a

1) Under preparation. Stage at the time of publication: prEN 14972-1:2019.