

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Lamp controlgear –
Part 2-7: Particular requirements for battery supplied electronic controlgear for
emergency lighting (self-contained)**

**Appareillages de lampes –
Partie 2-7: Règles particulières relatives aux appareillages électroniques
alimentés par batterie pour l'éclairage de secours (autonome)**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2011 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch
Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch
Tél.: +41 22 919 02 11
Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

NORME INTERNATIONALE



Lamp controlgear –

Part 2-7: Particular requirements for battery supplied electronic controlgear for emergency lighting (self-contained)

Appareillages de lampes –

Partie 2-7: Règles particulières relatives aux appareillages électroniques alimentés par batterie pour l'éclairage de secours (autonome)

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

ICS 29.140.99

ISBN 978-2-88912-830-3

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references.....	7
3 Terms and definitions.....	8
4 General requirements.....	9
5 General notes on tests.....	10
6 Classification.....	10
7 Marking.....	10
8 Protection against accidental contact with live parts.....	12
9 Terminals.....	12
10 Provisions for protective earthing.....	12
11 Moisture resistance and insulation.....	12
12 Electric strength.....	12
13 Thermal endurance test for windings of ballasts.....	12
14 Fault conditions.....	12
15 Starting conditions.....	12
16 Lamp current.....	13
17 Supply current.....	13
18 Maximum current in any lead (with cathode preheating).....	13
19 Lamp operating current waveforms.....	13
20 Functional safety (EBLF).....	14
21 Changeover operation.....	15
22 Recharging device.....	16
23 Protection against excessive discharge.....	18
24 Indicator.....	19
25 Remote control, rest mode, inhibition mode.....	19
26 Temperature cycling test and endurance test.....	20
27 Polarity reversal.....	20
28 Fault conditions.....	21
29 Construction.....	21
30 Creepage distances and clearances.....	21
31 Screws, current-carrying parts and connections.....	21
32 Resistance to heat, fire and tracking.....	21
33 Resistance to corrosion.....	21
34 Abnormal lamp conditions.....	21
35 Protection of associated components.....	26
Annex A (normative) Test to establish whether a conductive part is a live part, which may cause an electric shock.....	28
Annex B (normative) Particular requirements for thermally protected lamp controlgear.....	28
Annex C (normative) Particular requirements for electronic lamp controlgear with means of protection against overheating.....	28

Annex D (normative) Requirements for carrying out the heating test of thermally protected lamp controlgear	28
Annex E (normative) Use of constant S other than 4 500 in t_w tests.....	28
Annex F (normative) Draught-proof enclosure.....	28
Annex G (normative) Explanation of the derivation of the values of pulse voltages	29
Annex H (normative) Tests	29
Annex I (normative) Batteries for emergency lighting luminaires	29
Annex J (informative) Rest mode and inhibition mode facilities	29
Annex K (normative) Ballasts incorporating an automatic testing function for emergency lighting operation	30
Annex L (informative) Compatibility between normal mains operation electronic controlgear and battery-powered emergency operation controlgear	33
Figure 1 – Suitable circuit for the measurement of lamp current and luminous flux.....	15
Figure 2 – Rectifying effect test	23
Figure 3 – Circuit to test whether a controlgear can withstand a leaking burner	24
Figure 4 – Circuit to test whether a ballast can withstand rectification	26
Figure L.1 – Timing diagram: changeover operation.....	34
Figure L.2 – Supply voltage for the function test	35
Table 1 – Voltage per cell to which the battery is discharged	16
Table 2 – Relation between r.m.s. working voltage and maximum peak voltage	26
Table K.1 – Relevant requirements of IEC 62034.....	30

Preview generated by EVS

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LAMP CONTROLGEAR –

Part 2-7: Particular requirements for battery supplied electronic controlgear for emergency lighting (self-contained)

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61347-2-7 has been prepared by subcommittee 34C: Auxiliaries for lamps, of IEC technical committee 34: Lamps and related equipment.

The text of this standard is based on the following documents:

FDIS	Report on voting
34C/995/FDIS	34C/1002/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This third edition cancels and replaces the second edition published in 2006. It constitutes a technical revision. Significant changes introduced into this third edition include:

- modification of IEC 61347-2-7 to become a standard exclusively for d.c. battery supplied electronic controlgear for emergency lighting (self-contained). IEC 61347-2-3 Annex J is intended to cover centrally supplied emergency controlgear;
- update of Clause 22 – Recharging devices;
- modification of Clause 20 battery voltage characterisation to support EBLF measurement. This to simplify and increase reproducibility of testing;
- rationalisation of requirements between IEC 61347-2-7 and IEC 60598-2-22 requirements of IEC 60598-2-22 being transferred to IEC 61347-2-7.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

This standard shall be used in conjunction with IEC 61347-1. This part 2 supplements or modifies the corresponding clauses in IEC 61347-1.

NOTE In this standard, the following print types are used:

– requirements: in roman type;

– *test specifications: in italic type;*

– notes: in small roman type.

A list of all parts of the IEC 61347 series, published under the general title *Lamp controlgear*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

The formatting into separately published parts provides for ease of future amendments and revisions. Additional requirements will be added as and when a need for them is recognized.

This standard, and the parts which make up IEC 61347-2, in referring to any of the clauses of IEC 61347-1, specify the extent to which such a clause is applicable and the order in which the tests are to be performed; they also include additional requirements, as necessary. All parts which make up IEC 61347-2 are self-contained and, therefore, do not include reference to each other.

Where the requirements of any of the clauses of IEC 61347-1 are referred to in this standard by the phrase "The requirements of Clause n of IEC 61347-1 apply", this phrase is interpreted as meaning that all requirements of the clause in question of Part 1 apply, except any which are clearly inapplicable to the specific type of lamp controlgear covered by this particular part of IEC 61347-2.

This document is a preview generated by EVS

LAMP CONTROLGEAR –

Part 2-7: Particular requirements for battery supplied electronic controlgear for emergency lighting (self-contained)

1 Scope

This part of IEC 61347 specifies particular safety requirements for battery supplied electronic controlgear for maintained and non-maintained emergency lighting purposes.

It includes specific requirements for electronic controlgear and control units for self-contained luminaires for emergency lighting as specified by IEC 60598-2-22.

It is intended for controlgear for fluorescent lamps, but it is also applicable to other lamp types e.g. incandescent, high pressure discharge lamps and LEDs.

This standard covers the emergency mode operation of a controlgear. For controlgear with a combination of normal and emergency lighting operation, the normal lighting operation aspects are covered by the appropriate part 2 of IEC 61347.

DC supplied electronic controlgear for emergency lighting may or may not include batteries.

This standard also includes operational requirements for electronic controlgear, which, in the case of d.c. supplied electronic controlgear, are regarded as performance requirements. This is because non-operational emergency lighting equipment presents a safety hazard. It does not apply to d.c. supplied electronic controlgear for emergency lighting, which are intended for connection to a centralised emergency power supply system. A centralised emergency power system could be a central battery system.

NOTE Annex J of IEC 61347-2-3 applies to a.c., a.c./d.c. or d.c. supplied electronic controlgear for connection to centralised emergency power supply systems that are also intended for emergency lighting operations from a.c./d.c. supplies.

2 Normative references

For the purpose of this part of IEC 61347, the normative references given in Clause 2 of IEC 61347-1, which are mentioned in this standard, apply, together with the following normative references.

IEC 60081, *Double-capped fluorescent lamps – Performance specifications*

IEC 60598-2-22, *Luminaires – Part 2: Particular requirements – Luminaires for emergency lighting*

IEC 60901, *Single-capped fluorescent lamps – Performance specifications*

IEC 60921, *Ballasts for tubular fluorescent lamps – Performance requirements*

IEC 60929, *AC and/or DC-supplied electronic control gear for tubular fluorescent lamps – Performance requirements*

IEC 61347-1, *Lamp controlgear – Part 1: General and safety requirements*

IEC 61347-2-3, *Lamp control gear – Part 2-3: Particular requirements for a.c. and/or d.c. supplied electronic control gear for fluorescent lamps*

IEC 61558-1:2005, *Safety of power transformers, power supplies, reactors and similar products – Part 1: General requirements and tests*
Amendment 1 (2009)¹

IEC 61558-2-1:2007, *Safety of power transformers, power supply units and similar products – Part 2-1: Particular requirements and tests for separating transformers and power supplies incorporating separating transformers for general applications*

IEC 61558-2-6:2009, *Safety of transformers, reactors, power supply units and similar products for supply voltages up to 1 100 V – Part 2-6: Particular requirements and tests for safety isolating transformers and power supply units incorporating safety isolating transformers*

IEC 61558-2-16:2009, *Safety of transformers, reactors, power supply units and similar products for supply voltages up to 1 100 V – Part 2-16: Particular requirements and tests for switch mode power supply units and transformers for switch mode power supply units*

IEC 62034, *Automatic test systems for battery powered emergency escape lighting*

3 Terms and definitions

For the purposes of this part of IEC 61347, the terms and definitions of Clause 3 of IEC 61347-1 and Clause 22.3 in IEC 60598-2-22 apply, together with the following:

3.1

emergency lighting

lighting provided for use when the supply to the normal lighting fails

3.2

changeover operation

automatic connection of the lamp to emergency lighting supply when failure of the normal lighting supply occurs, and connecting automatically back to the normal lighting supply when it is restored

3.3

recharging device

device to maintain the battery charge and to recharge the battery within a specified time

3.4

protection device against extensive discharge

automatic device to disconnect the ballast from the battery when the battery voltage drops below a certain value

3.5

rated duration of emergency operation

time, as claimed by the manufacturer, for which the rated emergency ballast lumen factor is achieved

3.6

maximum d.c. operating voltage

maximum supply voltage declared by the controlgear manufacturer

¹ There exists a consolidated edition 2.1 (2009) comprising IEC 61558-1 (2005) and its Amendment 1 (2009).