

Overhead electrical lines exceeding AC 1 kV - Part 2-12:
National Normative Aspects (NNA) for ICELAND (based
on EN 50341-1:2012)

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 50341-2-12:2018 sisaldab Euroopa standardi EN 50341-2-12:2018 ingliskeelset teksti.	This Estonian standard EVS-EN 50341-2-12:2018 consists of the English text of the European standard EN 50341-2-12:2018.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 14.12.2018.	Date of Availability of the European standard is 14.12.2018.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 29.240.20

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

ICS 29.240.20

English Version

**Overhead electrical lines exceeding AC 1 kV - Part 2-12:
National Normative Aspects (NNA) for ICELAND (based on EN
50341-1:2012)**

This European Standard was approved by CENELEC on 2018-11-26.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents

Foreword	4
1 Scope	5
1.1 General	5
2 Normative references, definitions and symbols	5
2.1 Normative references	5
2.1 IS.1 National normative laws and government regulations:	5
3 Basis of design	5
3.2 Requirements of overhead lines	5
3.2.2 Reliability requirements	5
3.2.5 Strength coordination	6
4 Actions on lines	6
4.3 Wind loads	6
4.3.1 Field of application and basic wind velocity	6
4.3.2 Mean wind velocity	6
4.3.3 Mean wind pressure	6
4.4 Wind forces on overhead line components	6
4.4.1 Wind forces on conductors	6
4.4.3 Wind forces on lattice towers	7
4.5 Ice loads	8
4.5.2 Ice forces on conductors	8
4.6 Combined wind and ice loads	9
4.6.1 Combined probabilities	9
4.6.2 Drag factors and ice densities	9
4.7 Temperature effects	9
4.8 Security loads	9
4.8.1 General	9
4.8.4 Mechanical conditions of application	10
4.9 Safety loads	10
4.9.1 Construction and maintenance loads	10
4.12 Load cases	11
4.12.2 Standard load cases	11
4.13 Partial factors for actions	12
5 Electrical requirements	13
5.5 Minimum air clearance distances to avoid flashover	13
5.6 Load cases for calculation of clearances	13
5.6.4 Ice loads for the determination of electric clearances	13
5.8 Internal clearances within the span and at the top of support	13
5.9 External clearances	16
5.9.1 General	16

5.9.2	External clearances to ground in areas remote from buildings, roads, etc.	16
5.9.3	External clearances to residential and other buildings.....	16
5.9.4	External clearances to crossing traffic routes	17
5.9.5	External clearances to adjacent traffic routes	17
5.9.6	External clearances to other power lines and overhead telecommunication lines	17
5.9.7	External clearances to recreational areas (playgrounds, sports areas, etc.)	17
5.10.2	Audible noise	18
6	Earthing systems.....	18
7	Supports.....	18
7.2	Materials	18
7.3	Lattice steel towers	18
7.3.3	Materials	18
7.3.6	Ultimate limit states.....	19
7.3.8	Resistance of connections	19
7.5	Wood poles	19
7.5.5	Ultimate limit states.....	19
7.7	Guyed structures	20
7.7.4	Ultimate limit states.....	20
7.7.6	Design details for guys	20
7.9	Corrosion protection and finishes	21
7.9.2	Galvanising.....	21
8	Foundations	21
8.2	Basis of geotechnical design	21
8.2.2	Geotechnical design by calculation	21
8.3	Soil investigation and geotechnical data	23
9	Conductors and earth-wires	24
9.1	Introduction.....	24
9.6	General requirements.....	25
9.6.2	Partial factor for conductors.....	25
10	Insulators	25
10.7	Mechanical requirements.....	25
11	Hardware	25
11.6	Mechanical requirements.....	25
12	Quality assurance, checks and taking-over	25
Annex J	Lattice steel towers	25
J.5	Design resistance of bolted connections	25
J.5.1	General	25

European Foreword

- 1 The Icelandic National Committee (NC) is identified by the following address:

Rafstaðlaráð
Staðlaráð Íslands
Þórunnartúni 2
105 Reykjavík
Iceland
Tel. +354 520 7150
Fax +354 520 7171
Web <http://www.stadlar.is>

- 2 The Icelandic NC has prepared this Part 2-12 of EN 50341-1:2012 listing the Icelandic National Normative Aspects (NNA), under its sole responsibility, and duly passed it through the CENELEC and CLC/TC 11 procedures.

Note 1: The Icelandic NC also takes sole responsibility for the technically correct co-ordination of this EN 50341-2-12 with EN 50341-1. It has performed the necessary checks in the frame of quality assurance/control. However, it is noted that this quality control has been made in the framework of the general responsibility of a standards committee under the national laws/regulations.

- 3 This EN 50341-2-12 is normative in Iceland and informative for other countries.

- 4 This Part 2-12 has to be read in conjunction with EN 50341-1, hereinafter referred to as Part 1. All clause numbers used in this Part 2-12 correspond to those of Part 1. Specific subclauses, which are prefixed "IS", are to be read as amendments to the relevant text in Part 1. Any necessary clarification regarding the application of Part 2-12 in conjunction with Part 1 shall be referred to the Icelandic NC who will, in co-operation with CLC/TC 11 clarify the requirements.

When no reference is made in Part 2-12 to a specific subclause, then Part 1 applies.

- 5 In the case of "boxed values" defined in Part 1, amended values (if any) which are defined in Part 2-12 shall be taken into account in Iceland.

However, any boxed value, whether in Part 1 or Part 2-12, shall not be amended in the direction of greater risk in a Project Specification.

- 6 The national Icelandic standards/regulations related to overhead electrical lines exceeding 1 kV (AC) are listed in subclause 2.1/IS.1.

NOTE All national standards referred to in this Part 2-12 will be replaced by the relevant European Standards as soon as they become available and are declared by the Icelandic NC to be applicable and thus reported to the secretary of CLC/TC 11.

1 Scope

1.1 General

1.1 IS.1 Application to new lines

(snc) This Part 2-12 is only applicable to new overhead transmission lines exceeding 1 kV (AC). If deviations and/or extensions to existing transmission lines are planned, the Icelandic NC shall be informed and will decide case by case whether IST EN 50341 is applicable or not.

2 Normative references, definitions and symbols

2.1 Normative references

2.1 IS.1 National normative laws and government regulations:

(A-dev)

- Lög nr. 146/1996 um öryggi raforkuvirkja, neysluveitna og raffanga.
Act no. 146/1996 on the Safety of Electrical Installations, Consumer Apparatus and Electrical Materials.
- Reglugerð um raforkuvirki nr. 678/2009, með áorðnum breytingum.
The Electrical Regulation no. 678/2009, with later changes.
- Reglugerð um hávaða nr. 724/2008, með áorðnum breytingum.
The Regulation on noise no. 724/2008, with later changes.

3 Basis of design

3.2 Requirements of overhead lines

3.2.2 Reliability requirements

3.2.2 IS.1 Reliability requirements

(snc) Three reliability levels are used for new transmission lines as shown in the following table:

Table 3.2.2/IS.1 Reliability levels

Reliability level	Voltage	Transmission lines
1	≤ 45 kV	Normal lines
	> 45 kV and ≤ 132 kV	Less important lines
2	≤ 45 kV	Very important lines
	> 45 kV and ≤ 132 kV	Normal lines
	> 132 kV and ≤ 400 kV	Less important lines
3	< 220 kV	Very important lines
	≥ 220 kV	Normal lines
Level 3 shall be used in built up or urban areas for lines ≥ 132 kV		

Level of importance shall be defined in Project Specification.