

**High-voltage switchgear and controlgear - Part 107:
Alternating current fused circuit-switchers for rated
voltages above 1 kV up to and including 52 kV**

This document is a preview generated by EVS

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 62271-107:2012 sisaldab Euroopa standardi EN 62271-107:2012 ingliskeelset teksti.	This Estonian standard EVS-EN 62271-107:2012 consists of the English text of the European standard EN 62271-107:2012.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 03.08.2012.	Date of Availability of the European standard is 03.08.2012.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 29.130.10

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Aru 10, 10317 Tallinn, Eesti; www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:
Aru 10, 10317 Tallinn, Estonia; www.evs.ee; phone 605 5050; e-mail info@evs.ee

English version

**High-voltage switchgear and controlgear -
Part 107: Alternating current fused circuit-switchers for rated voltages
above 1 kV up to and including 52 kV
(IEC 62271-107:2012)**

Appareillage à haute tension -
Partie 107: Circuits-switchers fusibles
pour courant alternatif de tension
assignée supérieure à 1 kV et jusqu'à
52 kV inclus
(CEI 62271-107:2012)

Hochspannungs-Schaltgeräte und -
Schaltanlagen -
Teil 107: Wechselstrom-
Leistungsschalter-Sicherungs-
Kombinationen für
Bemessungsspannungen über 1 kV bis
einschließlich 52 kV
(IEC 62271-107:2012)

This European Standard was approved by CENELEC on 2012-07-03. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 17A/997/FDIS, future edition 2 of IEC 62271-107, prepared by SC 17A, "High-voltage switchgear and controlgear", of IEC TC 17, "Switchgear and controlgear" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 62271-107:2012.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2013-04-03
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2015-07-03

This document supersedes EN 62271-107:2005.

EN 62271-107:2012 includes the following significant technical changes with respect to EN 62271-107:2005:

- the reference to EN 60694 has been changed to EN 62271-1;
- the new clauses and subclauses from EN 62271-1 have been added and where necessary new wording has been provided:
 - 4.11 Rated filling levels for insulation and/or operation;
 - 5.19 X-ray emission;
 - 5.20 Corrosion;
 - 6.10 Additional tests on auxiliary and control circuits;
 - 6.11 X-radiation test procedure for vacuum interrupters;
 - 12 Influence of the product on the environment;
- the normative references have been updated: EN 60265-1 to EN 62271-103, IEC 60787 to IEC/TR 60787, IEC 60466 to EN 62271-201, and IEC/TR 60787 was moved to the bibliography;
- the figures and tables have been placed in the document where they are first cited;
- the numbering of figures and tables has been changed to obtain the correct order;
- the definition of NSDD was deleted. This definition is included in EN 62271-1;
- the acceptance criteria have been aligned with 6.101.4 of EN 62271-103:2011;
- the various provisions expressed about "extension of the validity of type tests" have been grouped under 6.103: some of the rules were duplicated in Clauses 6 and 8, and it seems better fitted to deal within each type test sub-clause only with the type test to be performed. Conditions have not been changed, but the wording is clearer;
- new numbering of subclauses in Clauses 8 and 9 to avoid conflict with clauses from EN 62271-1.

This International Standard is to be read in conjunction with EN 62271-1:2008, to which it refers and which is applicable unless otherwise specified. In order to simplify the indication of corresponding requirements, the same numbering of clauses and subclauses is used as in EN 62271-1. Amendments to these clauses and subclauses are given under the same numbering, whilst additional subclauses, are numbered from 101.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 62271-107:2012 was approved by CENELEC as a European Standard without any modification.

This document is a preview generated by EVS

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60282-1	2009	High-voltage fuses - Part 1: Current-limiting fuses	EN 60282-1	2009
IEC 62271-1	2007	High-voltage switchgear and controlgear - Part 1: Common specifications	EN 62271-1	2008
IEC 62271-100	2008	High-voltage switchgear and controlgear - Part 100: Alternating current circuit-breakers	EN 62271-100	2009
IEC 62271-102 + corr. April + corr. February + corr. May	2001 2002 2005 2003	High-voltage switchgear and controlgear - Part 102: Alternating current disconnectors and earthing switches	EN 62271-102 + corr. July + corr. March	2002 2008 2005
IEC 62271-103	2011	High-voltage switchgear and controlgear - Part 103: Switches for rated voltages above 1 kV up to and including 52 kV	EN 62271-103	2011
IEC 62271-105	-	High-voltage switchgear and controlgear - Part 105: Alternating current switch-fuse combinations	EN 62271-105	-
IEC 62271-200	-	High-voltage switchgear and controlgear - Part 200: AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV	EN 62271-200	-
IEC 62271-201	-	High-voltage switchgear and controlgear - Part 201: AC insulation-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV	EN 62271-201	-

CONTENTS

FOREWORD.....	5
1 General.....	7
1.1 Scope.....	7
1.2 Normative references.....	7
2 Normal and special service conditions.....	8
3 Terms and definitions.....	8
3.1 General terms.....	8
3.2 Assemblies of switchgear and controlgear.....	8
3.3 Parts of assemblies.....	8
3.4 Switching devices.....	8
3.5 Parts of switchgear and controlgear.....	9
3.6 Operation.....	9
3.7 Characteristic quantities.....	10
3.101 Fuses.....	12
4 Ratings.....	12
4.1 Rated voltage (U_r).....	13
4.2 Rated insulation level.....	13
4.3 Rated frequency (f_r).....	13
4.4 Rated normal current and temperature rise.....	13
4.4.1 Rated normal current (I_r).....	13
4.4.2 Temperature rise.....	13
4.4.101 Rated maximum thermal current (I_{th}).....	13
4.5 Rated short-time withstand current (I_k).....	13
4.6 Rated peak withstand current (I_p).....	13
4.7 Rated duration of short circuit (t_k).....	14
4.8 Rated supply voltage of closing and opening devices and of auxiliary and control circuits (U_a).....	14
4.9 Rated supply frequency of closing and opening devices and of auxiliary circuits.....	14
4.10 Rated pressure of compressed gas supply for controlled pressure systems.....	14
4.11 Rated filling levels for insulation and/or operation.....	14
4.101 Rated short-circuit breaking current I_{sc}	14
4.102 Rated transient recovery voltage.....	14
4.103 Rated short-circuit making current.....	14
4.104 Rated take-over current.....	15
5 Design and construction.....	15
5.1 Requirements for liquids in fused circuit-switchers.....	15
5.2 Requirements for gases in fused circuit-switchers.....	15
5.3 Earthing of fused circuit-switchers.....	15
5.4 Auxiliary and control equipment.....	15
5.5 Dependent power operation.....	16
5.6 Stored energy operation.....	16
5.7 Independent manual or power operation (independent unlatched operation).....	16
5.8 Operation of releases.....	16
5.9 Low- and high- pressure interlocking and monitoring devices.....	16
5.10 Nameplates.....	16

5.11	Interlocking devices	17
5.12	Position indication	17
5.13	Degrees of protection by enclosures	17
5.14	Creepage distances for outdoor insulators	17
5.15	Gas and vacuum tightness	17
5.16	Liquid tightness	17
5.17	Fire hazard (flammability)	17
5.18	Electromagnetic compatibility (EMC)	17
5.19	X-ray emission	17
5.20	Corrosion	17
5.101	Linkages between the fuse striker(s) and the circuit-switcher release	18
5.102	Low over-current conditions (long fuse pre-arcing time conditions)	18
6	Type tests	18
6.1	General	18
6.1.1	Grouping of tests	19
6.1.2	Information for identification of specimens	19
6.1.3	Information to be included in type-test reports	19
6.2	Dielectric tests	19
6.3	Radio interference voltage (r.i.v.) test	19
6.4	Measurement of the resistance of circuits	19
6.5	Temperature-rise tests	19
6.6	Short-time withstand current and peak withstand current tests	19
6.7	Verification of the protection	19
6.8	Tightness tests	20
6.9	Electromagnetic compatibility tests (EMC)	20
6.10	Additional tests on auxiliary and control circuits	20
6.11	X-radiation test procedure for vacuum interrupters	20
6.101	Making and breaking tests	20
6.101.1	Conditions for performing the tests	20
6.101.2	Test duty procedures	25
6.101.3	Behaviour of the fused circuit-switcher during tests	30
6.101.4	Condition of the apparatus after tests	30
6.102	Mechanical operation tests	31
6.102.1	Condition of fused circuit-switcher during and after mechanical operation tests	32
6.102.2	Condition of the fuses during and after mechanical operation tests	32
6.103	Extension of validity of type tests	32
6.103.1	Dielectric properties	32
6.103.2	Temperature rise	32
6.103.3	Making and breaking	33
7	Routine tests	33
7.101	Mechanical operating tests	33
8	Guide for the selection of fused circuit-switchers	34
8.1	Selection of rated values	34
8.2	Continuous or temporary overload due to changed service conditions	34
8.101	Additional criteria	34
8.102	Short-circuit breaking current	34
8.103	Rated maximum thermal current	35
8.104	Currents between thermal current and I_3 of the fuses	35

8.105	Transfer current.....	35
8.106	Take-over current.....	35
8.107	Extension of the validity of type tests.....	35
8.108	Operation.....	36
8.109	Comparison of performances of fused circuit-switchers with performances of switch-fuse combinations and circuit-breakers.....	36
9	Information to be given with enquiries, tenders and orders.....	37
9.1	Information to be given with enquiries and orders.....	37
9.2	Information to be given with tenders.....	37
10	Rules for transport, storage, installation, operation and maintenance.....	38
11	Safety.....	38
12	Influence of the product on the environment.....	38
Annex A (informative)	Applicability of the rated take-over current test duty.....	39
Bibliography	47
Figure 1	– Characteristics for determining the take-over current.....	15
Figure 2	– Arrangement of test circuits for test duties $TD_{I_{th}}$, $TD_{I_{sc}}$, $TD_{I_{to}}$ and $TD_{I_{low}}$	22
Figure 3	– Representation of a specified TRV by a two-parameter reference line and a delay line.....	24
Figure 4	– Example of a two parameters envelope for a TRV.....	25
Figure 5	– Measurement of the power frequency recovery voltage with striker operation.....	27
Figure A.1	– Visualization of the application margin for a given fuse.....	41
Table 1	– Nameplate markings.....	16
Table 2	– Summary of test parameters for test duties.....	29
Table 3	– Comparison between switch-fuse combination and fused circuit-switcher.....	37
Table 4	– Comparison between fused circuit-switcher and circuit breaker.....	37
Table A.1	– Minimum application margin A_m according to fuse characteristic.....	44
Table A.2	– Minimum protection time delay.....	45
Table A.3	– Examples of possible need for time delay.....	45

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 107: Alternating current fused circuit-switchers for rated voltages above 1 kV up to and including 52 kV

1 General

1.1 Scope

Subclause 1.1 of IEC 62271-1:2007 is not applicable, and is replaced as follows.

This part of IEC 62271 applies to three-pole operated units for distribution systems that are functional assemblies of a circuit-switcher and current-limiting fuses designed so as to be capable of:

- breaking, at the rated recovery voltage, any load or fault current up to and including the rated short-circuit breaking current;
- making, at the rated voltage, circuits to which the rated short-circuit breaking current applies.

They are intended to be used for circuits or applications requiring only a normal mechanical and electrical endurance capability. Such applications cover protection of HV/LV transformers for instance, but exclude distribution lines or cables, as well as motor circuits and capacitor bank circuits.

Short-circuit conditions with low currents, up to the fused circuit-switcher rated take-over current, are dealt with by supplementary devices (strickers, relays, etc.), properly arranged, tripping the circuit-switcher. Fuses are incorporated in order to ensure that the short-circuit breaking capacity of the device is above that of the circuit-switcher.

NOTE 1 In this standard the term "fuse" is used to designate either the fuse or the fuse-link where the general meaning of the text does not result in ambiguity.

This standard applies to fused circuit-switchers designed with rated voltages above 1 kV up to and including 52 kV for use on three-phase alternating current systems of either 50 Hz or 60 Hz. Comparison with other existing switching devices is provided in Clause 8.

NOTE 2 Other circuit-switchers exist; see reference [1]¹.

Devices that require a dependent manual operation are not covered by this standard.

Fuses are covered by IEC 60282-1.

Earthing switches forming an integral part of a circuit-switcher are covered by IEC 62271-102.

Installation in enclosure, if any, is covered either by IEC 62271-200 or by IEC 62271-201.

1.2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For

¹ Numbers between brackets refer to the Bibliography.

undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60282-1:2009, *High-voltage fuses – Part 1: Current-limiting fuses*

IEC 62271-1:2007, *High-voltage switchgear and controlgear – Part 1: Common specifications*

IEC 62271-100:2008, *High-voltage switchgear and controlgear – Part 100: Alternating-current circuit-breakers*

IEC 62271-102:2001, *High-voltage switchgear and controlgear – Part 102: Alternating current disconnectors and earthing switches*

IEC 62271-103:2011, *High-voltage switchgear and controlgear – Part 103: Switches for rated voltages above 1 kV up to and including 52 kV*

IEC 62271-105:—, *High-voltage switchgear and controlgear – Part 105: Alternating current switch-fuse combinations for rated voltages above 1 kV up to and including 52 kV²*

IEC 62271-200, *High-voltage switchgear and controlgear – Part 200: AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV*

IEC 62271-201, *High-voltage switchgear and controlgear – Part 201: AC insulation-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV*

2 Normal and special service conditions

Clause 2 of IEC 62271-1:2007 is applicable.

3 Terms and definitions

Clause 3 of IEC 62271-1:2007 is applicable with the following additions:

3.1 General terms

Subclause 3.1 of IEC 62271-1:2007 is applicable.

3.2 Assemblies of switchgear and controlgear

Subclause 3.2 of IEC 62271-1:2007 is applicable.

3.3 Parts of assemblies

Subclause 3.3 of IEC 62271-1:2007 is applicable.

3.4 Switching devices

Subclause 3.4 of IEC 62271-1:2007 is applicable, with the following additions.

² To be published.