

**High-voltage switchgear and controlgear - Part 110:
Inductive load switching (IEC 62271-110:2012 +
corrigendum Oct. 2012)**

This document is a preview generated by EVS

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 62271-110:2012 sisaldab Euroopa standardi EN 62271-110:2012 ingliskeelset teksti.	This Estonian standard EVS-EN 62271-110:2012 consists of the English text of the European standard EN 62271-110:2012.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 14.12.2012.	Date of Availability of the European standard is 14.12.2012.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 29.130.10

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Aru 10, 10317 Tallinn, Eesti; www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:
Aru 10, 10317 Tallinn, Estonia; www.evs.ee; phone 605 5050; e-mail info@evs.ee

English version

**High-voltage switchgear and controlgear -
Part 110: Inductive load switching**
(IEC 62271-110:2012 + corrigendum Oct. 2012)

Appareillage à haute tension -
Partie 110: Manoeuvre de charges
inductives
(CEI 62271-110:2012 + corrigendum Oct.
2012)

Hochspannungs-Schaltgeräte und -
Schaltanlagen -
Teil 110: Schalten induktiver Lasten
(IEC 62271-110:2012 + corrigendum Oct.
2012)

This European Standard was approved by CENELEC on 2012-11-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 17A/1016/FDIS, future edition 3 of IEC 62271-110, prepared by SC 17A, "High-voltage switchgear and controlgear", of IEC TC 17, "Switchgear and controlgear" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 62271-110:2012.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2013-08-01
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2015-11-01

This document supersedes EN 62271-110:2009.

EN 62271-110:2012 includes the following significant technical changes with respect to EN 62271-110:2009:

- former Table 2 has been split into three new tables to conform with EN 62271-100 and to address actual in-service circuit configurations;
- the criteria for successful testing has been revised to a more explicit statement (see 6.114.11a);
- comments received in response to 17A/959/CDV and 17A/981/RVC have been addressed.

This standard is to be read in conjunction with EN 62271-1:2008, and with EN 62271-100:2009, to which it refers and which are applicable, unless otherwise specified. In order to simplify the indication of corresponding requirements, the same numbering of clauses and subclauses is used as in EN 62271-1 and EN 62271-100. Additional subclauses are numbered from 101.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 62271-110:2012 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following note has to be added for the standard indicated:

IEC 62271-106 NOTE Harmonized as EN 62271-106.

Annex ZA
(normative)

**Normative references to international publications
with their corresponding European publications**

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

Annex ZA of EN 62271-100:2009 is applicable with the following addition:

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 62271-100	2008	High-voltage switchgear and controlgear - Part 100: Alternating current circuit-breakers	EN 62271-100	2009

This document is a preview generated by EVS

CONTENTS

FOREWORD.....	4
1 General.....	6
1.1 Scope.....	6
1.2 Normative references.....	6
2 Normal and special service conditions.....	6
3 Terms and definitions.....	7
4 Ratings.....	8
5 Design and construction.....	8
6 Type tests.....	8
6.1 General.....	8
6.2 Dielectric tests.....	9
6.3 Radio interference voltage (r.i.v.) test.....	9
6.4 Measurement of the resistance of circuits.....	9
6.5 Temperature-rise tests.....	9
6.6 Short-time withstand current and peak withstand current tests.....	9
6.7 Verification of protection.....	9
6.8 Tightness tests.....	9
6.9 Electromagnetic compatibility tests (EMC).....	9
6.101 Mechanical and environmental tests.....	9
6.102 Miscellaneous provisions for making and breaking tests.....	9
6.103 Test circuits for short-circuit making and breaking tests.....	10
6.104 Short-circuit test quantities.....	10
6.105 Short-circuit test procedure.....	10
6.106 Basic short-circuit test-duties.....	10
6.107 Critical current tests.....	10
6.108 Single-phase and double-earth fault tests.....	10
6.113 High-voltage motor current switching tests.....	10
6.114 Shunt reactor current switching tests.....	16
7 Routine tests.....	27
8 Guide to selection of switchgear and controlgear.....	27
9 Information to be given with enquiries, tenders and orders.....	27
10 Transport, storage, installation, operation and maintenance.....	27
11 Safety.....	27
12 Influence of the product on the environment.....	27
Annex A (normative) Calculation of t_3 values.....	29
Bibliography.....	31
Figure 1 – Motor switching test circuit and summary of parameters.....	12
Figure 2 – Illustration of voltage transients at interruption of inductive current for first phase clearing in a three-phase non-effectively earthed circuit.....	16
Figure 3 – Reactor switching test circuit – Three-phase test circuit for in-service load circuit configurations 1 and 2 (Table 2).....	18
Figure 4 – Reactor switching test circuit – Single-phase test circuit for in-service load circuit configurations 1, 2 and 4 (Table 2).....	19

Figure 5 – Reactor switching test circuit – Three-phase test circuit for in-service load circuit configuration 3 (Table 2).....	20
Figure 6 – Illustration of voltage transients at interruption of inductive current for a single-phase test	28
Table 1 – Test duties at motor current switching tests	14
Table 2 – In-service load circuit configurations	17
Table 3 – Standard values of prospective transient recovery voltages – Rated voltages 12 kV to 170 kV for effectively and non-effectively earthed systems – Switching shunt reactors with isolated neutrals (Table 2: In-service load circuit configuration 1)	21
Table 4 – Standard values of prospective transient recovery voltages – Rated voltages 100 kV to 1 200 kV for effectively earthed systems – Switching shunt reactors with earthed neutrals (Table 2: In-service load circuit configuration 2).....	22
Table 5 – Standard values of prospective transient recovery voltages – Rated voltages 12 kV to 52 kV for effectively and non-effectively earthed systems – Switching shunt reactors with isolated neutrals (Table 2: In-service load circuit configuration 3)	23
Table 6 – Standard values of prospective transient recovery voltages – Rated voltages 12 kV to 52 kV for effectively and non-effectively earthed systems – Switching shunt reactors with earthed neutrals (Table 2: In-service load circuit configuration 4).....	23
Table 7 – Load circuit 1 test currents	24
Table 8 – Load circuit 2 test currents	24
Table 9 – Test duties for reactor current switching tests	25

Preview generated by EVS

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 110: Inductive load switching

1 General

1.1 Scope

This part of IEC 62271 is applicable to a.c. circuit-breakers designed for indoor or outdoor installation, for operation at frequencies of 50 Hz and 60 Hz on systems having voltages above 1 000 V and applied for inductive current switching with or without additional short-circuit current breaking duties. The standard is applicable to circuit-breakers in accordance with IEC 62271-100 that are used to switch high-voltage motor currents and shunt reactor currents and also to high-voltage contactors used to switch high-voltage motor currents as covered by IEC 62271-106. For circuit-breakers applied to switch shunt reactor currents at rated voltages according to IEC 62271-1:2007 Tables 2a and 2b, combined voltage tests across the isolating distance are not required (refer to 4.2).

Switching unloaded transformers, i.e. breaking transformer magnetizing current, is not considered in this standard. The reasons for this are as follows:

- a) due to the non-linearity of the transformer core, it is not possible to correctly model the switching of transformer magnetizing current using linear components in a test laboratory. Tests conducted using an available transformer, such as a test transformer, will only be valid for the transformer tested and cannot be representative for other transformers;
- b) as detailed in IEC 62271-306¹, the characteristics of this duty are usually less severe than any other inductive current switching duty. It should be noted that such a duty may produce severe overvoltages within the transformer winding(s) depending on the circuit-breaker re-ignition behaviour and transformer winding resonance frequencies.

Short-line faults, out-of-phase current making and breaking and capacitive current switching are not applicable to circuit-breakers applied to switch shunt reactors or motors. These duties are therefore not included in this standard.

Subclause 1.1 of IEC 62271-100:2008 is otherwise applicable.

1.2 Normative references

Subclause 1.2 of IEC 62271-100:2008 is applicable with the following addition:

IEC 62271-100:2008, *High-voltage switchgear and controlgear – Part 100: Alternating-current circuit-breakers*

2 Normal and special service conditions

Clause 2 of IEC 62271-1:2007 is applicable.

¹ To be published.