

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Instrument transformers –
Part 3: Additional requirements for inductive voltage transformers**

**Transformateurs de mesure –
Partie 3: Exigences supplémentaires concernant les transformateurs inductifs
de tension**





THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2011 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembé
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00



IEC 61869-3

Edition 1.0 2011-07

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Instrument transformers –
Part 3: Additional requirements for inductive voltage transformers**

**Transformateurs de mesure –
Partie 3: Exigences supplémentaires concernant les transformateurs inductifs
de tension**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

ICS 17.220.20

ISBN 978-2-88912-544-9

CONTENTS

FOREWORD	4
1 Scope	7
2 Normative references	7
3 Terms, definitions and abbreviations	7
3.1 General definitions	7
3.2 Definitions related to dielectric ratings	8
3.4 Definitions related to accuracy	9
3.5 Definitions related to other ratings	9
3.7 Index of abbreviation	9
5 Ratings	9
5.3 Rated insulation levels	10
5.5 Rated output	10
5.5.301 Rated output values	10
5.5.302 Rated thermal limiting output	10
5.5.303 Rated output values for residual voltage windings	10
5.5.304 Rated thermal limiting output for residual voltage windings	10
5.6 Rated accuracy class	11
5.6.301 Accuracy requirements for single-phase inductive measuring voltage transformers	11
5.6.302 Additional requirements for single-phase inductive protective voltage transformers	12
5.301 Standard values of rated voltages	13
5.301.1 Rated primary voltages	13
5.301.2 Rated secondary voltages	13
5.301.3 Rated voltages for residual voltage windings	13
5.302 Standard values of rated voltage factor	14
6 Design and construction	15
6.4 Requirements for temperature rise of parts and components	15
6.4.1 General	15
6.13 Markings	15
6.13.301 Terminal markings	15
6.13.302 Rating plate markings	19
6.301 Short-circuit withstand capability	20
7 Tests	20
7.1 General	20
7.1.2 List of tests	20
7.2 Type tests	21
7.2.2 Temperature-rise test	21
7.2.3 Impulse voltage withstand test on primary terminals	22
7.2.5 Electromagnetic Compatibility (EMC) tests	23
7.2.6 Test for accuracy	23
7.2.301 Short-circuit withstand capability test	23
7.3 Routine tests	24
7.3.1 Power-frequency voltage withstand tests on primary terminals	24
7.3.2 Partial discharge measurements	27
7.3.5 Test for accuracy	27

7.4 Special tests	27
7.4.3 Measurement of capacitance and dielectric dissipation factor	27
7.4.6 Internal arc fault test	28
 Figure 301 – Single-phase transformer with fully insulated terminals and a single secondary.....	16
Figure 302 – Single-phase transformer with a neutral primary terminal with reduced insulation and a single secondary	16
Figure 303 – Three-phase assembly with a single secondary.....	16
Figure 304 – Single-phase transformer with two secondaries.....	17
Figure 305 – Three-phase assembly with two secondaries.....	17
Figure 306 – Single-phase transformer with one multi-tap secondary.....	17
Figure 307 – Three-phase assembly with one multi-tap secondary.....	17
Figure 308 – Single-phase transformer with two multi-tap secondaries	18
Figure 309 – Single-phase transformer with one residual voltage winding	18
Figure 310 – Three-phase transformer with one residual voltage winding.....	18
Figure 311 – Example of a typical rating plate.....	20
Figure 312 – Example of a rating plate with typical data.....	20
Figure 313 – Common mode (separate source) test voltage application	26
Figure 314 – Differential mode (induced) test voltage application – Primary excitation	26
Figure 315 – Differential mode (induced) test voltage application – Secondary excitation	27
 Table 301 – Limits of voltage error and phase displacement for measuring voltage transformers	11
Table 302 – Limits of voltage error and phase displacement for protective voltage transformers	12
Table 303 – Rated voltages for secondary windings intended to produce a residual voltage.....	14
Table 10 – List of tests	21
Table 305 – Burden ranges for accuracy tests	23

INTERNATIONAL ELECTROTECHNICAL COMMISSION

INSTRUMENT TRANSFORMERS –**Part 3: Additional requirements for inductive voltage transformers****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This International Standard IEC 61869-3 has been prepared by subcommittee 38: Instrument transformers.

This standard replaces IEC 60044-2: Inductive Voltage Transformers.

The text of this standard is based on the following documents:

FDIS	Report on voting
38/410/FDIS	38/413/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

This standard is Part 3 of IEC 61869, published under the general title *Instrument transformers*.

This part 3 is to be read in conjunction with, and is based on, IEC 61869-1, *General Requirements* - first edition (2007)- however the reader is encouraged to use its most recent edition.

This Part 3 follows the structure of IEC 61869-1 and supplements or modifies its corresponding clauses.

When a particular clause/subclause of Part 1 is not mentioned in this Part 3, that clause/subclause applies as far as is reasonable. When this standard states “addition”, “modification” or “replacement”, the relevant text in Part 1 is to be adapted accordingly.

For additional clauses, subclauses, figures, tables, annexes or notes, the following numbering system is used:

- clauses, subclauses, tables, figures and notes that are numbered starting from 301 are additional to those in Part 1;
- additional annexes are lettered 3A, 3B, etc.

An overview of the planned set of standards at the date of publication of this document is given below. The updated list of standards issued by IEC TC38 is available at the website: www.iec.ch.

PRODUCT FAMILY STANDARDS	PRODUCT STANDARD	PRODUCTS	OLD STANDARD
61869-1 GENERAL REQUIREMENTS FOR INSTRUMENT TRANSFORMERS	61869-6 ADDITIONAL GENERAL REQUIREMENT FOR ELECTRONIC INSTRUMENT TRANSFORMERS AND LOW POWER STAND ALONE SENSORS	61869-2 ADDITIONAL REQUIREMENTS FOR CURRENT TRANSFORMERS	60044-1 60044-6
		61869-3 ADDITIONAL REQUIREMENTS FOR INDUCTIVE VOLTAGE TRANSFORMERS	60044-2
		61869-4 ADDITIONAL REQUIREMENTS FOR COMBINED TRANSFORMERS	60044-3
		61869-5 ADDITIONAL REQUIREMENTS FOR CAPACITIVE VOLTAGE TRANSFORMERS	60044-5
		61869-7 ADDITIONAL REQUIREMENTS FOR ELECTRONIC VOLTAGE TRANSFORMERS	60044-7
		61869-8 ADDITIONAL REQUIREMENTS FOR ELECTRONIC CURRENT TRANSFORMERS	60044-8
		61869-9 DIGITAL INTERFACE FOR INSTRUMENT TRANSFORMERS	
		61869-10 ADDITIONAL REQUIREMENTS FOR LOW-POWER STAND-ALONE CURRENT SENSORS	
		61869-11 ADDITIONAL REQUIREMENTS FOR LOW-POWER STAND ALONE VOLTAGE SENSOR	60044-7
		61869-12 ADDITIONAL REQUIREMENTS FOR COMBINED ELECTRONIC INSTRUMENT TRANSFORMER OR COMBINED STAND ALONE SENSORS	
		61869-13 STAND ALONE MERGING UNIT	

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INSTRUMENT TRANSFORMERS –

Part 3: Additional requirements for inductive voltage transformers

1 Scope

This part of IEC 61869 applies to new inductive voltage transformers for use with electrical measuring instruments and electrical protective devices at frequencies from 15 Hz to 100 Hz.

NOTE 301 Requirements specific to three-phase voltage transformers are not included in this standard but, so far as they are relevant, the requirements in clauses 4 to 10 apply to these transformers and a few references to them are included in those clauses (e.g. see 3.1.303, 5.301.1, 5.301.2, 5.5.301, 6.13.301.1 and Table 304).

All the transformers shall be suitable for measuring purposes, but, in addition, certain types may be suitable for protection purposes. Transformers for the dual purpose of measurement and protection shall comply with all clauses of this standard.

2 Normative references

Clause 2 of IEC 61869-1:2007 is applicable with the following additions:

IEC 60028, *International Standard of resistance for copper*

IEC 60038, *IEC standard voltages*

IEC 61869-1:2007, *Instrument transformers – Part 1: General requirements*

3 Terms, definitions and abbreviations

For the purposes of this document, the terms and definitions in IEC 61869-1:2007 apply with the following additions:

3.1 General definitions

3.1.301

voltage transformer

instrument transformer in which the secondary voltage, in normal conditions of use, is substantially proportional to the primary voltage and differs in phase from it by an angle which is approximately zero for an appropriate direction of the connections

[IEC 60050-321:1986, 321-03-01]

3.1.302

unearthed voltage transformer

voltage transformer which has all parts of its primary winding, including terminals, insulated from earth to a level corresponding to its rated insulation level

3.1.303

earthing voltage transformer

single-phase voltage transformer which is intended to have one end of its primary winding directly earthed or a three-phase voltage transformer which is intended to have the star-point of its primary winding directly earthed