

# INTERNATIONAL STANDARD

## NORME INTERNATIONALE

**Instrument transformers –  
Part 5: Additional requirements for capacitor voltage transformers**

**Transformateurs de mesure –  
Partie 5: Exigences supplémentaires concernant les transformateurs  
condensateurs de tension**





## THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2011 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office  
3, rue de Varembé  
CH-1211 Geneva 20  
Switzerland  
Email: [inmail@iec.ch](mailto:inmail@iec.ch)  
Web: [www.iec.ch](http://www.iec.ch)

## About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: [www.iec.ch/searchpub](http://www.iec.ch/searchpub)

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: [www.iec.ch/online\\_news/justpub](http://www.iec.ch/online_news/justpub)

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: [www.iec.ch/webstore/custserv](http://www.iec.ch/webstore/custserv)

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: [csc@iec.ch](mailto:csc@iec.ch)

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

---

## A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

### A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: [www.iec.ch/searchpub/cur\\_fut-f.htm](http://www.iec.ch/searchpub/cur_fut-f.htm)

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: [www.iec.ch/online\\_news/justpub](http://www.iec.ch/online_news/justpub)

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: [www.electropedia.org](http://www.electropedia.org)

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: [www.iec.ch/webstore/custserv/custserv\\_entry-f.htm](http://www.iec.ch/webstore/custserv/custserv_entry-f.htm)

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: [csc@iec.ch](mailto:csc@iec.ch)

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00



IEC 61869-5

Edition 1.0 2011-07

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE

**Instrument transformers –  
Part 5: Additional requirements for capacitor voltage transformers**

**Transformateurs de mesure –  
Partie 5: Exigences supplémentaires concernant les transformateurs  
condensateurs de tension**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

PRICE CODE  
CODE PRIX XA

ICS 17.220.20

ISBN 978-2-88912-543-2

## CONTENTS

FOREWORD .....	5
1 Scope .....	8
2 Normative references .....	8
3 Terms and Definitions .....	8
3.1 General definitions .....	9
3.2 Definitions related to dielectric ratings and voltages .....	14
3.4 Definitions related to accuracy .....	14
3.5 Definitions related to other ratings .....	14
3.7 Index of abbreviations .....	15
5 Ratings .....	15
5.3 Rated insulation levels .....	16
5.3.3 Other requirements for primary terminals insulation .....	16
5.3.5 Insulation requirements for secondary terminals .....	17
5.3.501 Electromagnetic unit insulation requirements .....	17
5.4 Rated frequency .....	17
5.5 Rated output .....	17
5.5.501 Rated output values .....	17
5.5.502 Rated thermal limiting output .....	18
5.5.503 Rated output values for residual voltage windings .....	18
5.5.504 Rated thermal limiting output for residual voltage windings .....	18
5.6 Rated accuracy class .....	18
5.6.501 Accuracy requirements for measuring capacitor voltage transformer .....	18
5.6.502 Accuracy requirements for protective capacitor voltage transformers .....	19
5.501 Standard values of rated voltages .....	20
5.501.1 Rated primary voltages $U_{Pr}$ .....	20
5.501.2 Rated secondary voltages .....	20
5.501.3 Rated voltages for secondary winding intended to produce a residual voltage .....	21
5.501.4 Standard values of rated voltage factor .....	21
6 Design and construction .....	22
6.1 Requirements for liquids used in equipment .....	22
6.1.4 Liquid tightness .....	22
6.7 Mechanical requirements .....	22
6.8 Multiple chopped impulse on primary terminals .....	22
6.9 Internal arc fault protection requirements .....	22
6.13 Markings .....	22
6.13.501 Terminal markings .....	22
6.13.502 Rating plate markings .....	23
6.501 Short circuit withstand capability .....	27
6.502 Ferro-resonance .....	27
6.502.1 General .....	27
6.502.2 Transients of ferro-resonance oscillations .....	27
6.503 Transient response .....	28
6.503.1 General .....	28
6.503.2 Requirements for transient response .....	28
6.503.3 Standard transient response classes .....	28

6.504 Requirements for carrier – frequency accessories .....	29
6.504.1 General .....	29
6.504.2 Drain coil .....	29
6.504.3 Voltage limitation device .....	29
7 Tests .....	30
7.1 General .....	30
7.1.2 List of tests .....	30
7.1.3 Sequence of tests .....	31
7.2 Type tests .....	33
7.2.2 Temperature-rise test .....	33
7.2.3 Impulse voltage withstand test on primary terminals .....	34
7.2.4 Wet test for outdoor type transformers .....	35
7.2.6 Test for accuracy .....	35
7.2.8 Enclosure tightness test at ambient temperature .....	37
7.2.501 Capacitance and $\tan\delta$ measurement at power-frequency .....	37
7.2.502 Short-circuit withstand capability test .....	38
7.2.503 Ferro-resonance tests .....	39
7.2.504 Transient response test .....	39
7.2.505 Type test for carrier frequency accessories .....	41
7.3 Routine tests .....	42
7.3.1 Power-frequency voltage withstand tests on primary terminals .....	42
7.3.2 Partial discharge measurement .....	44
7.3.5 Test for accuracy .....	44
7.3.7 Enclosure tightness test at ambient temperature .....	46
7.3.8 Pressure test for the enclosure .....	46
7.3.501 Ferro-resonance check .....	46
7.3.502 Routine tests for carrier frequency accessories .....	46
7.4 Special tests .....	47
7.4.1 Chopped impulse voltage withstand test on primary terminals .....	47
7.4.2 Multiple chopped impulse test on primary terminals .....	47
7.4.3 Measurement of capacitance and dielectric dissipation factor .....	47
7.4.6 Internal arc fault test .....	47
7.4.501 Determination of the temperature coefficient (TC) .....	47
7.4.502 Tightness design test of capacitor units .....	47
Annex 5A (normative) Typical diagrammeme of a capacitor voltage transformer .....	49
Annex 5B (informative) Transient response of capacitor voltage transformer under fault conditions .....	50
Annex 5C (normative) High-frequency characteristics of capacitor voltage transformers .....	51
Bibliography .....	52
 Figure 501 – Error diagram of a capacitor voltage transformer for accuracy classes 0,2, 0,5 and 1,0 .....	19
Figure 502 – Capacitor voltage transformer with a single secondary .....	23
Figure 503 – Capacitor voltage transformer with two secondaries .....	23
Figure 504 – Capacitor voltage transformer with two tapped secondaries .....	23
Figure 505 – Capacitor voltage transformer with one residual voltage winding and a single secondary .....	23

Figure 506 – Example of a typical rating plate.....	26
Figure 507 – Transient response of a capacitor voltage transformer .....	28
Figure 508 – Flow charts test sequence to be applied when performing type test (Figure 508a) and routine test (Figure 508b).....	32
Figure 509 – Diagram of a capacitor voltage transformer for the transient response test using equivalent circuit method.....	40
Figure 510 – Series burden.....	41
Figure 511 – Pure resistance .....	41
Figure 512 – Example of an error diagramme of class 1 CVT for accuracy check with the equivalent circuit.....	45
Figure 5A.1 – Example of a diagram for a capacitor voltage transformer.....	49
Figure 5A.2 – Example of a diagram for a capacitor voltage transformer with carrier- frequency accessories .....	49
Table 501 – Limits of voltage error and phase displacement for measuring capacitor voltage transformers .....	19
Table 502 – Limits of voltage error and phase displacement for protective capacitor voltage transformers .....	20
Table 503 – Rated secondary voltages for capacitor voltage transformers to produce a residual voltage .....	21
Table 504 – Standard values of rated voltage factors for accuracy and thermal requirements.....	21
Table 505 – Marking of the rating plate .....	23
Table 506a – Ferro-resonance requirements.....	27
Table 506b – Ferro-resonance requirements.....	28
Table 507 – Standard transient response values and classes .....	29
Table 10 – List of tests .....	31
Table 508 – Test voltage for temperature rise test .....	34
Table 509– Burden ranges for accuracy tests .....	36
Table 510 – Test voltages for units, stacks and complete capacitor voltage divider.....	43
Table 511 – Accuracy check points (example) .....	45
Table 512 – Ferro resonance check .....	46

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INSTRUMENT TRANSFORMERS –****Part 5: Additional requirements for capacitor voltage transformers****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This International Standard IEC 61869-5 specific clauses for capacitor voltage transformers has been prepared by IEC technical committee 38: Instrument transformers.

This standard replaces IEC 60044-5 regarding capacitor voltage transformers as well as IEC-PAS 60044-5 for capacitor voltage transformers.

The text of this standard is based on the following documents:

FDIS	Report on voting
38/411/FDIS	38/414/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

This standard is Part 5 of IEC 61869, published under the general title *Instrument transformers*.

This part 5 is to be read in conjunction with, and is based on, IEC 61869-1, *General Requirements* – first edition (2007) – however the reader is encouraged to use its most recent edition.

This Part 5 follows the structure of IEC 61869-1 and supplements or modifies its corresponding clauses.

When a particular clause/subclause of Part 1 is not mentioned in this Part 5, that clause/subclause applies as far as is reasonable. When this standard states “addition”, “modification” or “replacement”, the relevant text in Part 1 is to be adapted accordingly.

For additional clauses, subclauses, figures, tables, annexes or note, the following numbering system is used:

- clauses, subclauses, tables and figures and notes that are numbered starting from 501 are additional to those in Part 1;
- additional annexes are lettered 5A, 5B, etc.

An overview of the planned set of standards at the date of publication of this document is given below. The updated list of standards issued by IEC TC38 is available at the website: [www.iec.ch](http://www.iec.ch).

PRODUCT FAMILY STANDARDS	PRODUCT STANDARD	PRODUCTS	OLD STANDARD
<b>61869-1</b> GENERAL REQUIREMENTS FOR INSTRUMENT TRANSFORMERS	<b>61869-6</b> ADDITIONAL GENERAL REQUIREMENT FOR ELECTRONIC INSTRUMENT TRANSFORMERS AND LOW POWER STAND ALONE SENSORS	<b>61869-2</b> ADDITIONAL REQUIREMENTS FOR CURRENT TRANSFORMERS	60044-1 60044-6
		<b>61869-3</b> ADDITIONAL REQUIREMENTS FOR INDUCTIVE VOLTAGE TRANSFORMERS	60044-2
		<b>61869-4</b> ADDITIONAL REQUIREMENTS FOR COMBINED TRANSFORMERS	60044-3
		<b>61869-5</b> ADDITIONAL REQUIREMENTS FOR CAPACITIVE VOLTAGE TRANSFORMERS	60044-5
		<b>61869-7</b> ADDITIONAL REQUIREMENTS FOR ELECTRONIC VOLTAGE TRANSFORMERS	60044-7
	<b>61869-8</b> ADDITIONAL REQUIREMENTS FOR ELECTRONIC CURRENT TRANSFORMERS	<b>61869-8</b> ADDITIONAL REQUIREMENTS FOR ELECTRONIC CURRENT TRANSFORMERS	60044-8
		<b>61869-9</b> DIGITAL INTERFACE FOR INSTRUMENT TRANSFORMERS	
		<b>61869-10</b> ADDITIONAL REQUIREMENTS FOR LOW-POWER STAND-ALONE CURRENT SENSORS	
		<b>61869-11</b> ADDITIONAL REQUIREMENTS FOR LOW-POWER STAND ALONE VOLTAGE SENSOR	
		<b>61869-12</b> ADDITIONAL REQUIREMENTS FOR COMBINED ELECTRONIC INSTRUMENT TRANSFORMER OR COMBINED STAND ALONE SENSORS	
		<b>61869-13</b> STAND ALONE MERGING UNIT	

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

## INSTRUMENT TRANSFORMERS –

### Part 5: Additional requirements for capacitor voltage transformers

#### 1 Scope

This part of IEC 61869 applies to new single-phase capacitor voltage transformers connected between line and ground for system voltages  $U_m \geq 72,5$  kV at power frequencies from 15 Hz to 100 Hz. They are intended to supply a low voltage for measurement, control and protective functions.

The capacitor voltage transformer can be equipped with or without carrier-frequency accessories for power line carrier-frequency (PLC) application at carrier frequencies from 30 kHz to 500 kHz.

The base requirements for coupling capacitors and capacitors dividers are defined in IEC 60358. The transmission requirements for coupling devices for power line carrier (PLC) system are defined in IEC 60481.

The measurement application includes both indication measuring and revenue measuring.

NOTE 501 Diagrams of capacitor voltage transformer to which this standard applies are given in Figures 5A.1 and 5A.2.

#### 2 Normative references

Clause 2 of IEC 61869-1:2007 is applicable with the following additions:

IEC 61869-1:2007, *Instrument transformers – Part 1: General requirements*

IEC 60038 ed7.0 (2009-06) – *IEC standard voltages*

IEC 60060-1, *High-voltage test techniques – Part 1: General definitions and test requirements*

IEC 60050-436, *International Electrotechnical Vocabulary (IEV) – Chapter 436: Power capacitors*

IEC 60050-601, *International Electrotechnical Vocabulary (IEV) – Chapter 601: Generation, transmission and distribution of electricity – General*

IEC 60050-604, *International Electrotechnical Vocabulary (IEV) – Chapter 604: Generation, transmission and distribution of electricity – Operation*

IEC 60358, *Coupling capacitors and capacitor dividers*

IEC 60481, *Coupling devices for power line carrier systems*

#### 3 Terms and Definitions

For the purpose of this document, the terms and definitions of IEC 61869-1 apply with the following additions: