

TECHNICAL REPORT



**Communication networks and systems for power utility
automation –**

**Part 7-6: Guideline for definition of Basic Application Profiles (BAPs) using
IEC 61850**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2019 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

TECHNICAL REPORT



**Communication networks and systems for power utility
automation –
Part 7-6: Guideline for definition of Basic Application Profiles (BAPs) using
IEC 61850**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 33.200

ISBN 978-2-8322-6418-8

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
2 Normative references	9
3 Terms and definitions	10
4 Methodology for profiling	11
4.1 General.....	11
4.2 IEC 61850 profiling concept	12
4.2.1 General	12
4.2.2 IEC 61850 profile definition.....	13
4.3 Basic Application Profiles (BAPs).....	14
4.4 Basic Application Interoperability Profiles (BAIOPs).....	16
4.5 Process from a use case to interoperability on SGAM function layer	18
4.6 Managing profiles	20
4.7 Implementation of BAPs in real projects.....	20
Annex A (informative) Example for BAP of distributed automation function “reverse blocking” using BAP template	21
A.1 Functional description	21
A.2 Description of use case and associated roles/actors	23
A.2.1 List of roles / actors	23
A.2.2 Use case	23
A.2.3 Sequence diagram of typical interactions.....	24
A.3 Logical architecture.....	25
A.4 Allocation variants (conditional)	25
A.5 Functional variants.....	25
A.5.1 Core functional variants	25
A.5.2 Noncore functional variants	25
A.6 Performance requirements.....	26
A.6.1 Functional related	26
A.6.2 Service related	26
A.7 Description of data model per actor.....	26
A.7.1 General	26
A.7.2 PTOC for blocked function (infeed bay)	27
A.7.3 PTOC for blocking function 1 to n (outflow bay(s))	28
A.7.4 Monitoring	28
A.8 Communication services	29
A.9 Device related requirements (conditional) – Test behaviour	29
A.10 Engineering tool related requirements.....	29
A.11 Naming rules	29
A.12 Capabilities for testing	29
Annex B (informative) Example for BAP of “condition monitoring diagnosis functions of on-load tap changer” using BAP template	30
B.1 Functional description	30
B.2 Description of use case and associated roles/actors	32
B.2.1 List of roles / actors	32
B.2.2 Use case	33
B.2.3 Sequence diagram of typical interactions.....	34

B.3	Logical Architecture	37
B.3.1	Overview	37
B.3.2	Monitoring operation property	38
B.3.3	Monitoring operation counts.....	38
B.3.4	Monitoring contact abrasion.....	39
B.3.5	Monitoring LTC oil temperature and flow.....	39
B.3.6	Monitoring operation of oil filter unit.....	40
B.4	Allocation variants (conditional)	40
B.5	Functional variants.....	40
B.6	Performance requirements	40
B.6.1	Functional related	40
B.6.2	Service related	40
B.7	Description of data model per actor.....	41
B.7.1	General	41
B.7.2	SLTC	41
B.7.3	YLTC	44
B.7.4	TTRQ	44
B.7.5	TCTR.....	44
B.7.6	SIML.....	45
B.7.7	TTMP	45
B.7.8	KFIL	46
B.8	Communication services	46
B.9	Device related requirements (conditional)	46
B.10	Engineering tool related requirements.....	46
B.11	Naming rules	46
B.12	Capabilites for testing	46
Annex C (informative)	Example for BAP of protection function “line distance protection” using BAP template.....	47
C.1	Functional description	47
C.2	Description of use case and associated roles/actors	47
C.2.1	List of roles / actors	47
C.2.2	Use case	48
C.2.3	Sequence diagram of typical interactions.....	49
C.3	Logical architecture.....	50
C.4	Allocation variants (conditional)	50
C.5	Functional variants.....	50
C.5.1	Core functional variants	50
C.5.2	Noncore functional variants (different features for testing)	51
C.6	Performance requirements).....	51
C.6.1	Functional related	51
C.6.2	Service related	51
C.7	Description of data model per actor.....	52
C.8	Communication services	54
C.8.1	General	54
C.8.2	Variant FA:	54
C.8.3	Variant FB:	55
C.9	Device related requirements (conditional)	55
C.9.1	Degraded operation behaviour.....	55
C.10	Engineering tool related requirements.....	56

C.11	Naming rules	56
C.12	Capabilites for testing	56
Annex D (informative)	Example of BAIOP for BAP reverse blocking (without process bus)	57
D.1	General.....	57
D.2	Test description	57
D.2.1	General	57
D.2.2	Normal sequence of reverse blocking	58
D.2.3	Functional description of test environment	60
D.2.4	Test reverse blocking – role blocking (without output to process).....	60
D.2.5	Test reverse blocking – role blocked.....	62
Annex E (informative)	Example of BAIOP for BAP of “condition monitoring diagnosis functions of on-load tap changer”	65
E.1	General.....	65
E.2	Test description	65
E.2.1	Overview	65
E.2.2	Sequence of monitoring the motor drive current value	66
Bibliography	68
Figure 1	– Stakeholders collaborate in user groups to create a common IOP profile	12
Figure 2	– Framework for profiling IEC 61850	13
Figure 3	– Aggregating BAPs.....	16
Figure 4	– Framework for testing a profile	18
Figure 5	– Relation between BAP and SGAM interoperability	19
Figure 6	– Device features covered by profiles depending on compatibility levels according to IEC Technical Committee 65, Industrial-process measurement, control and automation	19
Figure 7	– BAPs and BAIOPs as building blocks for user/project specific implementation and testing	20
Figure A.1	– Behaviour in the event of faults on an outflow bay	21
Figure A.2	– Behaviour in the event of busbar faults	22
Figure A.3	– List of roles / actors reverse blocking	23
Figure A.4	– Use case reverse blocking	23
Figure A.5	– Sequence diagram reverse blocking	24
Figure A.6	– Logical architecture reverse blocking	25
Figure B.1	– Structure of LTC	30
Figure B.2	– Overview of system configuration of LTC condition monitoring	31
Figure B.3	– Typical system configuration of LTC condition monitoring system	31
Figure B.4	– Use cases	33
Figure B.5	– Sequence diagram for monitoring operation property	34
Figure B.6	– Sequence diagram for monitoring operation counts.....	35
Figure B.7	– Sequence diagram for monitoring contact abrasion	35
Figure B.8	– Sequence diagram for monitoring oil temperature and flow	36
Figure B.9	– Sequence diagram for monitoring operation of oil filter unit.....	36
Figure B.10	– Logical architecture.....	37
Figure B.11	– Logical architecture for monitoring operation property.....	38

Figure B.12 – Logical architecture for monitoring operation counts	38
Figure B.13 – Logical architecture for monitoring contact abrasion.....	39
Figure B.14 – Logical architecture for monitoring LTC oil temperature and flow	39
Figure B.15 – Logical architecture for monitoring operation of oil filter unit.....	40
Figure C.1 – Use case distance protection	48
Figure C.2 – Sequence diagram distance protection	49
Figure C.3 – Logical architecture distance protection	50
Figure D.1 – Normal sequence of application function reverse blocking	58
Figure D.2 – Functional test environment.....	60
Figure D.3 – Test of role “blocking”	60
Figure D.4 – Test of role “blocked”.....	62
Figure E.1 – Sequence of monitoring the motor drive current value.....	66
Table A.1 – Selection of data attributes for PTOC of actor blocked	27
Table A.2 – Selection of data attributes for PTOC of actor blocking	28
Table A.3 – Selection of data attributes of PTOC for monitoring.....	28
Table B.1 – List of actors	32
Table B.2 – Selection of data attributes of SLTC.....	41
Table B.3 – Selection of data attributes of YLTC.....	44
Table B.4 – Selection of data attributes of TTRQ	44
Table B.5 – Selection of data attributes of TCTR	44
Table B.6 – Selection of data attributes of SIML.....	45
Table B.7 – Selection of data attributes of TTMP	45
Table B.8 – Selection of data attributes of KFIL	46
Table C.1 – Description of data model	52
Table C.2 – Services for variant FA	54
Table C.3 – Services for variant FB	55
Table C.4 – Degraded operation behaviours	56
Table D.1 – Description of normal operation of application function reverse blocking.....	58
Table D.2 – Description of sequence for test of role “blocking”.....	61
Table D.3 – Description of sequence for test of role “blocked”	63
Table E.1 – Description of the sequence of monitoring the motor drive current value	67

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**COMMUNICATION NETWORKS AND SYSTEMS FOR POWER UTILITY
AUTOMATION –****Part 7-6: Guideline for definition of Basic Application Profiles (BAPs)
using IEC 61850****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a Technical Report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

International Standard IEC 61850 has been prepared IEC technical committee 57: Power systems management and associated information exchange.

The text of this Technical Report is based on the following documents:

Draft TR	Report on voting
57/1986/DTR	57/2034/RVDTR

Full information on the voting for the approval of this Technical Report can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 61850 series, published under the general title *Communication networks and systems for power utility automation*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

The IEC 61850 series of standards offers a broad basis for communication networks and systems in power utility automation. Due to its broad coverage of power utility automation applications, it is up to the standard's user (utility, vendor, system integrator, etc.) to pick and choose specific options from the standard in order to meet the requirements of the intended objective. As a consequence, implementations of IEC 61850 represent specific subsets of the standard.

In the context of standards the term “profile” is commonly used to describe a subset of an entity (e.g. standard, model, rules).

Accordingly an IEC 61850 standard profile contains a selection of data models (mandatory elements), applicable communication services and relevant engineering conventions (based on the Substation Configuration Language SCL defined in IEC 61850-6) for an application function of a specific use case in the domain of power utility automation.

Depending on the scope and objective different profile types can be distinguished:

- User profile – defined subset that is valid for a specific user / organization (e.g. utility)
- Product / device profile – implemented subset in a specific vendor product /device
- Domain profile – defined subset for a specific domain and relevant use cases (e.g. monitoring of substation)
- Application / function profile – subset covering a specific application or function (e.g. substation interlocking)

These profile types target the reduction of complexity and facilitation of interoperability for their specific scope and during engineering and device / substation lifetime. In order to achieve both these goals, a properly defined profile and appropriate implementations (processes, tools, products) that support the profile are required.

COMMUNICATION NETWORKS AND SYSTEMS FOR POWER UTILITY AUTOMATION –

Part 7-6: Guideline for definition of Basic Application Profiles (BAPs) using IEC 61850

1 Scope

This part of IEC 61850, which is a technical report, is focused on building application / function profiles and specifies a methodology to define Basic Application Profiles (BAPs). These Basic Application Profiles provide a framework for interoperable interaction within or between typical substation automation functions. BAPs are intended to define a subset of features of IEC 61850 in order to facilitate interoperability in a modular way in practical applications.

It is the intention of this document to provide a common and generic way to describe the functional behaviour of a specific application function in the domain of power utility automation systems as a common denominator of various possible interpretations/implementations of using IEC 61850.

The guidelines in this document are based on the functional definitions of

- IEC 61850-5, Communication requirements for functions and device models, which gives a comprehensive overview of all application functions needed in a state-of-the-art substation automation implementation.
- IEC TR 61850-7-500, Basic information and communication structure – Use of logical nodes for modelling application functions and related concepts and guidelines for substations, which illustrates and explains application functions for the substation/protection domain of Logical Nodes in modelling simple and complex functions, to improve common understanding in modelling and data exchange, and finally to lead to interoperable implementations.
- IEC TR 61850-90-3, Using IEC 61850 for condition monitoring diagnosis and analysis, which gives use cases and data modelling for condition monitoring diagnosis and analysis functions for substation and power grid facilities.

This document does not describe the applications and respective implementation requirements; the focus is on their typical information exchange including data and communication services and engineering conventions.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61850-5:2013, *Communication networks and systems for power utility automation - Part 5: Communication requirements for functions and device models*

IEC 61850-7-2, *Communication networks and systems for power utility automation - Part 7-2: Basic information and communication structure - Abstract communication service interface (ACSI)*

IEC TR 61850-90-3, *Communication networks and systems for power utility automation - Part 90-3: Using IEC 61850 for condition monitoring diagnosis and analysis*

IEC TR 62361-103:2018, *Power systems management and associated information exchange - Interoperability in the long term - Part 103: Standard profiling*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1

Basic Application Profile

BAP

user/user group agreed-upon selection and interpretation of relevant parts of the applicable standards and specifications, intended to be used as building blocks for interoperable user/project specifications

Note 1 to entry: BAPs must not have options; all selected criteria are required to facilitate interoperability. For implementation in projects, BAPs might be extended or refined to meet the user specific requirements.

[SOURCE: CEN-CENELEC-ETSI SG-CG Report on Interoperability CEN_9762_CLC_9624 – Clause 12.1, Terms and definitions]

3.2

Basic Application Interoperability Profile

BAIOP

interoperability test for BAPs defined by test sequences and test cases

[SOURCE: CEN-CENELEC-ETSI SG-CG Report on Interoperability CEN_9762_CLC_9624 – Clause 12.1, Terms and definitions]

3.3

compliance

accordance of the whole implementation with specified requirements or standards

Note 1 to entry: Some requirements in the specified standards may not be implemented.

[SOURCE: CEN-CENELEC-ETSI SG-CG Report on Interoperability CEN_9762_CLC_9624 – Clause 12.1, Terms and definitions]

3.4

conformance

accordance of the implementation of a product, process or service with all specified requirements or standards

Note 1 to entry: Additional features to those in the requirements / standards may be included.

Note 2 to entry: All features of the standard/specification are implemented and in accordance, but some additional features are not covered by the standard/specification.

[SOURCE: CEN-CENELEC-ETSI SG-CG Report on Interoperability CEN_9762_CLC_9624 – Clause 12.1, Terms and definitions]