

**Kaablite kohtkindla ja paindliku lahtise asetuse
süsteemid**

**Articulated systems and flexible systems for cable
guiding**

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 62549:2011 sisaldab Euroopa standardi EN 62549:2011 ingliskeelset teksti.	This Estonian standard EVS-EN 62549:2011 consists of the English text of the European standard EN 62549:2011.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 02.12.2011.	Date of Availability of the European standard is 02.12.2011.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 29.120.10

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Aru 10, 10317 Tallinn, Eesti; www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:
Aru 10, 10317 Tallinn, Estonia; www.evs.ee; phone 605 5050; e-mail info@evs.ee

Articulated systems and flexible systems for cable guiding
(IEC 62549:2011)

Systèmes articulés et souples pour
guidage de câbles
(CEI 62549:2011)

Gelenkige Systeme und flexible Systeme
für die Leitungsführung
(IEC 62549:2011)

This European Standard was approved by CENELEC on 2011-11-28. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 23A/636/FDIS, future edition 1 of IEC 62549, prepared by SC 23A, "Cable management systems", of IEC/TC 23, "Electrical accessories" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 62549:2011.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2012-08-28
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2014-11-28

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 62549:2011 was approved by CENELEC as a European Standard without any modification.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60068-2-75	1997	Environmental testing - Part 2-75: Tests - Test Eh: Hammer tests	EN 60068-2-75	1997
IEC 60417	Data- base	Graphical symbols for use on equipment	-	-
IEC 60423	2007	Conduit systems for cable management - Outside diameters of conduits for electrical installations and threads for conduits and fittings	EN 60423	2007
IEC 60529 + A1	1989 1999	Degrees of protection provided by enclosures (IP Code)	EN 60529 + corr. May + A1	1991 1993 2000
IEC 60670-1 + corr. February	2002 2003	Boxes and enclosures for electrical accessories for household and similar fixed electrical installations - Part 1: General requirements	EN 60670-1 + corr. March + corr. November	2005 2010 2007
IEC 60670-22	2003	Boxes and enclosures for electrical accessories for household and similar fixed electrical installations - Part 22: Particular requirements for connecting boxes and enclosures	EN 60670-22	2006
IEC 60670-23 (mod)	2006	Boxes and enclosures for electrical accessories for household and similar fixed electrical installations - Part 23: Particular requirements for floor boxes and enclosures	EN 60670-23	2008
IEC 60670-24	2011	Boxes and enclosures for electrical accessories for household and similar fixed electrical installations - Part 24: Particular requirements for enclosures for housing protective devices and other power dissipating electrical equipment	-	-
IEC 60695-2-11 + corr. January	2000 2001	Fire hazard testing - Part 2-11: Glowing/hot-wire based test methods - Glow-wire flammability test method for end-products	EN 60695-2-11	2001
IEC 60695-11-5	2004	Fire hazard testing - Part 11-5: Test flames - Needle-flame test method - Apparatus, confirmatory test arrangement and guidance	EN 60695-11-5	2005

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 62262	2002	Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code)	EN 62262	2002

This document is a preview generated by EVS

CONTENTS

FOREWORD.....	4
1 Scope.....	6
2 Normative references	6
3 Terms and definitions	7
4 General requirements	9
5 General conditions for tests.....	9
6 Classification.....	10
6.1 According to temperatures as given in Table 1 and Table 2.....	10
6.2 According to resistance to impact.....	10
6.3 According to the installation onfloor.....	11
6.4 According to electrical continuity characteristic	11
6.5 According to degrees of protection, if any, provided by the system according to IEC 60529:1989	11
7 Marking and documentation.....	11
8 Dimensions	12
9 Construction.....	12
9.1 Sharp edges.....	12
9.2 Minimum bending radius.....	12
9.3 Cable retention.....	13
9.4 Protection against ingress of solid foreign objects	13
9.5 Protection against ingress of water.....	14
9.6 Protection against access to hazardous parts.....	14
9.7 Relieve terminals from strain	14
9.8 Apparatus mounting	15
9.9 Reliable connection to earth for accessible conductive parts	16
9.10 Electrically protective separation	16
9.11 Inlet openings.....	16
9.12 Mechanical connections	16
10 Mechanical properties	17
10.1 Mechanical strength	17
10.2 Impact test	17
10.3 External load test for apparatus mounting	19
10.3.1 Fixing test for apparatus mounting of socket-outlets	19
10.3.2 Fixing test for apparatus mounting other than socket-outlets	19
10.4 External load test	19
10.4.1 Axial load test.....	19
10.4.2 Compression test.....	20
11 Electrical properties.....	21
11.1 Electrical continuity	21
11.2 Void	22
12 Fire hazard.....	22
12.1 Contribution to fire.....	22
12.2 Void	23
13 External influences	23
13.1 Degree of protection provided by enclosure.....	23

13.1.2 Protection against ingress of solid foreign objects	23
13.1.3 Protection against ingress of water	23
13.1.4 Protection against access to hazardous parts	24
14 Electromagnetic compatibility	24
Annex A (normative) Summary of requirements to be applied to boxes	38
Annex B (normative) IK code	39
Bibliography	40
Figure 1 – Example of articulated system for cable guiding	24
Figure 2 – Examples of flexible system for cable guiding	25
Figure 3 – Examples of application of systems for cable guiding	29
Figure 4 – Minimum bending radius measurement	29
Figure 5 – Examples of arrangements for cable retention tests	30
Figure 6 – Typical apparatus for testing the resistance of cable anchorage to pull force	31
Figure 7 – Typical apparatus for testing the resistance of cable anchorage to twist force	32
Figure 8 – Examples of arrangement for impact test	34
Figure 9 – Examples of arrangement for axial load test	36
Figure 10 – Arrangement for compression test	37
Table 1 – Minimum application temperature	10
Table 2 – Maximum application temperature	10
Table 3 – Torque values for screwed connections	14
Table 4 – Forces and torques to be applied to cable anchorage	15

ARTICULATED SYSTEMS AND FLEXIBLE SYSTEMS FOR CABLE GUIDING

1 Scope

This International Standard specifies requirements and tests for systems with adaptable linear geometry for cable guiding intended for the accommodation and retention of cables and possibly other electrical equipment in electrical and/or communication systems installations. The maximum voltage of these installations is 1 000 V a.c. and 1 500 V d.c.

This standard does not apply to cable trunking systems, cable ducting systems, conduit systems, cable tray systems, cable ladder systems, powertrack systems, energy conveying chains or equipment covered by other standards.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-2-75:1997, *Environmental testing – Part 2-75: Tests – Test Eh: Hammer tests*

IEC 60417, *Graphical symbols for use on equipment*

IEC 60423:2007, *Conduit systems for cable management – Outside diameters of conduits for electrical installations and threads for conduits and fittings*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*
Amendment 1 (1999)¹

IEC 60670-1:2002, *Boxes and enclosures for electrical accessories for household and similar fixed electrical installations – Part 1: General requirements*

IEC 60670-22:2003, *Boxes and enclosures for electrical accessories for household and similar fixed electrical installations – Part 22: Particular requirements for connecting boxes and enclosures*

IEC 60670-23:2006, *Boxes and enclosures for electrical accessories for household and similar fixed electrical installations – Part 23: Particular requirements for floor boxes and enclosures*

IEC 60670-24:2011, *Boxes and enclosures for electrical accessories for household and similar fixed electrical installations – Part 24: Particular requirements for enclosures for housing protective devices and other power dissipating electrical equipment*

IEC 60695-2-11:2000, *Fire hazard testing – Part 2-11: Glowing/hot-wire based test methods – Glow-wire flammability test method for end-products*
Corrigendum (2001)

¹ There exists a consolidation version of IEC 60529 (2001), which contains IEC 60529 (1989) and its amendment 1 (1999).

IEC 60695-11-5:2004, *Fire hazard testing – Part 11-5: Test flames – Needle-flame test method - Apparatus, confirmatory test arrangement and guidance*

IEC 62262:2002, *Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code)*

3 Terms and definitions

For the purpose of this document, the following definitions apply.

3.1

articulated system for cable guiding

assembly comprising an articulated length for cable guiding and possibly other system components to provide accommodation of cables and possibly the accommodation of other electrical equipment

NOTE 1 An example of an articulated system for cable guiding is shown in Figure 1.

NOTE 2 Examples of application are shown in Figure 3.

3.2

flexible system for cable guiding

assembly comprising a flexible length for cable guiding and possibly other system components to provide accommodation of cables and possibly the accommodation of other electrical equipment

NOTE 1 Examples of flexible system for cable guiding are shown in Figure 2.

NOTE 2 Examples of application are shown in Figure 3.

3.3

system component

part of the system which includes

- a) articulated length for cable guiding or flexible length for cable guiding,
- b) box,
- c) apparatus mounting device,
- d) fixing device,
- e) system accessory

NOTE A system does not necessarily include all system components a) to e). Different combinations of system components may be used.

3.4

articulated length for cable guiding

system component of an articulated system for cable guiding consisting of several elements which are connected by articulated joint(s)

3.5

flexible length for cable guiding

system component of a flexible system for cable guiding with adaptable linear geometry other than articulated length

3.6

enclosure

combination of parts, such as boxes, covers, cover-plates, lids, box extensions, accessories, etc. providing, after assembly and installation as in normal use, an appropriate protection against external influences and a defined protection against contact with enclosed live parts from any accessible direction