

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**High-voltage switchgear and controlgear –
Part 203: Gas-insulated metal-enclosed switchgear for rated voltages above
52 kV**

**Appareillage à haute tension –
Partie 203: Appareillage sous enveloppe métallique à isolation gazeuse de
tensions assignées supérieures à 52 kV**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2011 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**High-voltage switchgear and controlgear –
Part 203: Gas-insulated metal-enclosed switchgear for rated voltages above
52 kV**

**Appareillage à haute tension –
Partie 203: Appareillage sous enveloppe métallique à isolation gazeuse de
tensions assignées supérieures à 52 kV**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

XC

ICS 29.130.10

ISBN 978-2-88912-664-4

CONTENTS

FOREWORD.....	6
1 General	8
1.1 Scope.....	8
1.2 Normative references	8
2 Normal and special service conditions.....	9
2.1 Normal service conditions	9
2.2 Special service conditions	9
3 Terms and definitions	10
4 Ratings.....	12
4.1 Rated voltage (U_r)	13
4.2 Rated insulation level.....	13
4.3 Rated frequency (f_r).....	15
4.4 Rated normal current and temperature rise	15
4.4.1 Rated normal current (I_r)	15
4.4.2 Temperature rise	15
4.5 Rated short-time withstand current (I_k)	15
4.6 Rated peak withstand current (I_p)	15
4.7 Rated duration of short-circuit (t_k).....	15
4.8 Rated supply voltage of closing and opening devices and of auxiliary and control circuits (U_a)	15
4.9 Rated supply frequency of closing and opening devices and of auxiliary circuits	16
4.10 Rated pressure of compressed gas supply for controlled pressure systems	16
4.11 Rated filling levels for insulation and/or operation.....	16
5 Design and construction.....	16
5.1 Requirements for liquids in switchgear and controlgear	16
5.2 Requirements for gases in switchgear and controlgear	16
5.3 Earthing of switchgear and controlgear	16
5.4 Auxiliary and control equipment	17
5.5 Dependent power operation	17
5.6 Stored energy operation.....	17
5.7 Independent manual or power operation (independent unlatched operation)	17
5.8 Operation of releases	17
5.9 Low- and high-pressure interlocking and monitoring devices	17
5.10 Nameplates	18
5.11 Interlocking devices	18
5.12 Position indication.....	18
5.13 Degrees of protection by enclosures	18
5.14 Creepage distances for outdoor insulators	18
5.15 Gas and vacuum tightness.....	19
5.15.1 Controlled pressure systems for gas	19
5.15.2 Closed pressure systems for gas	19
5.15.3 Sealed pressure systems	19
5.16 Liquid tightness	19
5.17 Fire hazard (flammability)	19
5.18 Electromagnetic compatibility (EMC).....	19

5.19	X-Ray emission	20
5.20	Corrosion	20
5.101	Pressure coordination	20
5.102	Internal fault	21
5.103	Enclosures	22
5.104	Partitions	23
5.105	Pressure relief	25
5.106	Noise	26
5.107	Interfaces	26
6	Type tests	27
6.1	General	27
6.1.1	Grouping of tests	27
6.1.2	Information for identification of specimens	28
6.1.3	Information to be included in type-tests reports	29
6.2	Dielectric tests	29
6.2.1	Ambient air conditions during tests	29
6.2.2	Wet test procedure	29
6.2.3	Conditions of switchgear and controlgear during dielectric tests	29
6.2.4	Criteria to pass the test	29
6.2.5	Application of the test voltage and test conditions	29
6.2.6	Tests of switchgear and controlgear of $U_r \leq 245$ kV	30
6.2.7	Tests of switchgear and controlgear of rated voltage $U_r > 245$ kV	30
6.2.8	Artificial pollution tests for outdoor insulators	31
6.2.9	Partial discharge tests	31
6.2.10	Dielectric tests on auxiliary and control circuits	32
6.2.11	Voltage test as condition check	32
6.3	Radio interference voltage (r.i.v.) test	32
6.4	Measurement of the resistance of circuits	32
6.4.1	Main circuit	32
6.4.2	Auxiliary circuits	32
6.5	Temperature-rise tests	32
6.5.1	Conditions of the switchgear and controlgear to be tested	32
6.5.2	Arrangement of the equipment	32
6.5.3	Measurement of the temperature and the temperature rise	33
6.5.4	Ambient air temperature	33
6.5.5	Temperature-rise test of the auxiliary and control equipment	33
6.5.6	Interpretation of the temperature-rise tests	33
6.6	Short-time withstand current and peak withstand current tests	33
6.6.1	Arrangement of the switchgear and controlgear and of the test circuit	33
6.6.2	Test current and duration	33
6.6.3	Behaviour of switchgear and controlgear during test	33
6.6.4	Conditions of switchgear and controlgear after test	34
6.7	Verification of the protection	34
6.7.1	Verification of the IP coding	34
6.7.2	Verification of the IK coding	34
6.8	Tightness tests	34
6.8.1	Controlled pressure systems for gas	34
6.8.2	Closed pressure systems for gas	34
6.8.3	Sealed pressure systems	35

6.8.4	Liquid tightness tests	35
6.9	Electromagnetic compatibility tests (EMC).....	35
6.10	Additional tests on auxiliary and control circuits.....	35
6.11	X-radiation test procedure for vacuum interrupters	35
6.101	Verification of making and breaking capacities	35
6.102	Mechanical and environmental tests.....	35
6.103	Proof tests for enclosures	36
6.104	Pressure test on partitions	37
6.105	Test under conditions of arcing due to an internal fault.....	37
6.106	Insulator tests.....	38
6.107	Corrosion test on earthing connections	38
6.108	Corrosion tests on enclosures.....	39
7	Routine tests	39
7.1	Dielectric test on the main circuit	39
7.1.101	Power-frequency voltage tests on the main circuit	40
7.1.102	Partial discharge measurement.....	40
7.2	Tests on auxiliary and control circuits.....	40
7.3	Measurement of the resistance of the main circuit.....	40
7.4	Tightness test.....	40
7.5	Design and visual checks.....	40
7.101	Pressure tests of enclosures.....	40
7.102	Mechanical operation tests	41
7.103	Tests on auxiliary circuits, equipment and interlocks in the control mechanism	41
7.104	Pressure test on partitions	41
8	Guide to the selection of switchgear and controlgear	41
8.1	Selection of rated values.....	41
8.2	Continuous or temporary overload due to changed service conditions	41
9	Information to be given with enquiries, tenders and orders	42
9.1	Information with enquiries and orders.....	42
9.2	Information with tenders	42
10	Transport, storage, installation, operation and maintenance	42
10.1	Conditions during transport, storage and installation	42
10.2	Installation.....	42
10.3	Operation	47
10.4	Maintenance.....	48
11	Safety.....	48
12	Influence of the product on the environment.....	48
Annex A (normative)	Test procedure for dielectric test on three-phase encapsulated GIS, range II	49
Annex B (normative)	Methods for testing gas-insulated metal-enclosed switchgear under conditions of arcing due to an internal fault.....	50
Annex C (informative)	Technical and practical considerations of site testing	53
Annex D (informative)	Calculation of pressure rise due to an internal fault	58
Annex E (informative)	Information to be given with enquiries, tenders and orders.....	59
Annex F (informative)	Service continuity.....	65
Annex G (informative)	Insulation levels for GIS with rated voltages higher than 800 kV	74
Annex H (informative)	List of notes concerning certain countries.....	75

Bibliography	76
Figure 1 – Pressure coordination	20
Figure 2 – Example of arrangement of enclosures and gas compartments	25
Figure F.1 – Impact due to the removal of common partition between busbar-disconnector	66
Figure F.2 – Impact of GIS partitioning on service continuity	67
Figure F.3 – Single line diagram with gas partitioning scheme	67
Figure F.4 – Localisation and isolation	69
Figure F.5 – Removal of busbar disconnector in SECTION-1	69
Figure F.6 – Removal of busbar disconnector in SECTION-3	70
Figure F.7 – Extension	70
Figure F.8 – On-site dielectric test	71
Table 1 – Reference table of service conditions relevant to GIS	10
Table 2 – Rated insulation levels for rated voltages for equipment of range I	14
Table 3 – Rated insulation levels for rated voltages for equipment of range II	14
Table 4 – Performance criteria	22
Table 5 – Example of grouping of type tests	28
Table 6 – Test voltage for measuring PD intensity	31
Table 7 – On site test voltages	45
Table A.1 – Switching impulse test conditions above 245 kV	49
Table E.1 – Normal and special service conditions	59
Table E.2 – Ratings	60
Table E.3 – Design and construction	61
Table E.4 – Bus ducts	62
Table E.5 – Bushing	62
Table E.6 – Cable connection	63
Table E.7 – Transformer connection	63
Table E.8 – Current transformer	63
Table E.9 – Inductive voltage transformer	63
Table E.10 – Documentation for enquiries and tenders	64
Table F.1 – Example for service continuity requirements	72
Table G.1 – Insulation levels used for GIS with rated voltages higher than 800 kV in different countries	74

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 203: Gas-insulated metal-enclosed switchgear for rated voltages above 52 kV

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62271-203 has been prepared by subcommittee 17C: High-voltage switchgear and controlgear assemblies, of IEC technical committee 17: Switchgear and controlgear.

This second edition of IEC 62271-203 cancels and replaces the first edition of IEC 62271-203, published in 2003, and constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- adopting the structure and the content to IEC 62271-1,
- harmonisation with IEEE C37.122,
- addition of the new Annex F and the new Annex G.

The text of this standard is based on the following documents:

FDIS	Report on voting
17C/512/FDIS	17C/524/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The reader's attention is drawn to the fact that Annex H lists all of the 'in-some-country' clauses on differing practices of a less permanent nature relating to the subject of this standard.

This International Standard should be read in conjunction with IEC 62271-1:2007, to which it refers and which is applicable unless otherwise specified. In order to simplify the indication of corresponding requirements, the same numbering of clauses and subclauses is used as in IEC 62271-1. Amendments to these clauses and subclauses are given under the same numbering, whilst additional subclauses, are numbered from 101.

A list of all the parts of IEC 62271 series can be found under the general title *High-voltage switchgear and controlgear*, on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 203: Gas-insulated metal-enclosed switchgear for rated voltages above 52 kV

1 General

1.1 Scope

This part of IEC 62271 specifies requirements for gas-insulated metal-enclosed switchgear in which the insulation is obtained, at least partly, by an insulating gas other than air at atmospheric pressure, for alternating current of rated voltages above 52 kV, for indoor and outdoor installation, and for service frequencies up to and including 60 Hz.

For the purpose of this standard, the terms “GIS” and “switchgear” are used for “gas-insulated metal-enclosed switchgear”.

The gas-insulated metal-enclosed switchgear covered by this standard consists of individual components intended to be directly connected together and able to operate only in this manner.

This standard completes and amends, if necessary, the various relevant standards applying to the individual components constituting GIS.

1.2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60044-1:1996, *Instrument transformers – Part 1: Current transformers*

IEC 60044-2:1997, *Instrument transformers – Part 2: Inductive voltage transformers*

IEC 60068-2-11, *Basic environmental testing procedures – Part 2-11: Tests – Test Ka: Salt mist*

IEC 60137:2008, *Insulating bushings for alternating voltages above 1 000 V*

IEC 60141-1, *Tests on oil-filled and gas-pressure cables and their accessories – Part 1: Oil-filled, paper-insulated, metal-sheathed cables and accessories for alternating voltages up to and including 400 kV*

IEC 60270, *High-voltage test techniques – Partial discharge measurements*

IEC 60376, *Specification of technical grade sulfur hexafluoride (SF₆) for use in electrical equipment*

IEC 60480, *Guidelines for the checking and treatment of sulfur hexafluoride (SF₆) taken from electrical equipment and specification for its re-use*

IEC 60840, *Power cables with extruded insulation and their accessories for rated voltages above 30 kV ($U_m = 36$ kV) up to 150 kV ($U_m = 170$ kV) – Test methods and requirements*

IEC/TR 61639:1996, *Direct connection between power transformers and gas-insulated metal-enclosed switchgear for rated voltages of 72,5 kV and above*

IEC 62067, *Power cables with extruded insulation and their accessories for rated voltages above 150 kV ($U_m = 170$ kV) up to 500 kV ($U_m = 550$ kV) – Test methods and requirements*

IEC 62271-1:2007, *High-voltage switchgear and controlgear – Part 1: Common specifications*

IEC 62271-100:2008, *High-voltage switchgear and controlgear – Part 100: Alternating-current circuit-breakers*

IEC 62271-102:2001, *High-voltage switchgear and controlgear – Part 102: Alternating current disconnectors and earthing switches*

IEC 62271-209:2007, *High-voltage switchgear and controlgear – Part 209: Cable connections for gas-insulated metal-enclosed switchgear for rated voltages above 52 kV – Fluid-filled and extruded insulation cables – Fluid-filled and dry-type cable-terminations*

IEC/TR 62271-303, *High-voltage switchgear and controlgear – Part 303: Use and handling of sulphur hexafluoride (SF_6)*

ISO 3231, *Paints and varnishes – Determination of resistance to humid atmospheres containing sulfur dioxide*

2 Normal and special service conditions

Clause 2 of IEC 62271-1 is applicable with the following additions:

At any altitude the dielectric characteristics of the internal insulation are identical with those measured at sea-level. For this internal insulation, therefore, no specific requirements concerning the altitude are applicable.

Some items of a GIS such as pressure relief devices and pressure and density monitoring devices may be affected by altitude. The manufacturer shall take appropriate measures if necessary.

2.1 Normal service conditions

Subclause 2.1 of IEC 62271-1 is applicable, taking into account Table 1 of this standard.

2.2 Special service conditions

Subclause 2.2 of IEC 62271-1 is applicable, taking into account Table 1 of this standard.

In the cases where higher than (>) is used in the table the values shall be specified by the user as described in IEC 62271-1.