

Edition 1.0 2009-06

INTERNATIONAL STANDARD NORME

GROUP SAFETY PUBLICATION

PUBLICATION GROUPÉE DE SÉCURITÉ

Safety of transformers, reactors power supply units and similar products for supply voltages up to 1 100 V –

Part 2-16: Particular requirements and tests for switch mode power supply units and transformers for switch mode power supply units

Sécurité des transformateurs, bobines d'inductance, blocs d'alimentation et produits analogues pour des tensions d'alimentation jusqu'à 1 100 V – Partie 2-16: Règles particulières et essais pour les blocs d'alimentation à découpage et les transformateurs pour blocs d'alimentation à découpage





THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2009 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IFC Central Office 3, rue de Varembé CH-1211 Geneva 20 Switzerland Email: inmail@iec.ch Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

■ Catalogue of IEC publications: www.iec.ch/searchpub
The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

IEC Just Published: www.iec.ch/online news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

Electropedia: www.electropedia.org

■ Electropedia: www.electropedia.org
The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch Tel.: +41 22 919 02 11 Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

■ Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

■ Electropedia: <u>www.electropedia.org</u>

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch Tél.: +41 22 919 02 11 Fax: +41 22 919 03 00



Edition 1.0 2009-06

INTERNATIONAL STANDARD NORME INTERNATIONALE

GROUP SAFETY PUBLICATION

PUBLICATION GROUPÉE DE SÉCURITÉ

Safety of transformers, reactors power supply units and similar products for supply voltages up to 1 100 V –

Part 2-16: Particular requirements and tests for switch mode power supply units and transformers for switch mode power supply units

Sécurité des transformateurs, bobines d'inductance, blocs d'alimentation et produits analogues pour des tensions d'alimentation jusqu'à 1 100 V – Partie 2-16: Règles particulières et essais pour les blocs d'alimentation à découpage et les transformateurs pour blocs d'alimentation à découpage

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION ELECTROTECHNIQUE INTERNATIONALE

PRICE CODE

ISBN 2-8318-1047-2

CONTENTS

FOI	REWORD	4
1	Scope	6
2	Normative references	8
3	Terms and definitions	9
4	General requirements	9
5	General notes on tests	9
6	Ratings	9
7	Classification	10
8	Marking and other information	10
9	Protection against electric shock	11
10	Change of input voltage setting	12
11	Output voltage and output current under load	12
12	No-load output voltage	12
13	Short circuit voltage	13
14	Heating	13
15	Short-circuit and overload protection	13
16	Mechanical strength	14
17	Protection against harmful ingress of dust, solid objects and moisture	14
18	Insulation resistance, dielectric strength and leakage current	
19	Construction	14
20		
21	Internal wiring	18
22	Supply connection and other external flexible cables or cords	19
23	Terminals for external conductors	19
24	Provisions for protective earthing	19
25	Screws and connections	19
26	Creepage distances, clearances and distances through insulation	19
27	Resistance to heat, fire and tracking	32
28	Resistance to rusting	32
Anr	nexes	33
Anr	nex AA (informative) Partial discharge (PD) test	33
	nex BB (normative) Particular requirements for associated transformers for use in tch mode power supplies with internal frequencies > 500 Hz	33
SWII	teri mode power supplies with internal frequencies > 300 Hz	
Figi	ure 101 – Diagram for dimensioning of clearances	20
Figi	ure 102 – Diagram of dimensioning creepage distances	24
	ure 103 – Permissible field strength for dimensioning of solid insulation according to	C
⊨qι	uation (1)	32
Tab	ole 101 – Output voltages ratio	13
	ole 102 – Values of clearances for frequencies > 30 kHz with approximately	
	nogeneous field condition according to 4.3 of IEC 60664-4	21

Table 103 – Values of clearances for transient overvoltages or recurring peak voltages produced in the primary circuit of the SMPS for frequencies ≤ 30 kHz	22
Table 104 – Minimum values of clearances in air for inhomogeneous field conditions for frequency > 30 kHz	22
Table 105 – Basic or supplementary insulation – Minimum values of creepage distances for different frequency ranges (pollution degree 1)	25
Table 106 – Basic or supplementary insulation – Minimum values of creepage distances for different frequency ranges (pollution degree 2)	26
Table 107 – Basic or supplementary insulation – Minimum values of creepage distances for different frequency ranges (pollution degree 3)	27
Table 108 – Double or reinforced insulation – Minimum values of creepage distances for different frequency ranges (pollution degree 1)	28
Table 109 – Double or reinforced insulation – Minimum values of creepage distances for different frequency ranges (pollution degree 2)	29
Table 110 – Double or reinforced insulation – Minimum values of creepage distances for different frequency ranges (pollution degree 3)	30

rece pollutic forced inst. s (pollution de, s) and a solution of the solution

INTERNATIONAL ELECTROTECHNICAL COMMISSION

SAFETY OF TRANSFORMERS, REACTORS, POWER SUPPLY UNITS AND SIMILAR PRODUCTS FOR SUPPLY VOLTAGES UP TO 1 100 V –

Part 2-16: Particular requirements and tests for switch mode power supply units and transformers for switch mode power supply units

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also Participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61558-2-16 has been prepared by IEC technical committee 96: Transformers, reactors, power supply units and similar products for low voltage up to 1 100 V.

This first edition of IEC 61558-2-16 cancels and replaces IEC 61558-2-17, published in 1997. It constitutes a technical revision.

This part has the status of a group safety publication in accordance with IEC Guide 104 (1997): The preparation of safety publications and the use of basic safety publications and group safety publications.

The text of this standard is based on the following documents:

FDIS	Report on voting
96/330/CDV	96/333/RVC

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

This Part 2-16 is intended to be used in conjunction with the latest edition of IEC 61558-1 and its amendments. It is based on the second edition (2005) of that standard.

This part supplements or modifies the corresponding clauses in IEC 61558-1, so as to convert that publication into the IEC standard: *Particular requirements and tests for switch mode power supply units and transformers for switch mode power supply units.*

A list of all parts of the IEC 61558 series can be found on the IEC website under the title: Safety of transformers, reactors, power supply units and similar products for supply voltages up to 1 100 V.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the next edition.

Where a particular subclause of Part 1 is not mentioned in this part, that subclause applies as far as is reasonable. Where this part states "addition", "modification" or "replacement", the relevant text of Part 1 is to be adapted accordingly.

In this part, the following print types are used:

- requirements proper: in roman type;
- test specifications: in italic type;
- explanatory matter: in smaller roman type.

In the text of this part, the words in **bold** are defined in Clause 3

Subclauses, notes, figures and tables additional to those in Part 1 are numbered starting from 101; supplementary annexes are entitled AA, BB, etc.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- · replaced by a revised edition, or
- amended.

NOTE The attention of National Committees is drawn to the fact that equipment manufacturers and testing organizations may need a transitional period following publication of a new, amended or revised IEC publication in which to make products in accordance with the new requirements and to equip themselves for conducting new or revised tests.

It is the recommendation of the committee that the content of this publication be adopted for implementation nationally not earlier than 12 months from the date of publication.

SAFETY OF TRANSFORMERS, REACTORS, POWER SUPPLY UNITS AND SIMILAR PRODUCTS FOR SUPPLY VOLTAGES UP TO 1 100 V -

Part 2-16: Particular requirements and tests for switch mode power supply units and transformers for switch mode power supply units

1 Scope

Replacement:

This part of IEC 61558 deals with the safety of switch mode power supply units and transformers for switch mode power supply units. Transformers incorporating electronic circuits are also covered by this standard.

NOTE 1 Safety includes electrical, thermal and mechanical aspects.

This part applies to:

- a) switch mode power supply units incorporating safety isolating transformers providing SELV, PELV or FELV a.c. or d.c. output voltage(s), or a combination thereof according to IEC 61140 and IEC 60364-4-41 for use with household and other consumer products, except for products covered by IEC 60065, IEC 61347 series, IEC 61204-7 and IEC 60950-1.
- b) switch mode power supply units with a maximum output voltage not exceeding 1 000 V a.c. or 1 414 V ripple-free d.c. for use with household and other consumer products, except for products covered in a) and products covered by IEC 60065, IEC 61347 series, IEC 61204-7 and IEC 60950-1;
- c) this standard may be used for **transformers** for use in **switch mode power supply units** (see Annex BB).

This part covers the safety requirements for:

- separating SMPS for general use corresponding to Part 2
- isolating SMPS for general use corresponding to Part 2-4;
- safety isolating SMPS for general use corresponding to Part 2-6;
- auto-SMPS for general use corresponding to Part 2-13.

For SMPS for specific application corresponding to the other Parts 2 of 61558 series, the necessary requirements of the relevant Parts 2 are applicable. In addition, the requirements listed in this part apply. Where the two requirements are in conflict, the most severe take precedence.

NOTE 2 As the maximum rated supply voltage of the internal transformer is 1 000 V, the maximum rated supply voltage of the switch mode power supply may be lower due to type of rectification.

Switch mode power supply units covered by this standard are air cooled (natural or forced) **independent**, **associated**, **stationary**, **portable**, single-phase, or polyphase, with the **rated supply voltage** not exceeding 1 100 V a.c., the **rated supply frequency** not exceeding 500 Hz, the **rated internal operating frequency** exceeding 500 Hz, but not exceeding 100 MHz, and the **rated output** not exceeding 1 kVA or 1 kW, incorporating **dry-type transformers** with encapsulated or non-encapsulated windings.

Associated transformers for **switch mode power supply units** covered by Annex BB of this standard shall have a **rated output** not exceeding:

- 25 kVA for single-phase transformers;
- 40 kVA for polyphase transformers.

NOTE 3 For higher frequencies, additional requirements may be necessary. However, this standard may be used as a guide.

The no-load output voltage or the rated output voltage of switch mode power supply units shall not exceed:

- 1 000 V a.c. or 1 415 V ripple-free d.c. when separating transformers or autotransformers are used;
- 500 V a.c. or 708 V ripple-free d.c. when isolating transformers are used;
- 50 V a.c. or 120 V ripple-free d.c. when safety isolating transformers are used.

The no-load output voltage or the rated output voltage of independent switch mode power supply units shall not be less than:

 50 V a.c. or 120 V ripple-free d.c. when separating transformers or autotransformers are used.

This standard is also applicable to **switch mode power supply units**, converters and inverters without limitation of the **rated output**. However, such **switch mode power supply units** are for special applications and are subject to an agreement between the purchaser and the manufacturer.

NOTE 4 In the context of this standard, converters and invertors are considered to be switch mode power supply units.

This standard may also be used as a guide for products not covered by the scope of this standard, the scope of IEC 61204-7, or the scope of IEC 61347 series.

This standard does not apply to:

- motor-generator sets;
- uninterruptible power supplies (UPS) according to IEC 62040
- switch mode power supply units covered by IEC 61204-7 (i.e. low-voltage power supply devices, d.c. output, performance characteristics) and d.c. power and distribution equipment and switch mode power supply units for use in applications covered by IEC 60950-1, IEC 61010-1, IEC 60601-1, and IEC 60065;
- lamp control gear covered by IEC 61347-1;
- external circuits and their components intended to be connected to the input terminals and output terminals of the transformers.

NOTE 5 IEC 61204-7 will be updated by SC 22E.

NOTE 6 Attention is drawn to the following:

- for transformers intended to be used in vehicles, on board ships and aircraft, additional requirements (from other applicable standards, national rules, etc.) may be necessary;
- measures to protect the enclosure and the components inside the enclosure against external influences such
 as fungus, vermin, termites, solar-radiation, and icing should also be considered;
- the different conditions for transportation, storage, and operation of the transformers should also be considered;
- additional requirements in accordance with other appropriate standards and national rules may be applicable to transformers intended for use in special environments, such as tropical environment.

NOTE 7 Future technological development of **transformers** may necessitate a need to increase the upper limit of the frequencies; until then, this part may be used as a guidance document.

Unless otherwise specified, from here onward, the term **SMPS** covers **switch mode power supply units**.

2 Normative references

This clause of Part 1 is applicable, except as follows:

Addition:

IEC 60227 (all patts), Polyvinyl chloride insulated cables of rated voltages up to and including 450/750 V

IEC 60364-4-41, Low-voltage electrical installations – Part 4-41: Protection for safety – Protection against electric shock

IEC 60950-1, Information technology equipment – Safety – Part 1:General requirements

IEC 60601-1, Medical electrical equipment – Part 1:General requirements for basic safety and essential performance

IEC 60664-4:2005, Insulation coordination for equipment within low-voltage systems – Part 4: Consideration of high-frequency voltage stress

IEC 61010-1, Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 1:General requirements

IEC 61204-7:2006, Low voltage power supplies, d.c. output – Part 7:Safety requirements

IEC 61347 (all parts), Lamp controlgear

IEC 61558-1:2005, Safety of power transformers, power supplies, reactors and similar products – Part 1: General requirements and tests

IEC 61558-2-1, Safety of power transformers, power supplies, reactors and similar products – Part 2-1: Particular requirements and tests for separating transformers and power supplies incorporating separating transformers for general applications

IEC 61558-2-4, Safety of transformers, reactors, power supply units and similar products for supply voltages up to 1 100 V - Part 2-4: Particular requirements and tests for isolating transformers and power supply units incorporating isolating transformers

IEC 61558-2-6, Safety of transformers, reactors, power supply units and similar products for supply voltages up to 1 100 V – Part 2-6: Particular requirements and tests for safety isolating transformers and power supply units incorporating safety isolating transformers

IEC 61558-2-13, Safety of transformers, reactors, power supply units and similar products for supply voltages up to 1 100 V - Part 2-13: Particular requirements and tests for auto transformers and power supply units incorporating auto transformers

IEC 62040 (all parts), Uninterruptible power systems (UPS)