

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Nuclear power plants – Control rooms – Supplementary control points for reactor shutdown without access to the main control room

Centrales nucléaires de puissance – Salles de commande – Points de commande supplémentaires pour l'arrêt des réacteurs sans accès à la salle de commande principale (salle de commande de repli)



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2009 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Nuclear power plants – Control rooms – Supplementary control points for reactor shutdown without access to the main control room

Centrales nucléaires de puissance – Salles de commande – Points de commande supplémentaires pour l'arrêt des réacteurs sans accès à la salle de commande principale (salle de commande de repli)

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

Q

CONTENTS

FOREWORD.....	3
INTRODUCTION.....	5
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	8
4 Abbreviations	9
5 Design principles.....	9
5.1 General.....	9
5.2 Main objectives	9
5.3 Safety principles.....	10
5.4 Human factors engineering principles.....	12
6 Design process.....	12
7 Functional design	13
7.1 General.....	13
7.2 Human factors	13
7.3 Location and access route.....	13
7.4 SCP environment	14
7.5 Space and configuration.....	14
7.6 Information and control equipment	14
7.7 Communication systems.....	15
7.8 Other equipment.....	15
8 System verification and validation.....	15
Bibliography.....	16

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**NUCLEAR POWER PLANTS –
CONTROL ROOMS –
SUPPLEMENTARY CONTROL POINTS FOR REACTOR SHUTDOWN
WITHOUT ACCESS TO THE MAIN CONTROL ROOM**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60965 has been prepared by subcommittee 45A: Instrumentation and control of nuclear facilities, of IEC technical committee 45: Nuclear instrumentation.

The text of this standard is based on the following documents:

FDIS	Report on voting
45A/749/FDIS	45A/769/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This second edition cancels and replaces the first edition published in 1989. This edition constitutes a technical revision.

The main technical changes with regard to the previous edition are as follows:

- to clarify the definitions and review the requirements.
- to update the reference to new standards published since the first issue, including IEC 61227, IEC 61771, IEC 61772, IEC 61839, and IEC 62241.
- to align the Standard with the new revisions of IAEA documents NS-R-1 and NS-G-1.3.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INTRODUCTION

a) Technical background, main issues and organization of the standard

IEC 60965:1989 was developed to provide requirements relevant to the design of NPP supplementary control points for reactor shutdown without access to the main control room. The first edition of IEC 60965 has been used extensively within the nuclear industry. It was however recognized that recent technical developments especially those which are based on software technology should be incorporated. It was also recognized that the relationships with the standard for the main control room (i.e. IEC 60964) and the derivative standards to that standard (i.e. IEC 61227, IEC 61771, IEC 61772, IEC 61839, and IEC 62241) should be clarified and conditioned.

This IEC standard specifically focuses on the functional design process of the supplementary control points of an NPP. It is intended that the standard is used by NPP designers, design authorities, vendors, utilities, and by licensors.

At the end of the current revision, at the FDIS stage, two further points were identified. These are: (a) requirements should be included associated with regular testing of the SCP, and (b) a theoretical assessment is needed of the time available during which the reactor will be safe but unattended, in order to move from the MCR to the SCP and for the SCP to become operational. However, since these points were not raised formally by any National Committee, they are recorded in this introduction for development in the next revision.

b) Situation of the current standard in the structure of the IEC SC 45A standard series

IEC 60965 is the third level IEC SC 45A document tackling the issue of the design of supplementary control points.

IEC 60965 is to be read in association with IEC 60964 for the design of the main control room (including the derivative standards mentioned above) which is the appropriate IEC SC 45A document providing guidance on operator controls, verification and validation of design, application of visual display units, functional analysis and assignment, and alarm functions and presentation.

For more details on the structure of the IEC SC 45A standard series, see item d) of this introduction.

c) Recommendations and limitations regarding the application of this Standard

The purpose of this standard is to provide functional design requirements to be used in the design of the supplementary control points of a nuclear power plant to meet safety requirements.

This standard is intended for application to supplementary control points whose conceptual design is initiated after the publication of this standard. The recommendations of the standard may be used for refits, upgrades and modifications.

Aspects for which special recommendations have been provided in this Standard, in accordance with Clauses 6.15 to 6.30 of IAEA NS-G-1.3, are:

- The definition of the MCR and plant design bases for which the supplementary control points are to be used.
- Access by station staff to the supplementary control points in such emergencies.
- Assurance for the station staff that the environment at the supplementary control points is safe when they are to be used.

- Provision of information at the supplementary control points on the state of the reactor critical functions.
- Transfer of control and indication functions from the main control room to the supplementary control points in emergencies.
- Independence and separation of the cabling used by the supplementary control points from that used by the main control room.
- Assurance that a safe shutdown state has been reached using the supplementary control points.
- Communication facilities between the supplementary control points and to the station management.

To ensure that the Standard will continue to be relevant in future years, the emphasis has been placed on issues of principle, rather than specific technologies.

d) Description of the structure of the IEC SC 45A standard series and relationships with other IEC documents and other bodies documents (IAEA, ISO)

The top-level document of the IEC SC 45A standard series is IEC 61513. It provides general requirements for I&C systems and equipment that are used to perform functions important to safety in NPPs. IEC 61513 structures the IEC SC 45A standard series.

IEC 61513 refers directly to other IEC SC 45A standards for general topics related to categorization of functions and classification of systems, qualification, separation of systems, defence against common cause failure, software aspects of computer-based systems, hardware aspects of computer-based systems, and control room design. The standards referenced directly at this second level should be considered together with IEC 61513 as a consistent document set.

At a third level, IEC SC 45A standards not directly referenced by IEC 61513 are standards related to specific equipment, technical methods, or specific activities. Usually these documents, which make reference to second-level documents for general topics, can be used on their own.

A fourth level extending the IEC SC 45A standard series, corresponds to the Technical Reports which are not normative.

IEC 61513 has adopted a presentation format similar to the basic safety publication IEC 61508 with an overall safety life-cycle framework and a system life-cycle framework and provides an interpretation of the general requirements of IEC 61508-1, IEC 61508-2 and IEC 61508-4, for the nuclear application sector. Compliance with IEC 61513 will facilitate consistency with the requirements of IEC 61508 as they have been interpreted for the nuclear industry. In this framework IEC 60880 and IEC 62138 correspond to IEC 61508-3 for the nuclear application sector.

IEC 61513 refers to ISO as well as to IAEA 50-C-QA (now replaced by IAEA GS-R-3) for topics related to quality assurance (QA).

The IEC SC 45A standards series consistently implements and details the principles and basic safety aspects provided in the IAEA code on the safety of NPPs and in the IAEA safety series, in particular the Requirements NS-R-1, establishing safety requirements related to the design of Nuclear Power Plants, and the Safety Guide NS-G-1.3 dealing with instrumentation and control systems important to safety in Nuclear Power Plants. The terminology and definitions used by SC 45A standards are consistent with those used by the IAEA.

NUCLEAR POWER PLANTS – CONTROL ROOMS – SUPPLEMENTARY CONTROL POINTS FOR REACTOR SHUTDOWN WITHOUT ACCESS TO THE MAIN CONTROL ROOM

1 Scope

This International Standard establishes requirements for the supplementary control points provided to enable the operating staff of nuclear power plants to shut down the reactor and maintain the plant in a safe shut-down state in the event that control of the safety functions can no longer be exercised from the main control room, due to unavailability of the main control room or its facilities.

The standard also establishes requirements for the selection of functions, the design and organisation of the human-machine interface, and the procedures which shall be used systematically to verify and validate the functional design of the supplementary control points.

It is assumed that supplementary control points provided for shutdown operations from outside the main control room would be unattended during normal plant conditions other than for periodic testing. The requirements reflect the application of human engineering principles as they apply to the human-machine interface during such periodic testing and during abnormal plant conditions.

This standard does not cover special emergency response facilities (e.g. a technical support centre) or facilities provided for radioactive waste handling. Detailed equipment design is also outside the scope of the standard.

This standard follows the principles of IAEA Requirements NS-R-1 “Safety of Nuclear Power Plants: Design” and IAEA Safety Guide NS-G-1.3 “Instrumentation and Control Systems Important to Safety in Nuclear Power Plants”.

The purpose of this standard is to provide functional design requirements to be used in the design of the supplementary control points of a nuclear power plant to meet safety requirements.

This standard is intended for application to supplementary control points whose conceptual design is initiated after the publication of this standard. If it is desired to apply it to existing plants or designs, special care must be taken to ensure a consistent design basis. This relates, for example, to factors such as the consistency between the supplementary control points and the main control room, the ergonomic approach, the automation level and the information technology.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60709, *Nuclear power plants – Instrumentation and control systems important to safety – Separation*

IEC 60964, *Nuclear power plants – Control rooms – Design*

IEC 61226, *Nuclear power plants – Instrumentation and control systems important for safety – Classification of instrumentation and control functions*

IEC 61513, *Nuclear power plants – Instrumentation and control for systems important to safety – General requirements for systems*

IEC 61771, *Nuclear power plants – Main control room – Verification and validation of design*

IAEA NS-R-1:2000, *Safety of nuclear power plants: Design*

IAEA NS-G-1.3:2002, *Instrumentation and Control Systems Important to Safety in Nuclear Power Plants*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply. For other terms, refer to the general terminology defined in IEC 60964, IEC 61513 and in the IAEA NUSS programme, such as Safety Guide NS-G-1.3 or the safety glossary.

3.1

control room staff

a group of plant personnel stationed in the control room, which is responsible for achieving the plant operational goals by controlling plant through the human-machine interface. Typically, the control room staff consists of supervisory operators, and operators who actually monitor plant and plant conditions and manipulate controls, but may also include those staff members and experts who are authorised to be present in the control room, e.g. during long lasting event sequences.

[IEC 60964, 3.4]

3.2

local control points (or facilities)

points (or facilities) located outside the control room where local operators perform control activities

[IEC 60964, 3.17]

3.3

local operators

the operating staff that perform tasks outside the control room

[IEC 60964, 3.18]

3.4

operating staff

plant personnel working on shift to operate the plant. The operating staff includes the control room staff, maintenance engineers, etc.

[IEC 60964, 3.20]

3.5

supplementary control point

a location from which limited plant control and/or monitoring can be carried out to accomplish the safety functions identified by the safety analysis as required in the event of a loss of ability to perform those functions from the main control room. The supplementary control point may be a special control room, but in many cases comprises a set of control panels and displays in switchgear rooms or similar areas.