

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Measuring relays and protection equipment –
Part 1: Common requirements**

**Relais de mesure et dispositifs de protection –
Partie 1: Exigences communes**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2009 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch
Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch
Tél.: +41 22 919 02 11
Fax: +41 22 919 03 00



IEC 60255-1

Edition 1.0 2009-08

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Measuring relays and protection equipment –
Part 1: Common requirements**

**Relais de mesure et dispositifs de protection –
Partie 1: Exigences communes**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

ICS 29.120.70

ISBN 2-8318-1057-3

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	9
2 Normative references.....	9
3 Terms and definitions.....	11
4 Environmental conditions.....	13
4.1 General.....	13
4.2 Normal environmental conditions.....	13
4.3 Special environmental conditions.....	14
4.4 Storage conditions.....	15
5 Ratings.....	15
5.1 General.....	15
5.2 Rated voltage.....	15
5.2.1 Input energizing voltage.....	15
5.2.2 Auxiliary energizing voltage.....	16
5.2.3 Rated insulation voltage.....	16
5.3 Rated current.....	16
5.3.1 Input energizing current.....	16
5.3.2 Auxiliary energizing current.....	17
5.4 Binary input and output.....	17
5.4.1 Binary input.....	17
5.4.2 Binary output.....	17
5.5 Transducer analogue input and output.....	17
5.5.1 Transducer analogue input.....	17
5.5.2 Transducer analogue output.....	17
5.6 Frequency.....	17
5.6.1 Rated frequency.....	17
5.6.2 Frequency operating range.....	17
5.7 Rated burden.....	17
5.8 Rated ambient temperature.....	17
6 Design and construction.....	18
6.1 Marking.....	18
6.2 Dimensions.....	18
6.3 Enclosure protection.....	18
6.4 Product safety requirements.....	18
6.5 Functional performance requirements.....	18
6.5.1 General.....	18
6.5.2 Intrinsic accuracy.....	18
6.5.3 Operating accuracy.....	19
6.5.4 Performance under dynamic system conditions.....	19
6.5.5 Performance under transient signal conditions.....	19
6.5.6 Multifunctional protection relay.....	19
6.5.7 Programmable logic.....	20
6.6 Communication protocols.....	20
6.7 Binary input and output.....	20

6.7.1	Binary input	20
6.7.2	Binary output	20
6.8	Transducer analogue input and output	20
6.8.1	Transducer analogue input	20
6.8.2	Transducer analogue output	20
6.9	Input circuit for energizing quantities	20
6.9.1	Characteristic energizing quantity	20
6.9.2	Auxiliary energizing quantity	21
6.10	Burden tests	21
6.10.1	Burden for voltage transformers	21
6.10.2	Burden for current transformers	21
6.10.3	Burden for AC power supply	21
6.10.4	Burden for DC power supply	21
6.10.5	Burden for binary input	22
6.11	Contact performance	22
6.12	Climatic performance	23
6.12.1	General	23
6.12.2	Verification procedure	23
6.12.3	Climatic environmental tests	25
6.13	Mechanical requirements	31
6.13.1	Vibration response and endurance (sinusoidal)	31
6.13.2	Shock response, shock withstand and bump	31
6.13.3	Seismic	32
6.14	Pollution	32
6.15	Electromagnetic compatibility (EMC)	32
7	Tests	32
7.1	General	32
7.2	Test reference conditions	32
7.3	Test overview	33
7.4	Type test report content	34
8	Marking, labelling and packaging	35
9	Rules for transport, storage, installation, operation and maintenance	35
10	Product documentation	35
	Annex A (informative) Type testing guidelines	37
	Annex B (informative) Intrinsic, operating and overall system accuracy	40
	Annex C (informative) Guidance on dependability	42
	Bibliography	45
	Figure 1 – Contact performance parameters	23
	Figure A.1 – Definition of operate, transitional and quiescent states	38
	Figure B.1 – Different kind of accuracies	40
	Figure C.1 – Overview of fields that may be of interest for protection relays	42
	Figure C.2 – Failure detection chart	43
	Table 1 – Normal environmental conditions	14

Table 2 – Special environmental conditions	15
Table 3 – Dry heat test – operational	25
Table 4 – Cold test – Operational.....	26
Table 5 – Dry heat test, storage temperature	27
Table 6 – Cold test, storage temperature	28
Table 7 – Cyclic temperature test.....	29
Table 8 – Damp heat steady state test.....	30
Table 9 – Cyclic temperature with humidity test	31
Table 10 – Test reference conditions	32
Table 11 – Test overview	34
Table A.1 – Example of protection functions that may be used during tests	38
Table A.2 – Example of EMC test conditions for measuring inputs	39
Table C.1 – Definitions of symbols.....	43
Table C.2 – Meaning of terms defined in IEC 60050-191 for protection relays.....	43

This document is a preview generated by EVS

INTERNATIONAL ELECTROTECHNICAL COMMISSION

MEASURING RELAYS AND PROTECTION EQUIPMENT –**Part 1: Common requirements**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60255-1 has been prepared by IEC technical committee 95: Measuring relays and protection equipment.

This standard cancels and replaces the second edition of IEC 60255-6, published in 1988, and constitutes a technical revision.

The text of this standard is based on the following documents:

FDIS	Report on voting
95/252FDIS	95/257/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all the parts in the IEC 60255 series, under the general title *Measuring relays and protection equipment*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

This document is a preview generated by EVS

INTRODUCTION

NUMBERING OF STANDARDS FALLING UNDER THE RESPONSIBILITY OF TC 95

In accordance with the decision taken at the technical committee 95 meeting in Paris on 2006-04-06 (item 12 of 95/191/RM) a new numbering system will be established of the standards falling under the responsibility of TC 95. Numbering of the standards will follow the following principle:

- common standards will start with IEC 60255 –;
- protection functional standards will start with IEC 60255-100 series;
- technical reports will start with IEC 60255-200 series.

The IEC 60255 series will consist of the following parts, under the general title *Measuring relays and protection equipment*. Five parts (Parts 3, 8, 12, 13 and 16) will be renumbered and Part 6 will be replaced by Part 1.

a) Common standards:

Part 1: Common requirements

Part 11: Interruptions to and alternating component (ripple) in d.c. auxiliary energizing quantity of measuring relays

Part 21: Vibration, shock, bump and seismic tests

Part 22: Electrical disturbance tests

Part 24: Common format for transient data exchange (COMTRADE) for power systems

Part 25: Electromagnetic emission tests

Part 26: Electromagnetic compatibility requirements

Part 27: Product safety requirements

b) Protection functional standards:

121 Functional requirements for distance protection (revision of IEC 60255-16)

124 Functional requirements for volts per hertz protection

125 Functional requirements for synchronizing or synchronism-check

127 Functional requirements for over/under voltage protection (revision of IEC 60255-3) (including the phase, neutral, residual and negative sequence)

132 Functional requirements for over/under power protection (revision of IEC 60255-12) (including the real reactive and power factor)

140 Functional requirements for loss of excitation protection

149 Functional requirements for thermal protection (revision of IEC 60255-8)

151 Functional requirements for over/under current protection (revision of IEC 60255-3) (including the phase, ground, residual and negative sequence)

160 Functional requirements for voltage or current unbalance protection

167 Functional requirements for directional current protection

178 Functional requirements for power swing/out-of-step protection

179 Functional requirements for reclosing

181 Functional requirements for frequency relay (including over/under, rate of change)

- 185 Functional requirements for teleprotection function
- 187 Functional requirements for differential protection (revision of IEC 60255-13)
(including generator, transformer, busbar, line and restricted earth fault)
- 195 Functional requirements for synchrophasor measurement

NOTE 1 The functional standard for synchrophasor measurement may be developed from IEEE Std C37.118:1995 [1]¹.

NOTE 2 The last two digits of the part of the proposed functional standard new numbering correspond to device function numbers as established in IEEE Std C37.2:1996[2].

c) Technical reports:

- Part 200: Application guide for generator protection
- Part 201: Application guide for motor protection
- Part 202: Application guide for transformer protection
- Part 203: Application guide for reactor protection
- Part 204: Application guide for bus protection
- Part 205: Application guide for line protection
- Part 206: Application guide for breaker failure protection

¹ Figures in square brackets refer to the bibliography.

MEASURING RELAYS AND PROTECTION EQUIPMENT –

Part 1: Common requirements

1 Scope

This part of IEC 60255 specifies common rules and requirements applicable to measuring relays and protection equipment including any combination of devices to form schemes for power system protection such as control, monitoring and process interface equipment in order to obtain uniformity of requirements and tests.

All measuring relays and protection equipment used for protection within the power system environment are covered by this standard. Other standards in this series may define their own requirements which in such cases shall take precedence.

For special applications (marine, aerospace, explosive atmospheres, computers, etc.), the general requirements within this standard may need to be enhanced by additional special requirements.

The requirements are applicable only to relays in new condition. All tests in this standard are type tests, unless otherwise declared.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60044-1:1996, *Instrument transformers – Part 1: Current transformers*

IEC 60044-2:1997, *Instrument transformers – Part 2: Inductive voltage transformers*

IEC 60044-5:2004, *Instrument transformers – Part 5: Capacitor voltage transformers*

IEC 60044-7:1999, *Instrument transformers – Part 7: Electronic voltage transformers*

IEC 60044-8:2002, *Instrument transformers – Part 8: Electronic current transformers*

IEC 60050-191:1990, *International Electrotechnical Vocabulary – Chapter 191: Dependability and quality of service*

IEC 60050-447:2009, *International Electrotechnical Vocabulary – Part 447: Measuring relays*

IEC 60068-2-1:2007, *Environmental testing – Part 2-1: Tests – Test A: Cold*

IEC 60068-2-2:2007, *Environmental testing – Part 2-2: Tests – Test B: Dry heat*

IEC 60068-2-14:2009, *Environmental testing – Part 2-14: Tests – Test N: Change of temperature*

IEC 60068-2-30:2005, *Environmental testing – Part 2-30: Tests – Test Db: Damp heat, cyclic (12 h + 12 h cycle)*

IEC 60068-2-78:2001, *Environmental testing – Part 2-78: Tests – Test Cab: Damp heat, steady state*

IEC 60068-3-4:2001, *Environmental testing – Part 3-4: Supporting documentation and guidance – Damp heat tests*

IEC 60255-11:2008, *Measuring relays and protection equipment – Part 11: Voltage dips, short interruptions, variations and ripple on auxiliary power supply port*

IEC 60255-21-1:1988, *Electrical relays – Part 21-1: Vibration, shock, bump and seismic tests on measuring relays and protection equipment – Vibration tests (sinusoidal)*

IEC 60255-21-2:1988, *Electrical relays – Part 21-2: Vibration, shock, bump and seismic tests on measuring relays and protection equipment – Shock and bump tests*

IEC 60255-21-3:1993, *Electrical relays – Part 21-3: Vibration, shock, bump and seismic tests on measuring relays and protection equipment – Seismic tests*

IEC 60255-22-2:2008, *Measuring relays and protection equipment – Part 22-2: Electrical disturbance tests – Electrostatic discharge tests*

IEC 60255-22-4:2008, *Measuring relays and protection equipment – Part 22-4: Electrical disturbance tests – Electrical fast transient/burst immunity test*

IEC 60255-22-5:2008, *Measuring relays and protection equipment – Part 22-5: Electrical disturbance tests – Surge immunity test*

IEC 60255-22-7:2003, *Electrical relays – Part 22-7: Electrical disturbance tests for measuring relays and protection equipment – Power frequency immunity tests*

IEC 60255-25:2000, *Electrical relays – Part 25: Electromagnetic emission tests for measuring relays and protection equipment*

IEC 60255-26:2008, *Measuring relays and protection equipment – Part 26: Electromagnetic compatibility requirements*

IEC 60255-27:2005, *Measuring relays and protection equipment – Part 27: Product safety equipment*

IEC 60255-100 (all parts), *Measuring relays and protection equipment – Parts 1XX: Protection functional standards*

IEC 60297-3-101:2004, *Mechanical structures for electronic equipment – Dimensions of mechanical structures of the 482,6 mm (19 in) series – Part 3-101: Subracks and associated plug-in units*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*

IEC 60688, *Electrical measuring transducers for converting a.c. electrical quantities to analogue or digital signals*

IEC 60721-3-3, *Classification of environmental conditions – Part 3-3: Classification of groups of environmental parameters and their severities – Stationary use at weather-protected locations*

IEC/TR 61000-2-5:1995, *Electromagnetic compatibility (EMC) – Part 2: Environment – Section 5: Classification of electromagnetic environments – Basic EMC publication*

IEC 61810-1, *Electromechanical elementary relays – Part 1: General requirements*

IEC 61810-2, *Electromechanical elementary relays – Part 2: Reliability*

IEC 61850 (all parts), *Communication networks and systems in substations*

IEC 61850-9-2, *Communication networks and systems in substations – Part 9-2: Specific Communication Service Mapping (SCSM) – Sampled values over ISO/IEC 8802-3*

3 Terms and definitions

For the purposes of this document, the terms and definitions of IEC 60050-447, as well as the following, apply.

3.1

absolute error

difference between a measured operate value of the characteristic quantity or a measured value of a specific time and its declared value (e.g. setting value).

3.2

alternating component

in d.c. expressed as a percentage of the difference between the maximum value U_{\max} and the minimum value U_{\min} of a pulsating d.c. voltage to the mean value U_0 of this voltage

$$\frac{U_{\max} - U_{\min}}{U_0} \times 100\%$$

3.3

analogue inputs and outputs

current or voltage inputs/outputs whose values are directly proportional to physical measured quantities i.e. transducer input

3.4

assigned error

error limits within which the manufacturer declares that any device of a given type will perform under the reference conditions

3.5

binary inputs/outputs

inputs/outputs which have either an on or off state and can be either physical connections or supplied via a communication port

3.6

dynamic performance

characteristics defining the ability of the relay to achieve the intended functions under fault conditions (for example single phase to earth fault) and/or abnormal system conditions which occur at the power system frequency (for example: power swings, harmonics, etc.)