

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Electric and magnetic field levels generated by AC power systems –
Measurement procedures with regard to public exposure**

**Champs électriques et magnétiques générés par les systèmes d'alimentation à
courant alternatif – Procédures de mesure des niveaux d'exposition du public**





THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2009 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembé
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00



IEC 62110

Edition 1.0 2009-08

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Electric and magnetic field levels generated by AC power systems –
Measurement procedures with regard to public exposure**

**Champs électriques et magnétiques générés par les systèmes d'alimentation à
courant alternatif – Procédures de mesure des niveaux d'exposition du public**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX XA

ICS 17.220.20; 29.240

ISBN 2-8318-1059-3

CONTENTS

FOREWORD	5
INTRODUCTION	7
1 Scope	8
2 Normative reference	8
3 Terms and definitions	8
4 Measurement principle for electric and magnetic fields	9
4.1 General	9
4.2 Instruments	9
4.3 Harmonic content	10
4.4 Record of measurement result	10
4.5 Measurement considerations	11
4.5.1 Field orientation	11
4.5.2 Measurement locations	12
4.5.3 Perturbing effects of an operator in electric field measurement	12
4.5.4 Effects from other sources in magnetic field measurement	12
4.5.5 Humidity condition in electric field measurement	12
5 Fundamental measurement procedures for electric and magnetic fields	12
5.1 General procedure	12
5.2 Single-point measurement	13
5.3 Three-point measurement	13
5.4 Five-point measurement	14
6 Measurement procedures for finding the maximum exposure level to an electric field	15
6.1 Overhead lines	15
6.2 Underground cables	15
6.3 Substations and power system equipment	15
7 Measurement procedures for finding the maximum exposure level to a magnetic field	16
7.1 Overhead lines	16
7.2 Underground cables	16
7.3 Substations and power system equipment	16
Annex A (informative) Characteristics of electric fields generated by AC overhead lines	18
Annex B (informative) Characteristics of magnetic fields generated by AC power systems	30
Annex C (informative) Concept of the <i>three-point measurement</i> with regard to the <i>average exposure level</i>	42
Annex D (informative) Example of a reporting form for field measurement	47
Bibliography	50
Figure 1 – Heights of the <i>three-point measurement</i>	13
Figure 2 – Five-point measurement	14
Figure A.1 – Linear charge distribution above ground	19
Figure A.2 – General <i>n</i> -phase system with ground	20
Figure A.3 – Electric field levels under an overhead transmission line	22

Figure A.4 – Electric field levels under an overhead transmission line with bundled conductors	22
Figure A.5 – Electric field levels and non-uniformity under a 77 kV overhead transmission line – Effect of heights of conductors	24
Figure A.6 – Electric field levels and non-uniformity under a 500 kV overhead transmission line – Effects of the heights of conductors	25
Figure A.7 – Electric field levels under a 77 kV overhead transmission line – Effect of separation between conductors.....	26
Figure A.8 – Electric field levels and non-uniformity under a 500 kV overhead transmission line – Effect of separation between conductors.....	27
Figure A.9 – Vertical and horizontal components of electric field levels under a 77 kV overhead transmission line	27
Figure A.10 – Vertical and horizontal components of electric field levels under a 500 kV overhead transmission line.....	28
Figure A.11 – Electric field contour of a 25 kV overhead line.....	28
Figure A.12 – Electric field profile along the wall of a building and at 1 m above ground level.....	29
Figure B.1 – Magnetic field levels under a 77 kV overhead transmission line	32
Figure B.2 – Magnetic field levels under a 500 kV overhead transmission line	33
Figure B.3 – Magnetic field levels and non-uniformity under a 77 kV overhead transmission line – Effect of heights of conductors	34
Figure B.4 – Magnetic field levels and non-uniformity under a 500 kV overhead transmission line – Effect of heights of conductors.....	35
Figure B.5 – Magnetic field levels and non-uniformity under a 77 kV overhead transmission line – Effect of separation between conductors.....	36
Figure B.6 – Magnetic field levels under a 500 kV overhead transmission line – Effect of separation between conductors.....	37
Figure B.7 – Values of semi-major and semi-minor components (r.m.s.) of magnetic field levels under a 77 kV overhead transmission line	38
Figure B.8 – Values of semi-major and semi-minor components (r.m.s.) of magnetic field levels under a 500 kV overhead transmission line	38
Figure B.9 – Magnetic field levels and non-uniformity under an overhead distribution line (6 600 V / 100 V).....	39
Figure B.10 – Magnetic field levels and non-uniformity above underground cables – Effect of buried depth	40
Figure B.11 – Magnetic field levels and non-uniformity above underground cables – Effect of separation between conductors.....	40
Figure B.12 – Measured magnetic field levels and non-uniformity around a 6 600 V pad-mounted transformer.....	41
Figure B.13 – Measured magnetic field levels and non-uniformity around 6 600 V vertical cables.....	41
Figure C.1 – A spheroidal human model	42
Figure C.2 – The model in the magnetic field generated by a straight cable	43
Figure C.3 – Magnetic field levels generated by a straight cable	43
Figure C.4 – The model in the magnetic field generated by three parallel cables	44
Figure C.5 – Magnetic field levels generated by three balanced parallel cables	44
Figure C.6 – The model in the magnetic field generated by underground cables	45
Figure C.7 – Magnetic field levels generated by underground cables	45
Figure C.8 – The model in the magnetic field generated by overhead wires	46

Figure C.9 – Magnetic field levels generated by balanced overhead wires 46

This document is a preview generated by EVS

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ELECTRIC AND MAGNETIC FIELD LEVELS GENERATED BY AC POWER
SYSTEMS – MEASUREMENT PROCEDURES
WITH REGARD TO PUBLIC EXPOSURE**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62110 has been prepared by IEC technical committee 106: Methods for the assessment of electric, magnetic and electromagnetic fields associated with human exposure.

The text of this standard is based on the following documents:

FDIS	Report on voting
106/177/FDIS	106/185/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

Terms defined in Clause 3 appear in *italics* throughout the document.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

INTRODUCTION

All populations of the world are now exposed to electric and magnetic fields and the levels will continue to increase with developing industry and technology. A number of countries have implemented regulations on public exposure to these fields. Therefore, in order to evaluate human exposure levels to these fields adequately, common measurement procedures are required by not only professionals of national authorities and electric power industries, but also the general public.

This standard is applied to the measurement of fields generated by AC power systems in areas accessible to the public. It establishes a common measurement procedure to evaluate the exposure levels of the human body to electric and magnetic fields among the general public.

The values obtained are for use to determine whether the fields comply with exposure limits by comparing them with the field limits for general public exposure such as the reference levels from the ICNIRP (International Commission on Non-Ionizing Radiation Protection) Guidelines [1]¹⁾, MPE (maximum permissible exposure) from the IEEE (Institute of Electrical and Electronics Engineers) [2] or in national regulations. If the values obtained are higher than the reference level or MPE, it does not necessarily mean that the basic restriction has been exceeded, in which case other methods must be used to ensure that basic restriction is not exceeded.

The values obtained by using the procedures in this standard are for the load conditions occurring at the time of measurement. Therefore, in the case of magnetic field, in order to check compliance with some exposure guidelines or regulations these values may need to be extrapolated to take account of the maximum load of the circuits.

This standard is not applicable to occupational exposure associated with, for example, the operation and/or maintenance of the power systems. Such exposure may occur when working inside a distribution or transmission substation, a power plant, in a manhole or a tunnel for underground cables, or on an overhead line tower or pole.

¹⁾ Numbers in square brackets refers to the Bibliography.

ELECTRIC AND MAGNETIC FIELD LEVELS GENERATED BY AC POWER SYSTEMS – MEASUREMENT PROCEDURES WITH REGARD TO PUBLIC EXPOSURE

1 Scope

This International Standard establishes measurement procedures for electric and magnetic field levels generated by AC power systems to evaluate the exposure levels of the human body to these fields. This standard is not applicable to DC power transmission systems.

This International Standard is applicable to public exposure in the domestic environment and in areas accessible to the public.

This standard specifies fundamental procedures for the measurement of fields, and, with regard to human exposure, for obtaining a field value that corresponds to a spatial average over the entire human body.

This standard is not applicable to occupational exposure associated with, for example, the operation and/or maintenance of the power systems. Such exposure may occur when working inside a distribution or transmission substation, a power plant, in a manhole or a tunnel for underground cables, or on an overhead line tower or pole.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61786, *Measurement of low-frequency magnetic and electric fields with regard to exposure of human beings – Special requirements for instruments and guidance for measurements*

3 Terms and definitions

For the purposes of this document, the following terms and definitions given below apply. Internationally accepted SI-units are used throughout the standard.

NOTE The distinction between “magnetic flux density” and “magnetic field strength” is only relevant when considering magnetic fields in magnetic materials. In air it is common to use “magnetic fields” as a generic term to cover both of these two quantities.

3.1

single-point measurement

procedure to measure the field level at a specified height, used for uniform fields

NOTE The conditions under which the field can be considered as uniform or non-uniform are given in section 5.1.

3.2

three-point measurement

procedure to measure the field levels at three specified heights at a single location, used for non-uniform fields