INTERNATIONAL STANDARD

ISO 21940-1

First edition 2019-02

Mechanical vibration — **Rotor** balancing —

Part 1: Introduction

Vibrations mécaniques — Équilibrage des rotors — Partie 1: Introduction





© ISO 2019

Nementation, no probanical, includir requested fr All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office CP 401 • Ch. de Blandonnet 8 CH-1214 Vernier, Geneva Phone: +41 22 749 01 11 Fax: +41 22 749 09 47 Email: copyright@iso.org Website: www.iso.org

Published in Switzerland

Coı	ntent	S	Page			
Fore	word		v			
Intr	oductio	n	vi			
1	Scon	e	1			
2	<.O.	native references				
3		ns and definitions				
4		indamentals of balancing				
	4.1 4.2	GeneralUnbalance of a single disc				
	4.2	Unbalance distribution				
	4.4					
5	Factors to consider when balancing					
3	5.1	General				
	5.2	Rotors with rigid behaviour				
	5.3	Rotors with flexible behaviour				
		5.3.1 General				
		5.3.2 Shaft-elastic behaviour	6			
		5.3.3 Component-elastic behaviour				
		5.3.4 Settling behaviour				
	5.4	Examples of rotor behaviours				
6	Selec	ction of a balancing procedure	8			
7	Unba	alance tolerances	9			
•	7.1	General	9			
	7.2	Permissible residual unbalance	9			
		7.2.1 General				
		7.2.2 Permissible residual unbalance for rotors with rigid behaviour	9			
		7.2.3 Permissible residual unbalance for rotors with flexible behaviour				
	7.3	Vibration limits				
	7.4	Influence of modes above service speed	10			
	7.5	Factors influencing balancing procedures	II 11			
		7.5.2 Tolerances				
		7.5.3 Speed and support conditions	12			
		7.5.4 Initial unbalance	12			
8	Cala	ction of a balancing machine				
	8.1	General				
	8.2	Special requirements				
•						
9	Inter 9.1	national Standards on balancing General				
	9.1	Vocabulary				
	9.2	9.2.1 ISO 21940-2 — Balancing vocabulary				
		9.2.2 ISO 2041 — Vibration and shock vocabulary				
	9.3	Balancing procedures and tolerances				
		9.3.1 General				
		9.3.2 ISO 21940-11 — Procedures and tolerances for rotors with rigid behaviour				
		9.3.3 ISO 21940-12 — Procedures and tolerances for rotors with flexible behaviour	r.14			
		9.3.4 ISO 21940-13 — Criteria and safeguards for the <i>in-situ</i> balancing of				
		medium and large rotors				
	0.4	9.3.5 ISO 21940-14 — Procedures for addressing balancing errors				
	9.4	Balancing machines 9.4.1 ISO 21940-21 — Description and evaluation of balancing machines	15 15			

ISO 21940-1:2019(E)

	9.4.2		— Enclosures and other protective measures for the	4.5
9.5	Machir	measuring stat le design for hala	tion of balancing machinesancing	15 16
	9.5.1 9.5.2	ISO 21940-31	— Susceptibility and sensitivity of machines to unbalance — Shaft and fitment key convention	16
Annex A (in			l and graphical representation of unbalance	
Annex B (in	formative	e) Examples of c	lifferent rotor behaviours as indicated on a typical	
	ıv			
iv			© ISO 2019 – All rights r	eserved

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 108, *Mechanical vibration, shock and condition monitoring*, Subcommittee SC 2, *Measurement and evaluation of mechanical vibration and shock as applied to machines, vehicles and structures*.

This first edition of ISO 21940-1 cancels and replaces ISO 19499:2007, which has been technically revised. The main changes are as follows:

- reference made to all International Standards in the ISO 21940 series;
- deletion of former Table 2 "Guidelines for balancing procedures";
- deletion of former Annex C "How to determine rotor flexibility based on an estimation from its geometric design".

A list of all parts in the ISO 21940 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

2/25

Introduction

Vibration caused by rotor unbalance is one of the most critical issues in the design and maintenance of rotating machines. It gives rise to dynamic forces which adversely affect both machine and human pu.

n a general calancing app. health and well-being. The purpose of this document is to give guidance on the usage of the other parts of the ISO 21940 series.

Balancing is explained in a general manner, using the specific terms and definitions, to help readers to select the appropriate balancing approach for their application.

Mechanical vibration — Rotor balancing —

Part 1:

Introduction

1 Scope

This document provides a general background to balancing technology, as used in the ISO 21940 series, and directs the reader to the appropriate parts of the series that include vocabulary, balancing procedures and tolerances, balancing machines and machine design for balancing.

Individual procedures are not included here as these can be found in the appropriate parts of ISO 21940.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 2041, Mechanical vibration, shock and condition monitoring — Vocabulary

ISO 21940-2, Mechanical vibration — Rotor balancing — Part 2: Vocabulary

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 2041 and ISO 21940-2 apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at https://www.iso.org/obp/
- IEC Electropedia: available at http://www.electropedia.org/

4 Fundamentals of balancing

4.1 General

Balancing is a procedure by which the mass distribution of a rotor (or part of a rotor or module) is measured and adjusted to ensure that unbalance tolerances are met.

Many factors can cause rotor unbalance, e.g. non-homogenous material, manufacture, assembly, wear during operation, debris or an operational event. It is important to understand that every rotor, even in series production, has a unique individual unbalance distribution.

New rotors are commonly balanced by the manufacturer in balancing machines before installation into their operational environment. Following rework or repair, rotors can be rebalanced in a balancing machine or, if appropriate facilities are not available, the rotor can be balanced *in situ* (for details, see ISO 21940-13). For *in-situ* balancing, the rotor is held in its service bearings and support structure and rotated within its operational drive train.

When rotated, unbalance generates forces that can be directly measured by force gauges mounted on the structures supporting the bearings or indirectly by measuring either the motion of the bearing or the shaft. The unbalance vector can be calculated from these measurements and balancing achieved by