
**Thermoplastics piping systems for
fluids under pressure — Flange
adapters and loose backing flanges —
Mating dimensions**

*Systèmes de canalisations thermoplastiques pour fluides sous
pression — Collets et brides folles plates — Dimensions de
raccordement*



This document is a preview generated by ERS



COPYRIGHT PROTECTED DOCUMENT

© ISO 2019

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Fax: +41 22 749 09 47
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	2
4 Symbols and abbreviated terms	2
5 Dimensions	3
5.1 General.....	3
5.2 Butt fusion systems.....	3
5.3 Socket fusion systems.....	8
5.4 Adhesive bonded systems.....	9
6 Gaskets	12
7 Marking	12
7.1 Minimum required marking of flange adapters.....	12
7.2 Minimum required marking of loose backing flanges.....	13
Annex A (informative) Gaskets	14
Annex B (informative) Guidance for the application of the bolt torque	15
Annex C (informative) Recommended dimensions for PE100 flange adapter in relation to the loose backing flanges PN	17
Bibliography	19

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 138, *Plastics pipes, fittings and valves for the transport of fluids*, Subcommittee SC 2, *Plastics pipes and fittings for water supplies*.

This second edition cancels and replaces the first edition (ISO 9624:1997), which has been technically revised.

The main changes compared to the previous edition are:

- increase of dimensions up to 2 500 mm;
- technical consistency with industrial applications standards;
- addition of two informative annexes on gaskets and torque application.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

This document covers the dimensions of flange adapters and loose backing flanges which are commonly used in the connection of plastic piping systems to valves, pumping stations or other equipment, and to pipelines of the same or other material. Some equipment (e.g. butterfly valves) may require specific designs that are not covered by this document.

This revised version of this document covers dimensions allowing the connection of plastic piping systems up to DN 2500, to answer the increasing demand of large dimensions on the market.

Flanged joints should be able to transfer long-term axial forces with maintained tightness, which requires use of suitable components and a correct assembly. This revised version includes informative annexes addressing joint design and torque application and gives bibliographic references to installation guidelines which are available on the market.

Thermoplastics piping systems for fluids under pressure — Flange adapters and loose backing flanges — Mating dimensions

1 Scope

This document specifies the mating dimensions for thermoplastic flange adapters and corresponding loose backing flanges intended to be used in thermoplastic piping systems for the conveyance of fluids under pressure.

It applies to flange adapters and loose backing flanges for use with pipes with nominal outside diameters (d_n) from 16 mm to 2 500 mm and nominal pressures up to 25 bar¹⁾ (PN 25).

This document specifies the dimensions of the flange adapters intended to be used for:

- butt fusion piping systems;
- socket fusion piping systems;
- adhesive jointed piping systems.

NOTE 1 For specific connections with dimensions (e.g. $d_n 450$ or $d_n 630$) not covered in this document, or specific equipment (butterfly valves), specific solutions are available on the market.

This document is applicable to loose backing flanges made from metal, thermoplastics, or a combination of metal and thermoplastics.

This document also provides information on gaskets and gives general recommendations on correct assembling practices.

NOTE 2 Industrial applications are not covered by this document. Products intended for industrial application are covered by ISO 15493^[1], ISO 15494 or ISO 10931^[2].

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 261, *ISO general purpose metric screw threads — General plan*

ISO 727-1, *Fittings made from unplasticized poly(vinyl chloride) (PVC-U), chlorinated poly(vinyl chloride) (PVC-C) or acrylonitrile/butadiene/styrene (ABS) with plain sockets for pipes under pressure — Part 1: Metric series*

ISO 1452-3, *Plastics piping systems for water supply and for buried and above-ground drainage and sewerage under pressure — Unplasticized poly(vinyl chloride) (PVC-U) — Part 3: Fittings*

ISO 4427-3, *Plastics piping systems — Polyethylene (PE) pipes and fittings for water supply — Part 3: Fittings*

ISO 7005-1, *Pipe flanges — Part 1: Steel flanges for industrial and general service piping systems*

1) 1 bar = 0,1 MPa = 10⁵ N/m².

ISO 15494, *Plastics piping systems for industrial applications — Polybutene (PB), polyethylene (PE), polyethylene of raised temperature resistance (PE-RT), crosslinked polyethylene (PE-X), polypropylene (PP) — Metric series for specifications for components and the system*

ISO 15874-3, *Plastics piping systems for hot and cold water installations — Polypropylene (PP) — Part 3: Fittings*

EN 1092-1, *Flanges and their joints — Circular flanges for pipes, valves, fittings and accessories, PN designated — Part 1: steel flanges*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1

nominal outside diameter

d_n

specified outside diameter, in millimetres, assigned to a nominal size DN/OD

Note 1 to entry: The nominal outside diameter d_n of pipes is given in ISO 161-1[3].

3.2

nominal size

DN

numerical designation of the size of a flange for reference purposes and only loosely related to manufacturing dimensions

3.3

nominal pressure

PN

numerical designation used for reference purposes related to the mechanical characteristics of the component of a piping system

Note 1 to entry: For plastic piping systems conveying water (including flange adapters), the PN symbols correspond to the allowable operating pressure (PFA) in bar, which can be sustained with water at 20 °C with a design basis of 50 years, and based on the minimum design coefficient in accordance with ISO 12162[4]. For loose backing flanges, the PN symbol is used to indicate its geometrical characteristics.

4 Symbols and abbreviated terms

d_n nominal (outside) diameter of connecting pipe and flange adapters, and nominal (inside) diameter of the socket

D outside diameter of loose backing flange

DN size designation of loose backing flange

D_1 bolt hole diameter

D_2 inside diameter of loose backing flange

D_3 pitch circle diameter