
**Water quality — Determination of
biochemical oxygen demand after n
days (BOD _{n}) —**

**Part 1:
Dilution and seeding method with
allylthiourea addition**

*Qualité de l'eau — Détermination de la demande biochimique en
oxygène après n jours (DBO _{n}) —*

*Partie 1: Méthode par dilution etensemencement avec apport
d'allylthiourée*



This document is a preview generated by EMS



COPYRIGHT PROTECTED DOCUMENT

© ISO 2019

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Fax: +41 22 749 09 47
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

	Page
Foreword.....	iv
Introduction.....	vi
1 Scope	1
2 Normative references	1
3 Terms and definitions	2
4 Principle	3
5 Reagents	3
6 Apparatus	6
7 Sampling and preservation	6
8 Interferences	7
8.1 General.....	7
8.2 Presence of free and/or combined chlorine.....	7
8.3 Presence of algae.....	7
8.4 Presence of peroxides and peroxide compounds.....	8
9 Procedure	8
9.1 General.....	8
9.2 Pretreatment.....	8
9.2.1 Neutralization of the sample.....	8
9.2.2 Homogenization.....	9
9.3 Preparation of test solutions.....	9
9.4 Calculation of dilutions.....	9
9.4.1 Empirical determination of the dilutions.....	9
9.4.2 Determination of dilutions via the factors <i>R</i> of the TOC, the permanganate index or the COD.....	10
9.4.3 Calculation of dilution stages via the COD.....	11
9.5 Blank value determination.....	11
9.6 Determination of dissolved oxygen.....	11
9.6.1 Measurement of dissolved oxygen using iodometric method (in accordance with ISO 5813).....	11
9.6.2 Measurement of dissolved oxygen using probes (in accordance with ISO 5814 or ISO 17289).....	12
9.7 Control analysis.....	12
10 Calculation and indication of the results	13
10.1 Examination of test solutions for valid oxygen consumption during test.....	13
10.2 Calculation of biochemical oxygen demand after <i>n</i> days (BOD _{<i>n</i>}).....	13
10.3 Validity criteria.....	14
11 Test report	14
Annex A (normative) Influence of incubation periods and temperatures	15
Annex B (informative) Multitesting	16
Annex C (informative) Direct seeding of the analysis batches	19
Annex D (informative) Performance data	20
Bibliography	22

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 147, *Water quality*, Subcommittee SC 5, *Biological methods*.

This second edition cancels and replaces the first edition (ISO 5815-1:2003), which has been technically revised. The main changes compared to the previous edition are as follows:

- change of working range: 1 mg/l instead of 3 mg/l as lower limit;
- changes in test procedure;
- in [5.2](#), option to check seeding water suitability in advance with a CGA control analysis batch;
- in [5.3.2](#), phosphate buffer solution pH-value: requirement for preparation of a new solution if the pH value is out of the range pH 7 and pH 8;
- in [5.5](#), range for oxygen consumption of seeded dilution water 0,2 mg/l to 1,5 mg/l instead of upper limit 1,5 mg/l;
- in [5.9](#), allowable range BOD₅ of the CGA control solution changed to (198 ± 40) mg/l and BOD₇ (206 ± 40) mg/l;
- in [6.5](#), electrochemical probe option to measure the dissolved oxygen concentration added;
- in [8.4](#), interferences: subclause on presence of peroxides and peroxide compounds added;
- in [9.4](#), options to determinate the dilutions elaborated;
- in [9.7](#), control analysis: elaborated description of procedure;
- in [10.3](#), "approval of results/validity criteria" added;
- [Annex A](#): title changed and "normative" instead of "informative"
- [Annex C](#) "Direct seeding of the analysis batches" added;

— new [Annex D](#) "Performance data" included.

A list of all parts in the ISO 5815 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

The incubation time specified in this document is 5 d or 7 d. The latter corresponds to the practice in several Nordic countries. [Annex A](#) describes an incubation time of (2 + 5) d.

ISO 5815-1 specifies the determination of the biochemical oxygen demand (BOD) of waters with an expected BOD in the range 1 mg/l to 6 000 mg/l using the dilution method. A lower limit of working range may result from validation data in the laboratory. For samples with an expected low BOD in the range of 0,5 mg/l to 6 mg/l ISO 5815-2 provides the option of the determination of the (BOD) of waters using undiluted samples.

Water quality — Determination of biochemical oxygen demand after n days (BOD_n) —

Part 1:

Dilution and seeding method with allylthiourea addition

WARNING — Persons using this document should be familiar with normal laboratory practice. This document does not purport to address all of the safety problems, if any, associated with its use. It is the responsibility of the user to establish appropriate safety and health practices.

IMPORTANT — It is absolutely essential that tests conducted in accordance with this document be carried out by suitably qualified staff.

1 Scope

This document specifies the determination of the biochemical oxygen demand of waters by dilution and seeding with suppression of nitrification after 5 d or 7 d incubation time.

It is applicable to all waters having biochemical oxygen demands usually between 1 mg/l and 6 000 mg/l. It applies particularly to waste waters but also suits for the analysis of natural waters. For biochemical oxygen demands greater than 6 000 mg/l of oxygen, the method is still applicable, but special care is needed taking into consideration the representativeness of subsampling for preparation of the dilution steps. The results obtained are the product of a combination of biochemical and chemical reactions in presence of living matter which behaves only with occasional reproducibility. The results do not have the rigorous and unambiguous character of those resulting from, for example, a single, well-defined, chemical process. Nevertheless, the results provide an indication from which the quality of waters can be estimated.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 3696, *Water for analytical laboratory use — Specification and test methods*

ISO 5667-3, *Water quality — Preservation and handling of water samples*

ISO 5813, *Water quality — Determination of dissolved oxygen — Iodometric method*

ISO 5814, *Water quality — Determination of dissolved oxygen — Electrochemical probe method*

ISO 6060, *Water quality — Determination of the chemical oxygen demand*

ISO 8245, *Water quality — Guidelines for the determination of total organic carbon (TOC) and dissolved organic carbon (DOC)*

ISO 8467, *Water quality — Determination of permanganate index*

ISO 10523, *Water quality — Determination of pH*

ISO 15705, *Water quality — Determination of the chemical oxygen demand index (ST-COD) — Small-scale sealed-tube method*

ISO 17289, *Water quality — Determination of dissolved oxygen — Optical sensor method*