INTERNATIONAL STANDARD

ISO 4427-2

> Second edition 2019-08

Plastics piping systems for water supply, and for drainage and sewerage under pressure — Polyethylene (PE) —

Part 2: **Pipes**

> Systèmes de canalisations en plastique destinés à l'alimentation chen.
> ethylène
> ss en eau et aux branchements et collecteurs d'assainissement sous pression — Polyéthylène (PE) —

Partie 2: Tubes





© ISO 2019

lementation, no partanical, includir requested fr All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office CP 401 • Ch. de Blandonnet 8 CH-1214 Vernier, Geneva Phone: +41 22 749 01 11 Fax: +41 22 749 09 47 Email: copyright@iso.org Website: www.iso.org

Published in Switzerland

Co	ntents		Page
Fore	eword		iv
Intr	oduction		v
1	Scope		1
2	Normative references		2
3	Terms and definitions		2
4	Symbols and abbreviated terms		3
5	Material		3
	5.1 Compound		
	5.2 Identification compound5.3 Reprocessed and recycled material		
6	General characteristics		
	6.1 Appearance		
	6.2 Colour		
_	6.3 Effect on water quality		
7	Geometrical characteristics 7.1 Measurements		
	7.2 Mean outside diameter and out-of-roundness (ovality)		4
	7.3 Wall thicknesses and their tolerances		
	7.4 Coiled pipe		10 10
8	Mechanical characteristics		
	8.1 Conditioning		
	8.2 Requirements 8.3 Retest in case of failure at 80 °C		
9	Physical characteristics		
,	9.1 Conditioning		12
	9.2 Requirements		
10	Chemical characteristics of pipes in contact with chemicals		
11	Performance requirements		13
12	Marking		
	12.1 General		
Ann	nex A (normative) Pipes with co-extruded layers		
Ann	nex B (normative) Pipes with peelable layer		17
Ann	nex C (informative) Relationship between PN, MRS, S and SDR		19
Rihl	liography	0,	20
			5

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 138, *Plastics pipes, fitting and valves for the transport of fluids*, Subcommittee SC 2, *Plastics pipes and fittings for water supplies*.

This second edition cancels and replaces the first edition (ISO 4427-2:2007), which has been technically revised. It also incorporates Amendment ISO 4427-2:2007/Amd. 1:2014.

The main changes compared to the previous edition are:

- Update of the normative references;
- Technical consistency with ISO 4437-2 (see Bibliography [1]).

A list of all parts in the ISO 4427 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

5

Introduction

The ISO 4427 series of standards are a set of system standards that specify the requirements for a piping system and its components when made from polyethylene (PE). The piping system is intended to be used in buried or above ground applications, for the conveyance of water for human consumption, raw water prior to treatment, drainage and sewerage under pressure, vacuum sewer systems, and water for other purposes.

In respect of potential adverse effects on the quality of water intended for human consumption caused by assessment control of the control by the products covered by the ISO 4427 series, it does not provide information on the restriction on the use of products.

NOTE Guidance for assessment of conformity can be found in Reference [2] in the Bibliography. This document is a previous general ded by tills

Plastics piping systems for water supply, and for drainage and sewerage under pressure — Polyethylene (PE) —

Part 2:

Pipes

1 Scope

This document specifies the pipes made from polyethylene (PE) for buried or above ground applications, intended for the conveyance of:

- water for human consumption;
- raw water prior to treatment;
- drainage and sewerage under pressure;
- vacuum sewer systems;
- water for other purposes.

NOTE 1 The intended uses include sea outfalls, laid in water and pipes suspended below bridges.

Pipes complying with this document are not intended for the transport of water intended for human consumption in contaminated soils unless special consideration has been taken.

NOTE 2 For example, ISO 21004 provides an alternative solution for use in contaminated soils. See Reference [3] in the Bibliography.

This document specifies three types of pipe:

- PE pipes (outside diameter d_n), including any identification stripes;
- PE pipes with co-extruded layers on either or both the outside and/or inside of the pipe (total outside diameter d_n) where all layers have the same MRS rating;
- PE pipes (outside diameter d_n) having a peelable and contiguous thermoplastics additional layer on the outside of the pipe ("coated pipe").

This document also specifies the test parameters for the test methods referred to in this document.

In conjunction with the other parts of the ISO 4427 series, this document is applicable to PE pipes, their joints and to joints with components made of PE and other materials, intended to be used under the following conditions:

- a) a maximum allowable operating pressure (PFA) up to and including 25 bar¹;
- b) an operating temperature of 20 °C as the reference temperature.

NOTE 3 For other operating temperatures, guidance is given in ISO 4427-1:2019, Annex A.

¹⁾ $1 \text{ bar} = 0.1 \text{ MPa} = 10^5 \text{ Pa}; 1 \text{ MPa} = 1 \text{ N/mm}^2.$

ISO 4427-2:2019(E)

This document covers a range of maximum allowable operating pressures and gives requirements concerning colours.

NOTE 4 It is the responsibility of the purchaser or specifier to make the appropriate selections from these aspects, taking into account their particular requirements and installation practices or codes.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 1133-1, Plastics — Determination of the melt mass-flow rate (MFR) and melt volume-flow rate (MVR) of thermoplastics — Part 1: Standard method

ISO 1167-1:2006, Thermoplastics pipes, fittings and assemblies for the conveyance of fluids — Determination of the resistance to internal pressure — Part 1: General method

ISO 1167-2, Thermoplastics pipes, fittings and assemblies for the conveyance of fluids — Determination of the resistance to internal pressure — Part 2: Preparation of pipe test pieces

ISO 2505, Thermoplastics pipes — Longitudinal reversion — Test method and parameters

ISO 3126, Plastics piping systems — Plastics components — Determination of dimensions

ISO 4427-1:2019, Plastics piping systems — Polyethylene (PE) pipes and fittings for water supply — Part 1: General

ISO 4427-5:2019, Plastics piping systems — Polyethylene (PE) pipes and fittings for water supply — Part 5: Fitness for purpose of the system

ISO 4433-1, Thermoplastics pipes — Resistance to liquid chemicals — Classification — Part 1: Immersion test method

ISO 4433-2, Thermoplastics pipes — Resistance to liquid chemicals — Classification — Part 2: Polyolefin pipes

ISO 6259-1, Thermoplastics pipes — Determination of tensile properties — Part 1: General test method

ISO 6259-3, Thermoplastics pipes — Determination of tensile properties — Part 3: Polyolefin pipes

ISO 11357-6, Plastics — Differential scanning calorimetry (DSC) — Part 6: Determination of oxidation induction time (isothermal OIT) and oxidation induction temperature (dynamic OIT)

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 4427-1 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at http://www.electropedia.org/
- ISO Online browsing platform: available at http://www.iso.org/obp

3.1

application code

code letter which identifies the intended use of the product

Note 1 to entry: The code letter mentioned in this document is W indicating "water intended for human consumption".