

**Acoustics - Laboratory measurement of sound  
insulation of building elements - Part 4: Measurement  
procedures and requirements**

## EESTI STANDARDI EESSÕNA

## NATIONAL FOREWORD

Käesolev Eesti standard EVS-EN ISO 10140-4:2010 sisaldab Euroopa standardi EN ISO 10140-4:2010 ingliskeelset teksti.

Standard on kinnitatud Eesti Standardikeskuse 31.10.2010 käskkirjaga ja jõustub sellekohase teate avaldamisel EVS Teatajas.

Euroopa standardimisorganisatsioonide poolt rahvuslikele liikmetele Euroopa standardi teksti kättesaadavaks tegemise kuupäev on 01.09.2010.

Standard on kättesaadav Eesti standardiorganisatsioonist.

This Estonian standard EVS-EN ISO 10140-4:2010 consists of the English text of the European standard EN ISO 10140-4:2010.

This standard is ratified with the order of Estonian Centre for Standardisation dated 31.10.2010 and is endorsed with the notification published in the official bulletin of the Estonian national standardisation organisation.

Date of Availability of the European standard text 01.09.2010.

The standard is available from Estonian standardisation organisation.

ICS 91.120.20

### Standardite reprodutseerimis- ja levitamiseõigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonilisse süsteemi või edastamine ükskõik millises vormis või millisel teel on keelatud ilma Eesti Standardikeskuse poolt antud kirjaliku loata.

Kui Teil on küsimusi standardite autorikaitse kohta, palun võtke ühendust Eesti Standardikeskusega:  
Aru 10 Tallinn 10317 Eesti; [www.evs.ee](http://www.evs.ee); Telefon: 605 5050; E-post: [info@evs.ee](mailto:info@evs.ee)

### Right to reproduce and distribute belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without permission in writing from Estonian Centre for Standardisation.

If you have any questions about standards copyright, please contact Estonian Centre for Standardisation:  
Aru str 10 Tallinn 10317 Estonia; [www.evs.ee](http://www.evs.ee); Phone: 605 5050; E-mail: [info@evs.ee](mailto:info@evs.ee)

ICS 91.120.20

Supersedes EN 20140-10:1992, EN ISO 140-1:1997, EN ISO 140-11:2005, EN ISO 140-16:2006, EN ISO 140-3:1995, EN ISO 140-6:1998, EN ISO 140-8:1997

English Version

**Acoustics - Laboratory measurement of sound insulation of building elements - Part 4: Measurement procedures and requirements (ISO 10140-4:2010)**

Acoustique - Mesurage en laboratoire de l'isolation acoustique des éléments de construction - Partie 4: Exigences et modes opératoires de mesure (ISO 10140-4:2010)

Akustik - Messung der Schalldämmung von Gebäudeteilen im Prüfstand - Teil 4: Messverfahren und Anforderungen (ISO 10140-4:2010)

This European Standard was approved by CEN on 14 August 2010.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**Management Centre: Avenue Marnix 17, B-1000 Brussels**

## Foreword

This document (EN ISO 10140-4:2010) has been prepared by Technical Committee ISO/TC 43 "Acoustics" in collaboration with Technical Committee CEN/TC 126 "Acoustic properties of building elements and of buildings" the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by March 2011, and conflicting national standards shall be withdrawn at the latest by March 2011.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN ISO 140-1:1997, EN ISO 140-8:1997, EN ISO 140-11:2005, EN 20140-10:1992, EN ISO 140-3:1995, EN ISO 140-6:1998, EN ISO 140-16:2006.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

### Endorsement notice

The text of ISO 10140-4:2010 has been approved by CEN as a EN ISO 10140-4:2010 without any modification.

<b>Contents</b>		<b>Page</b>
<b>Foreword</b> .....		<b>iv</b>
<b>Introduction</b> .....		<b>v</b>
<b>1</b>	<b>Scope</b> .....	<b>1</b>
<b>2</b>	<b>Normative references</b> .....	<b>1</b>
<b>3</b>	<b>Terms and definitions</b> .....	<b>1</b>
<b>4</b>	<b>Measurement procedures and requirements</b> .....	<b>2</b>
<b>5</b>	<b>Sound insulation measurements</b> .....	<b>8</b>
<b>Annex A</b> (informative) <b>Additional procedures for measurements at low frequencies</b> .....		<b>10</b>
<b>Bibliography</b> .....		<b>12</b>

## Introduction

ISO 10140 (all parts) concerns laboratory measurement of the sound insulation of building elements (see Table 1).

ISO 10140-1 specifies the application rules for specific elements and products, including specific requirements for preparation, mounting, operating and test conditions. ISO 10140-2 and ISO 10140-3 contain the general procedures for airborne and impact sound insulation measurements, respectively, and refer to this part of ISO 10140 and ISO 10140-5 where appropriate. For elements and products without a specific application rule described in ISO 10140-1, it is possible to apply ISO 10140-2 and ISO 10140-3. This part of ISO 10140 contains basic measurement techniques and processes. ISO 10140-5 contains requirements for test facilities and equipment. For the structure of ISO 10140 (all parts), see Table 1.

ISO 10140 (all parts) was created to improve the layout for laboratory measurements, ensure consistency and simplify future changes and additions regarding mounting conditions of test elements in laboratory and field measurements. It is intended for ISO 10140 (all parts) to present a well-written and arranged format for laboratory measurements.

It is intended to update ISO 10140-1 with application rules for other products. It is also intended to incorporate ISO 140-18 into ISO 10140 (all parts).

**Table 1 — Structure and contents of ISO 10140 (all parts)**

Relevant part of ISO 10140	Main purpose, contents and use	Detailed content
ISO 10140-1	It indicates the appropriate test procedure for elements and products. For certain types of element/product, it can contain additional and more specific instructions about quantities and test element size and about preparation, mounting and operating conditions. Where no specific details are included, the general guidelines are according to ISO 10140-2 and ISO 10140-3.	Appropriate references to ISO 10140-2 and ISO 10140-3 and product-related, specific and additional instructions on: <ul style="list-style-type: none"> <li>— specific quantities measured;</li> <li>— size of test element;</li> <li>— boundary and mounting conditions;</li> <li>— conditioning, testing and operating conditions;</li> <li>— additional specifics for test report.</li> </ul>
ISO 10140-2	It gives a complete procedure for airborne sound insulation measurements according to ISO 10140-4 and ISO 10140-5. For products without specific application rules, it is sufficiently complete and general for the execution of measurements. However, for products with specific application rules, measurements are carried out according to ISO 10140-1, if available.	<ul style="list-style-type: none"> <li>— Definitions of main quantities measured</li> <li>— General mounting and boundary conditions</li> <li>— General measurement procedure</li> <li>— Data processing</li> <li>— Test report (general points)</li> </ul>
ISO 10140-3	It gives a complete procedure for impact sound insulation measurements according to ISO 10140-4 and ISO 10140-5. For products without specific application rules, it is sufficiently complete and general for the execution of measurements. However, for products with specific application rules, measurements are carried out according to ISO 10140-1, if available.	<ul style="list-style-type: none"> <li>— Definitions of main quantities to measured</li> <li>— General mounting and boundary conditions</li> <li>— General measurement procedure</li> <li>— Data processing</li> <li>— Test report (general points)</li> </ul>
ISO 10140-4	It gives all the basic measurement techniques and processes for measurement according to ISO 10140-2 and ISO 10140-3 or facility qualifications according to ISO 10140-5. Much of the content is implemented in software.	<ul style="list-style-type: none"> <li>— Definitions</li> <li>— Frequency range</li> <li>— Microphone positions</li> <li>— SPL measurements</li> <li>— Averaging, space and time</li> <li>— Correction for background noise</li> <li>— Reverberation time measurements</li> <li>— Loss factor measurements</li> <li>— Low-frequency measurements</li> <li>— Radiated sound power by velocity measurement</li> </ul>
ISO 10140-5	It specifies all information needed to design, construct and qualify the laboratory facility, its additional accessories and measurement equipment (hardware).	<p>Test facilities, design criteria:</p> <ul style="list-style-type: none"> <li>— volumes, dimensions;</li> <li>— flanking transmission;</li> <li>— laboratory loss factor;</li> <li>— maximum achievable sound reduction index;</li> <li>— reverberation time;</li> <li>— influence of lack of diffusivity in the laboratory.</li> </ul> <p>Test openings:</p> <ul style="list-style-type: none"> <li>— standard openings for walls and floors;</li> <li>— other openings (windows, doors, small technical elements);</li> <li>— filler walls in general.</li> </ul> <p>Requirements for equipment:</p> <ul style="list-style-type: none"> <li>— loudspeakers, number, positions;</li> <li>— tapping machine and other impact sources;</li> <li>— measurement equipment.</li> </ul> <p>Reference constructions:</p> <ul style="list-style-type: none"> <li>— basic elements for airborne and impact insulation improvement;</li> <li>— corresponding reference performance curves.</li> </ul>

# Acoustics — Laboratory measurement of sound insulation of building elements —

## Part 4: Measurement procedures and requirements

### 1 Scope

This part of ISO 10140 specifies the basic measurement procedures for airborne and impact sound insulation in laboratory test facilities.

### 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 3382-2, *Acoustics — Measurement of room acoustic parameters — Part 2: Reverberation time in ordinary rooms*

ISO 10140-1:2010, *Acoustics — Laboratory measurement of sound insulation of building elements — Part 1: Application rules for specific products*

ISO 10140-2, *Acoustics — Laboratory measurement of sound insulation of building elements — Part 2: Measurement of airborne sound insulation*

ISO 10140-3, *Acoustics — Laboratory measurement of sound insulation of building elements — Part 3: Measurement of impact sound insulation*

ISO 10140-5:2010, *Acoustics — Laboratory measurement of sound insulation of building elements — Part 5: Requirements for test facilities and equipment*

ISO 10848-1:2006, *Acoustics — Laboratory measurement of the flanking transmission of airborne and impact sound between adjoining rooms — Part 1: Frame document*

ISO 18233, *Acoustics — Application of new measurement methods in building and room acoustics*

### 3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

#### 3.1

##### energy average sound pressure level in a room

*L*

ten times the common logarithm of the ratio of the space and time average of the squared sound pressure to the square of the reference sound pressure, the space average being taken over the entire room with the