

Home and Building Electronic Systems (HBES) - Part 5-2:
Media and media dependent layers - Network based on
HBES Class 1, Twisted Pair

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 50090-5-2:2020 sisaldab Euroopa standardi EN 50090-5-2:2020 ingliskeelset teksti.	This Estonian standard EVS-EN 50090-5-2:2020 consists of the English text of the European standard EN 50090-5-2:2020.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 10.04.2020.	Date of Availability of the European standard is 10.04.2020.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 35.100.10, 35.100.20, 97.120

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

English Version

**Home and Building Electronic Systems (HBES) - Part 5-2:
Media and media dependent layers - Network based on HBES
Class 1, Twisted Pair**

Systèmes électroniques pour les foyers domestiques et les
bâtiments (HBES) - Partie 5-2: Médias et couches
dépendantes des médias - Réseau basé sur HBES Classe
1, Paire Torsadée

Elektrische Systemtechnik für Heim und Gebäude (ESHG) -
Teil 5-2: Medien und medienabhängige Schichten -
Netzwerk basierend auf ESHG Klasse 1, Twisted Pair

This European Standard was approved by CENELEC on 2020-01-09. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents

European foreword	4
Introduction.....	5
1 Scope.....	6
2 Normative references	6
3 Terms, definitions and abbreviations	7
3.1 Terms and definitions	7
3.2 Abbreviations	8
4 Requirements for HBES Class 1, Twisted Pair Type 1 (TP1-64 and TP1-256)	9
4.1 Physical layer requirements – Overview	9
4.2 Requirements for analogue bus signals	12
4.2.1 General	12
4.2.2 Specification of logical “1”	12
4.2.3 Specification of logical “0” (Single)	13
4.2.4 Specification of logical “0” (overlapping)	14
4.2.5 Analogue requirements within a transmitted character	15
4.2.6 Simultaneous sending / collision behaviour.....	16
4.3 Medium attachment unit (MAU)	16
4.3.1 General	16
4.3.2 Requirements within a physical segment	16
4.3.3 Remote powered devices (RPD).....	24
4.4 Twisted Pair Type 1 bus cable.....	25
4.4.1 Requirements	25
4.4.2 Measurement of continuous magnetic and electrical interference respectively transient induced differential voltages	26
4.5 Topology	27
4.5.1 Physical segment	27
4.5.2 Bridge	27
4.5.3 Router, subline, main line and zone	28
4.5.4 Gateways to other networks	29
4.6 Services of the physical layer type Twisted Pair Type 1.....	30
4.6.1 General	30
4.6.2 Physical_Data service	30
4.6.3 Physical_Reset service.....	32
4.7 Behaviour of the physical layer type Twisted Pair Type 1 entity.....	32
4.8 Data link layer type Twisted Pair Type 1	32
4.8.1 General	32
4.8.2 Frame formats	33
4.8.3 Medium access control	38
4.8.4 Data link layer services	41
4.8.5 Data link layer protocol.....	44
4.8.6 State machine of data link layer.....	46
4.8.7 Parameters of data link layer	46
4.8.8 Reflections on the system behaviour in case of L_Poll_Data configuration faults	47

4.8.9 The data link layer of a bridge 47

4.8.10 The data link layer of a router 47

4.8.11 Externally accessible bus monitor and data link layer interface 47

Bibliography 48

This document is a preview generated by EVS

European foreword

This document (EN 50090-5-2:2020) has been prepared by CLC/TC 205, “Home and Building Electronic Systems (HBES)”¹

The following dates are fixed:

- latest date by which this document has (dop) 2020-10-10
to be implemented at national level by
publication of an identical national
standard or by endorsement
- latest date by which the national (dow) 2023-04-10
standards conflicting with this document
have to be withdrawn

This document will supersede EN 50090-5-2:2004 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

EN 50090-5-2 is part of the EN 50090 series of European Standards, which will comprise the following parts:

- Part 1: Standardization structure;
- Part 3: Aspects of application;
- Part 4: Media independent layers;
- Part 5: Media and media dependent layers;
- Part 6: Interfaces;
- Part 7: System management;

NOTE Part 2 has been withdrawn.

¹ This document was prepared with the help of CENELEC co-operation partner KNX Association, De Kleetlaan 5, B-1831 Diegem.

Introduction

According to OSI, Physical Layers consist of the medium, the cable, the connectors, the transmission technology etc. which refers to their hardware requirements. In this document however, the status of the Physical Layer as a “communication medium” is emphasized.

This document is a preview generated by EVS

1 Scope

This document defines the mandatory and optional requirements for the medium specific physical and data link layer for HBES Class 1 Twisted Pair TP1.

Data link layer interface and general definitions, which are media independent, are given in EN 50090-4-2.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 50090-1, *Home and Building Electronic Systems (HBES) — Part 1: Standardization structure*

EN 50090-2-2, *Home and Building Electronic Systems (HBES) — Part 2-2: System overview — General technical requirements*

EN 50090-3-2, *Home and Building Electronic Systems (HBES) — Part 3-2: Aspects of application — User process for HBES Class 1*

EN 50090-4-2, *Home and Building Electronic Systems (HBES) — Part 4-2: Media independent layers — Transport layer, network layer and general parts of data link layer for HBES Class 1*

EN 50290 (series), *Communication cables*

EN 61000-4-5, *Electromagnetic compatibility (EMC) — Part 4-5: Testing and measurement techniques — Surge immunity test (IEC 61000-4-5)*

EN 61000-6-1, *Electromagnetic compatibility (EMC) — Part 6-1: Generic standards — Immunity for residential, commercial and light-industrial environments (IEC 61000-6-1)*

EN 61000-6-2, *Electromagnetic compatibility (EMC) — Part 6-2: Generic standards — Immunity for industrial environments (IEC 61000-6-2)*

HD 21.2 S2, *Polyvinyl chloride insulated cables of rated voltages up to and including 450/750 V — Part 2: Test methods (IEC 60227-2)*

HD 22.2 S2, *Rubber insulated cables of rated voltages up to and including 450/750 V — Part 2: Test methods (IEC 60245-2)*

IEC 60189-2, *Low-frequency cables and wires with PVC insulation and PVC sheath — Part 2: Cables in pairs, triples, quads and quintuples for inside installations*

IEC 60332-1, *Tests on electric cables under fire conditions — Part 1: Test on a single vertical insulated wire or cable*

IEC 60754-2, *Test on gases evolved during combustion of materials from cables — Part 2: Determination of acidity (by pH measurement) and conductivity*