

Stationary source emissions - Data acquisition and handling systems - Part 2: Specification of requirements on data acquisition and handling systems

## EESTI STANDARDI EESSÕNA

## NATIONAL FOREWORD

See Eesti standard EVS-EN 17255-2:2020 sisaldab Euroopa standardi EN 17255-2:2020 ingliskeelset teksti.	This Estonian standard EVS-EN 17255-2:2020 consists of the English text of the European standard EN 17255-2:2020.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 29.04.2020.	Date of Availability of the European standard is 29.04.2020.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile [standardiosakond@evs.ee](mailto:standardiosakond@evs.ee).

ICS 13.040.40

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:  
Koduleht [www.evs.ee](http://www.evs.ee); telefon 605 5050; e-post [info@evs.ee](mailto:info@evs.ee)

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Homepage [www.evs.ee](http://www.evs.ee); phone +372 605 5050; e-mail [info@evs.ee](mailto:info@evs.ee)

English Version

Stationary source emissions - Data acquisition and  
handling systems - Part 2: Specification of requirements on  
data acquisition and handling systems

Émissions de sources fixes - Systèmes d'acquisition et  
de traitement de données - Partie 2 : Spécification des  
exigences relatives aux systèmes d'acquisition et de  
traitement de données

Emissionen aus stationären Quellen - Datenerfassungs-  
und Auswerteeinrichtungen - Teil 2: Festlegung von  
Anforderungen an Datenerfassungs- und  
Auswerteeinrichtungen

This European Standard was approved by CEN on 7 March 2020.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

# Contents

Page

European foreword.....	4
Introduction .....	5
1 Scope.....	6
2 Normative references.....	6
3 Terms and definitions .....	6
4 Symbols and abbreviations .....	8
5 Principles .....	8
6 Performance requirements.....	9
6.1 General.....	9
6.2 Data acquisition.....	10
6.2.1 Overview .....	10
6.2.2 Interfaces .....	10
6.2.3 Manual data input.....	11
6.2.4 Remote data logger unit .....	11
6.3 Input data processing.....	11
6.3.1 Validity of input data .....	11
6.3.2 First level data (FLD) .....	12
6.4 Reported data.....	12
6.4.1 General.....	12
6.4.2 Warnings, alarms and violations.....	12
6.5 Reports.....	12
6.5.1 General.....	12
6.5.2 Emission reports .....	13
6.5.3 System reports .....	13
6.6 Data storage .....	13
6.6.1 General.....	13
6.6.2 Time stamping.....	13
6.6.3 Storage of FLD.....	13
6.6.4 Storage of STA.....	13
6.6.5 Storage of standardized STA (SSTA).....	14
6.6.6 Storage of validated STA (VSTA).....	14
6.6.7 Storage of QAL3 data.....	14
6.6.8 Storage of warnings, alarms and violations .....	14
6.6.9 Storage of the event-log and configuration parameters .....	14
6.7 System functions .....	14
6.7.1 Event log .....	14
6.7.2 Configuration .....	14
6.7.3 Export of data .....	14
6.7.4 Test mode.....	15
6.8 Data integrity.....	15
6.8.1 DAHS availability.....	15
6.8.2 Tamper-proof data transfer and handling.....	15
6.8.3 Preventing loss of data.....	15
6.8.4 Data back-up.....	15
6.8.5 DAHS identification .....	16

6.8.6	Time management.....	16
6.9	Documentation .....	16
Annex A (informative) Example list of configuration parameters.....		17
A.1	Measurement channel configuration .....	17
A.2	Data processing configuration.....	18
A.3	Data storage configuration.....	19
A.4	Report configuration.....	19
Bibliography .....		20

## European foreword

This document (EN 17255-2:2020) has been prepared by Technical Committee CEN/TC 264 “Air Quality”, the secretariat of which is held by DIN.

This document shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by October 2020, and conflicting national standards shall be withdrawn at the latest by October 2020.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document is Part 2 of the EN 17255 series.

The EN 17255 series, published under the general title Stationary source emissions — Data acquisition and handling systems, specifies:

- requirements for the handling and reporting of data;
- requirements on data acquisition and handling systems;
- requirements for the performance test of data acquisition and handling systems;
- requirements for the installation and on-going quality assurance and quality control of data acquisition and handling systems.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this document: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

## Introduction

This document forms part of a series of standards which, between them, govern the process for the quality assurance of data received by a data acquisition and handling system (DAHS) from automated measuring systems (AMS), being used for monitoring emissions from stationary sources and quality ensured to EN 14181.

The input data can be either in analogue representation or in digital form directly from an AMS or via a digital bus system. Inputs can include the data from the AMS, peripheral data needed for calculation of the reported values and information on plant conditions needed to apply data selection criteria.

The data acquisition and handling system (DAHS) receives the raw data, as they are measured, averaged and presented by the AMS, and converts, averages, stores and reports data as required by legislation.

This series of standards suggests that the process of data handling is best performed in a dedicated DAHS. It does not preclude the use of other options for all or part of the process provided that it can be shown to meet all of the requirements of the standard, particularly in relation to speed, accuracy, access, security and validation.

This series of standards applies to all DAHS installed after the date of implementation of this document.

EN 17255-2 specifies the implementation of the calculations laid down in EN 17255-1 and the specific requirements on functionality of the DAHS.

## 1 Scope

This document specifies the performance requirements on data acquisition and handling systems (DAHS) regarding implementation of the procedures defined in EN 17255-1 including

- data acquisition;
- data processing;
- data storage;
- data output;
- generation of reports;
- system functions;
- data integrity;
- documentation.

This document supports the requirements of EN 14181 and legislation such as the IED and E-PRTR. It does not preclude the use of additional features and functions provided the minimum requirements of this document are met and that these features do not adversely affect data quality, clarity or access.

## 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 14181:2014, *Stationary source emissions - Quality assurance of automated measuring systems*

EN 17255-1, *Stationary source emissions - Data acquisition and handling systems - Part 1: Specification of requirements for the handling and reporting of data*

IEEE 754, *Floating-point arithmetic*

## 3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 17255-1 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

### 3.1

#### **warning signal**

binary value or enumerated value signifying the need for action

Note 1 to entry: Warnings can be derived from measurement values or conditions, which are still within the specified limits, but where the value is close to the specified limit. Warnings are for the benefit of the plant operator.